

SEP 05 1984

Warren H. Owen
Executive Vice President,
Engineering and Construction
Duke Power Company
422 South Church Street
Charlotte, N.C. 28242

50-413

Dear Mr. Owen:

I am writing to express the NRC's appreciation for your assistance and for the cooperation of Duke Power Company in planning and conducting the July 19, 1984 development exercise for our Emergency Response Data System. The exercise was very successful in demonstrating the value of regular electronic data updates during emergencies. It was also extremely useful in developing the NRC's understanding of how to best manage and benefit from electronic data. Our Reactor Safety Team and Protective Measures Team personnel were very favorably impressed with the improvement it represents. A copy of our exercise report memorandum is enclosed for your information.

We are grateful for the time spent by Mike Glover, Ron Harris, and particularly, Greg Rogers in preparations prior to the actual exercise. Their efforts in adapting your Crisis Management Data Transmission System, to simulate the more limited transmissions expected from other licensees, provided a meaningful test of NRC's current ERDS concept.

We are also pleased to have had the practice with your Crisis Management Data Transmission System, particularly because it covers 7 nuclear units. It is reassuring that your system is available for our future use in the event that unfortunate circumstances should ever make it necessary.

Please pass along our thanks to all those involved in making this exercise a positive experience.

Sincerely,
Original Signed By:
E. L. Jordan

Edward L. Jordan, Director
Division of Emergency Preparedness
and Engineering Response
Office of Inspection and Enforcement

8409130011 XA

Enclosure: Exercise Report Memorandum

cc: R. Michael Glover, Duke Power Company
Ronald E. Harris, Duke Power Company
Randy Leonard, Duke Power Company
Gail Merritt, Duke Power Company
Greg Rogers, Duke Power Company

Distribution:

DCS S. Schwartz
IRB File ~~Long~~
DEPER Rdg. G. Lanik
E. Jordan E. Rossi
K. Perkins

bcc: William Orders, McGuire Resident Inspector
Phil Stohr, Region II

* For concurrence see previous page.

*DEPER: IE	DEPER: IE	DEPER: IE	IRB: DEPER: IE	D: DEPER: IE
S Long: dh	for Lanik	ERossi	KPerkins	EJordan
08/31/84	08/31/84	08/31/84	08/14/84	09/14/84

PARTICIPANTS

FACILITY:

DATE:

NAME

ORGANIZATION

PHONE

NAME	ORGANIZATION	PHONE
John B. Hickman	Incident Response NRC	(301) 492-4155
FRAYSER SIMPSON	Production Computer Applications Section	373-5757
James Eberle	Phoenix Associates	(301) 654 -0850
Peter Hastings	ONS Performance	(888) 882-2569
Alan D. Sweney	ONS I+E	882-2517
Randy Leonard	MNS Emerg. P/N	875-1357
Coleman Jennings	ONS Station Planner	882-5363
Brod McRee	GO Emergency Planning	(704) 373-5149

CONTACTS FOR DUKE ERDS/CRISIS MANAGEMENT DATA TRANSMITTAL SYSTEM

Ron Harris (704) 373-8669

Glenn Horne (704) 373-8552

Brad McRee (704) 373-5149
(Works for Ron Harris)

Greg Rogers (704) 373-6140 @ Corporate
(803) 324-3128 x2796 @ Catawba

Other Possible

Licensing - Corporate
Robert Sharpe (704) 373-8466

Technical Lead - SPDS
R. Morgan

H. J. Lee (Jackie)
J. Warren Steven (704) 373-4531

Electrical, I&C
Clay Little (704) 373-5166

PLANT DATA AND STATUS (EMERGENCY TSC USE)

09103:19A

PLANT STATUS

OAC COMPUTER POINT

PRIMARY SYSTEM

OAC COMPUTER POINT

AUXILIARY/INJECTION SYSTEMS

A0668	618.6 DEG F	NC LOOP A WIDE RANGE	HOT LEG TEMP	A0452	75.8 GPM	NV LETDOWN FLOW
A0669	613.5 DEG F	NC LOOP B WIDE RANGE	HOT LEG TEMP	A0820	112.2 GPM	CHARGING LINE FLOW CONTROL
A0670	616.9 DEG F	NC LOOP C WIDE RANGE	HOT LEG TEMP	A1262	95.8 %	FWST LEVEL CH 1
A0671	614.0 DEG F	NC LOOP D WIDE RANGE	HOT LEG TEMP	A1013	571.4 FT	SNSWP LEVEL
A0700	561.0 DEG F	NC LOOP A WIDE RANGE	COLD LEG TEM	A0586	4.219 KV	4KV BUS ETA VOLTS
A0706	555.8 DEG F	NC LOOP B WIDE RANGE	COLD LEG TEM	A0575	4.234 KV	4KV BUS ETB VOLTS
A0712	560.5 DEG F	NC LOOP C WIDE RANGE	COLD LEG TEM	D2450	OFF	CENTRIFUGAL CHARGING PUMP A
A0718	559.8 DEG F	NC LOOP D WIDE RANGE	COLD LEG TEM	D2440	ON	CENTRIFUGAL CHARGING PUMP B
P0828	624.0 DEG F	5-HIGHEST IN-CORE T/C TEMP		P1325	80 GPM	NC SYSTEM TOTAL EMERGENCY INJECTION FLOW
P1545	13.1 DEG F	LOWEST NC SYSTEM SUBCOOLING MARGI		D2456	OFF	NI PUMP A
P1389	2272 PSIA	NC SYSTEM PRESSURE, BEST ESTIMATE		D2456	OFF	NI PUMP B
A0713	2235 PSIG	PZR PRESS CH-1		A0902	0 GPM	ND HX A OUTLET FLOW
A0707	56.9 %	PZR LEVEL CH-1		A0908	0 GPM	ND HX B OUTLET FLOW
P0164	%	RVLIS TRAIN A UPPER RANGE		D2455	OFF	ND PUMP A
D2037	ON	REACTOR COOLANT PUMP A		D2445	OFF	ND PUMP B
D2085	ON	REACTOR COOLANT PUMP B				
D2038	ON	REACTOR COOLANT PUMP C				
D2086	ON	REACTOR COOLANT PUMP D				
A1214	293.7 PPM	CVCS BORON METER CONCENTRATION		A1499	0.2 F8IG	CONTAINMENT WIDE RANGE PRESSURE TRAIN A
A1248X	*****	SOURCE RANGE LEVEL CHANNEL 1		P1500	80.7 DEG F	UPPER CONT AVG TEMP - OPERATING UNITS
A0766	3.613E-01 MA	INTERMEDIATE RANGE LEVEL CHANNEL		A1418	0.7 FT	CONTAINMENT BUMP LEVEL A
P0738	99.6 %	POWER RANGE AVG LEVEL AVG		A0939	-7.5 %	CONTAINMENT HYDROGEN CONCENTRATION TRAIN A
				D2448	OFF	NS PUMP A
				D2438	OFF	NS PUMP B
				P0128	1.309E 04 CPM	EMF48 REACTOR COOLANT MONITOR
				A1308	1 R/HR	EMF53A CONT HIGH RANGE MONITOR TRAIN A
				A1314	6 W/HR	EMF53B CONT HIGH RANGE MONITOR TRAIN B
				A1315	3 R/HR	EMF54 UNIT VENT EXTENDED RANGE MONITOR
				A0048	2.829E 01 CPM	EMF37 UNIT VENT IODINE MONITOR
				P1822	1.232E 00 COUNTS	EMF37 UNIT VENT IODINE MONITOR
				A0013	1.113E 02 CPM	EMF37 DELTA COUNTS LAST 15 MINUTES
				A0019	1.336E 01 CPM	EMF36L UNIT VENT GAS MONITOR
				A0483	6.9 MPH	EMF36H UNIT VENT GAS MONITOR
				A0485	4.6 MPH	UPPER WIND SPEED
				A0484	152.7 DEG	LOWER WIND SPEED
				A0489	158.6 DEG	UPPER WIND DIRECTION
				A1127	29.609 IN HG	LOWER WIND DIRECTION
				A0490	-0.12 DEG C	BAROMETRIC PRESSURE
				A1172	9.6 DEG C	AMBIENT AIR D/T ELEV 662 & ELEV 762
				A0496	8.8 DEG C	AMBIENT AIR TEMP AT ELEV 662
				P0595	0.00 IN	DEWPOINT
				A1110	25.4 DEG	PRECIPITATION IN LAST 15 MIN
				A1104	46069 CFM	SIGMA THETA - LWR WIND DIRECTION STD-DEV
				P1483	50233 SPM	UNIT VENT STACK FLOW
						RL LINES A&B TOTAL AVG DISCHARGE FLOW

CONTAINMENT/RADIATION, ENVIRONMENTAL SYSTEMS

SECONDARY SYSTEM

A0674	62.4 %	S/G A WIDE RANGE LEVEL				
A0680	62.7 %	S/G B WIDE RANGE LEVEL				
A0686	62.2 %	S/G C WIDE RANGE LEVEL				
A0692	62.5 %	S/G D WIDE RANGE LEVEL				
A0723	1001 PSIG	S/G A STEAM PRESS CH #1				
A0729	999 PSIG	S/G B STEAM PRESS CH #1				
A0735	1021 PSIG	S/G C STEAM PRESS CH #1				
A0741	1006 PSIG	S/G D STEAM PRESS CH #1				
P0154	3.835 MLR/HR	S/G A FEEDWATER FLOW CH 1				
P0156	3.615 MLR/HR	S/G B FEEDWATER FLOW CH 1				
P0158	3.782 MLR/HR	S/G C FEEDWATER FLOW CH 1				
P0160	3.431 MLR/HR	S/G D FEEDWATER FLOW CH 1				
A0974	172 GPM	CA FLOW TO S/G A				
A0975	273 GPM	CA FLOW TO S/G B				
A0976	138 GPM	CA FLOW TO S/G C				
A0977	179 GPM	CA FLOW TO S/G D				
P0614	* LHM	TOTAL M/S RELEASED DURING LAST 15				

OTHER INFORMATION:

* LOCKED OUT * X = OUT OF SERVICE * S = BLOWN FUSE * * RAD VALUE

● Catawba

ERDS
Duke Power