


Limatorque Corporation

Automated Valve Actuators and Jacks for Industry
 5114 Woodall Road P.O. Box 11318 Lynchburg, VA 24506-1318
 Telephone—804-528-4400 • Telex—82-9448 • FAX—804-845-9736



June 1, 1989

U. S. Nuclear Regulatory Commission
 Washington, D. C. 20555

Re: Limatorque Corporation
 Part 21 Notification

Subject: Buchanan 724 Terminal Blocks

Attention: Director, Nuclear Reactor Regulation

Gentlemen:

Pursuant to the requirements of Title 10 of the Code of Federal Regulations Part 21 herein provided is notification of Limatorque Corporations inadvertent supply of Buchanan 724 terminal blocks for use in safety related SMB valve actuators, as detailed in the attached letter. In order to expedite the notification of the facilities affected, Limatorque has made simultaneous written notice to both the commission and the attached list of nuclear utility customers.

Signed:

I. E. Wilkinson
 Vice President of Engineering

LIMITORQUE CORPORATION

8906160209 890601
 PDR PT21 EMVLM
 89 FUL

IE19
 1/0