

52786

DISTRIBUTION:  
LQB R/F  
DHFS R/F (2)  
HBooher  
LCrocker  
DShum

APR 18 1985

MEMORANDUM FOR: Dennis Crutchfield, Assistant Director  
for Safety Assessment  
Division of Licensing

FROM: Don H. Beckham, Acting Deputy Director  
Division of Human Factors Safety

SUBJECT: SAFETY EVALUATION REPORT FOR PILGRIM STATION,  
GENERIC LETTER 83-28, ITEM 1.1 (POST-TRIP  
REVIEW) (TAC NO. 52786)

By letter dated November 7, 1983, the licensee of Pilgrim Station responded to Generic Letter 83-28 with regard to required actions based on generic implications of Salem ATWS events. The enclosed SER and SALP were prepared by the Licensee Qualifications Branch based upon TFR input from its contractor, Science Applications International Corporation (SAI), after having reviewed the applicable portions of the licensee's response to Generic Letter 83-28.

We find that the licensee's response does not meet the guidelines developed for post-trip review in the following areas:

1. The criteria for determining the need for independent assessment of the event.
2. The method and criteria for comparing the event with expected plant performance.
3. A systematic safety assessment program to assess unscheduled reactor trips.

We recommend that the licensee take necessary action to correct the deficiencies noted above, which are discussed in greater detail in Section III of the SER.

Acceptable responses to the above noted deficiencies are required before we can complete our review of the licensee's Post-Trip Review Program and Procedure for Pilgrim Station. We will review these responses when received and report our findings in a supplement to this SER.

2504290261XA JP

DHS6/MEMO FOR CRUTCH-PILGRIM *yes*

OFFICE	LQB	LQB	LQB	DHFS		
NAME	DShum: L	LCrocker	HBooher	DBeckham: ADD		
DATE	4/16/85	4/17/85	4/17/85	4/17/85		

E16

D. Crutchfield

-2-

APR 18 1964

This review has been conducted by D. Shum (x24906) and SAI. There are no known dissenting professional opinions on this matter.

*KS*  
Don H. Beckham, Acting Deputy Director  
Division of Human Factors Safety

Enclosures:

1. Safety Evaluation
2. SALP Evaluation

cc: A. Bournia  
J. Zwolinski  
G. Holahan