



**New York Power  
Authority**

John C. Brons  
Executive Vice President  
Nuclear Generation

June 14, 1989  
JPN-89-040

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-137  
Washington, D.C. 20555

SUBJECT: James A. FitzPatrick Nuclear Power Plant  
Docket No. 50-333  
Proposed Change to the Technical Specifications  
Regarding Suppression Chamber Water Temperature  
Indication (JPTS-89-006)

REFERENCE: 1. NYPA letter, W. Fernandez to NRC, dated  
March 20, 1989, (JAFF-89-0214), responds to  
Inspection Report 50-333/88-29.

Dear Sir:

This application for an amendment to the James A. FitzPatrick Technical Specifications proposes changes to Table 3.2-6, "Surveillance Instrumentation," on page 76a. These changes update the suppression chamber water temperature instrumentation to reflect modifications installed to meet Regulatory Guide 1.97.

These changes resolve one of the Technical Specification corrections committed to by the Authority in Reference 1.

Enclosed for filing is the signed original of a document entitled "Application for Amendment to Operating License," with Attachments I and II thereto, comprising a statement of the proposed change to the Technical Specifications and the associated Safety Evaluation.


In accordance with 10 CFR 50.91, a copy of this application and the associated attachments are being provided to the designated New York State official.

8906210050 890614  
PDR ADOCK 05000333  
P FDC

A003  
11

Should you or your staff have any questions regarding the proposed changes, please contact Mr. J. A. Gray, Jr. of my staff.

Very truly yours,

  
John C. Brons  
Executive Vice President  
Nuclear Generation

cc: U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Office of the Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 136  
Lycoming, NY 13093

Mr. David E. LaBarge  
Project Directorate I-1  
Division of Reactor Projects - I/II  
U.S. Nuclear Regulatory Commission  
Mail Stop 14 B2  
Washington, DC 20555

Ms. Donna Ross  
New York State Energy Office  
2 Empire State Plaza  
16th Floor  
Albany, NY 12223