



Log # TXX-89419
File # 10130
IR 89-12
IR 89-12
Ref # 10CFR2.201

June 15, 1989

William J. Cahill, Jr.
Executive Vice President

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
LOCKET NOS. 50-445 AND 50-446
REVISED DATE OF FULL COMPLIANCE FOR NOTICE
OF VIOLATION (NOV) ITEM A (445/8912-V-01)

REF: TU Electric letter logged TXX-89209 from W. J. Cahill to USNRC dated
April 24, 1989

Gentlemen:

The referenced letter provided our response to Notice of Violation Item A (445-8912-V-01). In that response we stated that replacement of low strength bolts with high strength bolts in NPSI snubbers would be completed no later than June 15, 1989. Completion of this work has taken longer than expected. We anticipate that bolt replacement for the snubbers will be completed no later than July 31, 1989.

Sincerely,

William J. Cahill, Jr.

By: J. S. Marshall
J. S. Marshall
Generic Licensing Manager

BSD/vld

c - Mr. R. D. Martin, Region IV
Resident Inspectors, CPSES (3)

8906230121 890615
PDR ADOCK 05000445
Q PNU

IE01
1/0