

APPENDIX A

NOTICE OF VIOLATION

Philadelphia Electric Company
Limerick 1

Docket No. 50-352
License No. NPF-39

As a result of the inspection conducted on March 18 - May 16, 1987 and in accordance with the NRC Enforcement Policy (10 CFR 2, Appendix C), the following violation was identified:

10 CFR 50 Appendix B Criterion V requires that "activities affecting quality shall be prescribed by documented procedures and shall be accomplished in accordance with these procedures."

Administrative Procedure A-12.2, Control of Combustible Materials, prohibits the unattended storage of any combustible material in areas designed as combustible free zones.

Contrary to the above, on May 12, 1987 in Area 15 of Reactor Enclosure Elevation 27 (Fire Zone 44), numerous combustible items, equivalent to about two bags of trash, were found unattended in a designated combustible free zone.

This is a severity level V violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, Philadelphia Electric Company is hereby required to submit to this office within thirty days of the date of the letter which transmitted this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending this response time.

8707010130 870618
PDR ADOCK 05000352
Q PDR