



GPU Nuclear Corporation  
Post Office Box 480  
Route 441 South  
Middletown, Pennsylvania 17057  
717 944-7621  
TELEX 84-2386  
Writer's Direct Dial Number:

C311-89-2047  
April 18, 1989

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

Dear Sir:

Three Mile Island Nuclear Station, Unit 1 (TMI-1)  
Operating License No. DPR-50  
Docket No. 50-289  
TMI Action Plan Items - Status

This is in response to the NRC's letter of April 14, 1989 requesting GPUN's prompt review and a report on the implementation status of TMI Action Plan Items at TMI-1. We have included the information as requested in the column labeled "Licensee Implementation Status".

We certify that the items reported (as indicated by a "C") are complete where, to the best of our knowledge, all GPUN actions necessary to satisfactorily meet the requirements of NUREG-0737 and Supplement 1 have been completed. Where the documentation was available, our markup also shows the date when the item was completed. Where items are indicated as being complete, we do not differentiate whether a change was necessary. Items that were not applicable to TMI-1 are indicated by "NA".

Because of the brief description given for the items that were broken down into subitems, some of the entries on the list were not entirely clear. Therefore, we feel that it is necessary to say that this information is accurate only insofar as we have been able to identify, within the short time allowed by your request, exactly what each of the items (subitems) represent.

Sincerely,

H. D. Hukill  
Vice President and Director, TMI-1

Attachment  
HDH/MRK

cc: T. Murley  
J. Stolz  
F. Young  
W. Russell  
R. Hernan

8904260185 890418  
PDR ADDCK 05000289  
PDC  
P

A046  
11

TMI-1

LICENSEE IMPLEMENTATION STATUS

MULTI-PLANT  
ACTION NO.

ISSUE TITLE

ISSUE NUMBER	MULTI-PLANT ACTION NO.	ISSUE TITLE	LICENSEE IMPLEMENTATION STATUS	DATE
I.A.1.1.1		SHIFT TECHNICAL ADVISOR - ON DUTY	C	6/80
*I.A.1.1.2		SHIFT TECHNICAL ADVISOR - TECH SPECS	C	4/82
*I.A.1.1.3	F001	SHIFT TECHNICAL ADVISOR - TRAINED PER LL CAT B	C	4/81
*I.A.1.1.4		SHIFT TECHNICAL ADVISOR - DESCRIBE LONG TERM PROGRAM	C	3/81
I.A.1.2		SHIFT SUPERVISOR RESPONSIBILITIES	C	1/80
I.A.1.3.1	F002	SHIFT MANNING - LIMIT OVERTIMES	C	3/81
I.A.1.3.2	F002	SHIFT MANNING - MIN SHIFT CREW	C	3/81
I.A.2.1.1		IMMEDIATE UPGRADING OF RO & SRO TRAINING AND QUAL - SRO EXPR	C	8/80
I.A.2.1.2		IMMEDIATE UPGRADING OF RO & SRO TRAINING AND QUAL - SRO'S BE RO'S 1YR	C	8/80
I.A.2.1.3		IMMEDIATE UPGRADING OF RO & SRO TRAINING AND QUAL - 3 MO. TRAINING	C	8/80
I.A.2.1.4	F003	IMMEDIATE UPGRADING OF RO & SRO TRAINING AND QUAL - MODIFY TRAINING	C	1/80
I.A.2.1.5		IMMEDIATE UPGRADING OF RO & SRO TRAINING AND QUAL - FACILITY CERTIF	C	8/80
I.A.2.3		ADMINISTRATION OF TRAINING PROGRAMS	C	8/80
I.A.3.1.1		REVISE SCOPE & CRITERIA FOR LICENSING EXAMS - INCREASE SCOPE	C	10/80
I.A.3.1.2		REVISE SCOPE & CRITERIA FOR LICENSING EXAMS - INCREASE PASSING GRADE	C	6/80
I.A.3.1.3.A		REVISE SCOPE & CRIT. FOR LIC. EXAMS - SIMULATOR PLANTS WITH SIMULATORS	NA	
I.A.3.1.3.B		REVISE SCOPE & CRIT. FOR LIC. EXAMS - SIMULATOR - OTHER PLANTS	C	2/82
*I.B.1.2		EVALUATION OF ORGANIZATION & MANAGEMENT	NA	NTOL
I.C.1.1		SHORT-TERM ACCIDENT & PROCEDURES REVIEW - SB LOCA	C	6/80
I.C.1.2.A	F004	SHORT-TERM ACCID. & PROCEDURES REV. - INADEQ. CORE COOL. REANAL. GUIDELINES	C	6/80
I.C.1.2.B	F004	SHORT-TERM ACCID. & PROCEDURES REV. - INADEQ. CORE COOL. REVISE PROCEDURES	C	1/84
I.C.1.3.A	F005	SHORT-TERM ACCID. & PROCEDURES REV. - TRANSIENTS & ACCDTS. REANAL GUIDELINES (PROC. GEN. PKG.)	C	1/84
I.C.1.3.B	F005	SHORT-TERM ACCID. & PROCEDURES REV. - TRANSIENTS & ACCDTS. REVISE PROCEDURES (UPGRADED FOP'S)	C	1/80
I.C.2		SHIFT & RELIEF TURNOVER PROCEDURES	C	11/80
I.C.3		SHIFT-SUPERVISOR RESPONSIBILITY	C	11/80
I.C.4		CONTROL-ROOM ACCESS	C	11/80
I.C.5	F006	FEEDBACK OF OPERATING EXPERIENCE	C	4/82
I.C.6	F007	VERIFY CORRECT PERFORMANCE OF OPERATING ACTIVITIES	C	4/82
*I.C.7.1		MSSS VENDOR REV. OF PROC - LOW POWER TEST PROGRAM	NA	NTOL
*I.C.7.2		MSSS VENDOR REV. OF PROC - POWER ASCENSION & EMER. PROC.	NA	NTOL
*I.C.8		PILOT MON OF SELECTED EMERGENCY PROC FOR NTOLS	NA	NTOL
I.D.1 (See FG08 & F071)		CONTROL-ROOM DESIGN REVIEWS (ENTER DATA FOR MPA F008 & MPA F-071)	C	5/84
I.D.2.1	F009	PLANT-SAFETY PARAMETER DISPLAY CONSOLE - DESCRIPTION	C	3/81



TMI-1

LICENSEE IMPLEMENTATION STATUS

ISSUE NUMBER	MULTI-PLANT ACTION NO.	ISSUE TITLE		
I.D.2.2	F009	PLANT-SAFETY PARAMETER DISPLAY CONSOLE - INSTALLED.	C	3/87
I.D.2.3	F009	PLANT-SAFETY PARAMETER DISPLAY CONSOLE - FULLY IMPLEMENTED.	C	
*I.G.1.1		TRAINING DURING LOW-POWER TESTING - PROPOSE TESTS.	NA	NTOL #
*I.G.1.2		TRAINING DURING LOW-POWER TESTING - SUBMIT ANAL. & PROCS.	NA	
*I.G.1.3		TRAINING DURING LOW-POWER TESTING - TRAINING & RESULTS.	NA	(NJD)
II.B.1.1		REACTOR-COOLANT SYSTEM VENTS - DESIGN VENTS.	NA	NTOL
II.B.1.2	F010	REACTOR-COOLANT SYSTEM VENTS - INSTALL VENTS (LL CAT B)	C	7/85
II.B.1.3	F010	REACTOR-COOLANT SYSTEM VENTS - PROCEDURES.	C	7/84
II.B.2.1		PLANT SHIELDING - REVIEW DESIGNS.	C	5/84
*II.B.2.2		PLANT SHIELDING - CORRECTIVE ACTIONS TO ASSURE ACCESS.	C	12/84
*II.B.2.3		PLANT SHIELDING - PLANT MODIFICATIONS (LL CAT B)	C	9/82
*II.B.2.4	F011	PLANT SHIELDING - EQUIPMENT QUALIFICATION- NOT TRACKED AS A TMI ACTION ITEM.	C	7/84
*II.B.3.1		POSTACCIDENT SAMPLING - INTERIM SYSTEM.	C	4/85
*II.B.3.2		POSTACCIDENT SAMPLING - CORRECTIVE ACTIONS.	C	4/84
*II.B.3.3		POSTACCIDENT SAMPLING - PROCEDURES.	C	11/84
*II.B.3.4	F012	POSTACCIDENT SAMPLING - PROCEDURES.	C	
II.B.4.1	F013	TRAINING FOR MITIGATING CORE DAMAGE - PLANT MODIFICATIONS (LL CAT B)	C	7/84
*II.B.4.2.A	F013	TRAINING FOR MITIGATING CORE DAMAGE - DEVELOP TRAINING PROGRAM.	C	4/81
*II.B.4.2.B	F013	TRAINING FOR MITIGATING CORE DAMAGE - INITIAL	C	4/81
II.D.1.1		TRAINING FOR MITIGATING CORE DAMAGE - COMPLETE.	C	3/83
*II.D.1.2.A		RELIEF & SAFETY VALVE TEST REQUIREMENTS - SUBMIT PROGRAM.	C	7/84
*II.D.1.2.B	F014	RELIEF & SAFETY VALVE TEST REQUIREMENTS - COMPLETE TESTING.	C	7/84
II.D.1.3		RELIEF & SAFETY VALVE TEST REQUIREMENTS - PLANT SPECIFIC REPORT.	C	7/84
*II.D.3.1		RELIEF & SAFETY VALVE TEST REQUIREMENTS - BLOCK-VALVE TESTING.	C	7/84
*II.D.3.2		VALVE POSITION INDICATION - INSTALL DIRECT INDICATIONS OF VALVE POS.	C	9/85
*II.E.1.1.1	F015	VALVE POSITION INDICATION - TECH SPECS.	C	10/84
(SEE NOTE 1)		AFS EVALUATION-ANALYSIS.	C	1/86
*II.E.1.1.2	F015	AFS EVALUATION-SHORT TERM MODS.	C	1/86
(SEE NOTE 2)				
II.E.1.1.3	F015	AFS -LONG TERM MODS.	C	4/87
(SEE NOTE 3)				

NOTE 1 - THE ITEM LISTED IS FROM NUREG-0737, ENCLOSURE 2 AND IS APPLICABLE TO NTOLS'S ONLY  
 NOTE 2 - THE ITEM LISTED IS FOR ALL PLANTS (OPERATING REACTORS AND NTOL'S)  
 NOTE 3 - THE ITEM LISTED IS FOR ALL PLANTS (OPERATING REACTORS AND NTOL'S)

# For the purposes of this review, we understand that R.G. 1.97 modifications are excluded per NRC letter of April 14, 1989.

TMI-1

ISSUE NUMBER ACTION NO. MULTI-PLANT

ISSUE TITLE

LICENSEE IMPLEMENTATION STATUS

ISSUE NUMBER	ACTION NO.	MULTI-PLANT	ISSUE TITLE	LICENSEE IMPLEMENTATION STATUS	DATE
II.E.1.2.1.A	F016		AFS INITIATION & FLOW-CONTROL GRADE	C	10/85
II.E.1.2.1.B			AFS INITIATION & FLOW - SAFETY GRADE	C	3/87
II.E.1.2.2.A			AFS INITIATION & FLOW - FLOW INDICATION CONTROL GRADE	C	4/81
II.E.1.2.2.B			AFS INITIATION & FLOW - LL CAT A TECH SPECS	C	10/84
II.E.1.2.2.C	F017		AFS INITIATION & FLOW - SAFETY GRADE	C	5/84
II.E.3.1.1			EMERGENCY POWER FOR PRESSURIZER HEATERS - UPGRADE POWER SUPPLY	C	9/85
II.E.3.1.2			EMERGENCY POWER FOR PRESSURIZER HEATERS - TECH SPECS	C	9/84
II.E.4.1.1			DEDICATED HYDROGEN PENETRATIONS - DESIGN	C	1/81
II.E.4.1.2			DEDICATED HYDROGEN PENETRATIONS - REVIEW & REVISE H2 CONTROL PROC.	C	
II.E.4.1.3	F018		DEDICATED HYDROGEN PENETRATION - INSTALL	C	9/85
II.E.4.2.1-4			CONTAINMENT ISOLATION DEPENDABILITY - IMP. DIVERSE ISOLATION	C	6/86
II.E.4.2.5.A			CONTAINMENT ISOLAT. DEPENDABILITY - CNTMT PRESS. SEPT. SPECIFY PRESS.	C	4/81
II.E.4.2.5.B			CONTAINMENT ISOLATION DEPENDABILITY - CNTMT PRESSURE SEPT. MODS.	C	4/81
II.E.4.2.6	F019		CONTAINMENT ISOLATION DEPENDABILITY - CNTMT PURGE VALVES	C	6/86
II.E.4.2.7	F019		CONTAINMENT ISOLATION DEPENDABILITY - RADIATION SIGNAL ON PURGE VALVES	C	4/81
II.E.4.2.8			CONTAINMENT ISOLATION DEPENDABILITY - TECH SPECS	C	5/85
II.F.1.1	F020		ACCIDENT - MONITORING - PROCEDURES	C	2/84
II.F.1.2.A	F020		ACCIDENT - MONITORING - MOBILE GAS MONITOR	C	2/84
II.F.1.2.B	F021		ACCIDENT - MONITORING - IODINE/PARTICULATE SAMPLING	C	2/84
II.F.1.2.C	F022		ACCIDENT - MONITORING - CONTAINMENT HIGH-RANGE MONITOR	C	1/84
II.F.1.2.D	F023		ACCIDENT - MONITORING - CONTAINMENT PRESSURE	C	9/85
II.F.1.2.E	F024		ACCIDENT - MONITORING - CONTAINMENT WATER LEVEL	C	1/83
II.F.1.2.F	F025		ACCIDENT - MONITORING - CONTAINMENT HYDROGEN	C	3/84
II.F.2.1			INSTRUMENTATION FOR DETECT. OF INADEQUATE CORE COOLING - PROCEDURES	C	9/85
II.F.2.2			INSTRUMENTATION FOR DETECT. OF INADEQUATE CORE COOLING - SUBCOOL METER	C	4/85
II.F.2.3	F026		INSTRUMENTATION FOR DETECT. OF INADEQUATE CORE COOLING - DESC. OTHER	C	3/87
II.F.2.4	F026		INSTRUMENTATION FOR DETECT. OF INADEQUATE CORE CLING INST'L INSTRUMENTATION	C	3/87
II.G.1.1			POWER SUPP. FOR PRESSURIZER RELIEF, BLOCK VALVES & LEVEL IND. - UPGRADE	C	4/81
II.G.1.2			POWER SUPP. FOR PRESSURIZER RELIEF, BLOCK VALVES & LEVEL IND. - TECH SP.	C	9/84
II.K.1 (Oper. Reactors Only)			IE BULLETINS - 79-05, 79-06, 79-08	C	7/84



TMI-1

LICENSEE IMPLEMENTATION STATUS

ISSUE NUMBER      MULTI-PLANT ACTION NO.      ISSUE TITLE

*II.K.1.5		IE BULLETINS - REVIEW ESF VALVES.....	C	1/81
*II.K.1.10		IE BULLETINS - OPERABILITY STATUS.....	C	1/81
*II.K.1.20		IE BULLETINS - PROMPT MANUAL REACTOR TRIP.....	C	1/84
*II.K.1.21		IE BULLETINS - AUTO SG ANTICIPATORY REACTOR TRIP.....	C	10/84
*II.K.1.22		IE BULLETINS - AUX. HEAT REM SYSTEM, PROC.....	NA	NIOL
*II.K.1.23		IE BULLETINS - RV LEVEL, PROCEDURES.....	NA	NIOL
*II.K.2.2		ORDERS ON B&W PLANTS - PROCEDURES TO CONTROL AFW IND OF ICS.....	NA	NIOL
*II.K.2.8		ORDERS ON B&W PLANTS - UPGRADE AFW SYSTEM.....	C	3/87
F027		ORDERS ON B&W PLANTS - FEMA ON ICS.....	C	6/82
F028		ORDERS ON B&W PLANTS - SAFETY-GRADE TRIP.....	C	1/86
F029		ORDERS ON B&W PLANTS - OPERATOR TRAINING.....	C	6/80
F030		ORDERS ON B&W PLANTS - THERMAL MECHANICAL REPORT (CE & W PLANTS ALSO).....	C	7/80
F031		ORDERS ON B&W PLANTS - LIFT FREQUENCY OF PORV'S & SV'S.....	C	7/84
II.K.2.15		ORDERS ON B&W PLANTS - EFFECTS OF SLUG FLOW.....	C	1/81
II.K.2.16		ORDERS ON B&W PLANTS - RCP SEAL DAMAGE.....	C	1/81
II.K.2.17		ORDERS ON B&W PLANTS - VOIDING IN RCS (CE & W PLANTS ALSO).....	C	1/81
II.K.2.19		BENCHMARK ANALYSIS OF SEQUENTIAL AFW FLOW TO ONCE THROUGH SIM GENERATOR.....	C	1/81
*II.K.2.20		ORDERS ON B&W PLANTS - SYSTEM RESPONSE TO SB LOCA.....	C	1/81
*II.K.3.1.A		B&O TASK FORCE - AUTOMATIC PORV ISOLATION DESIGN.....	NA	
*II.K.3.1.B		FINAL RECOMMENDATIONS, B&O TASK FORCE - AUTO PORV ISO TEST/INSTALL.....	NA	
II.K.3.2		B&O TASK FORCE - REPORT ON PORV FAILURES.....	C	9/81
II.K.3.3		B&O TASK FORCE - REPORTING SV & RV FAILURES AND CHALLENGES.....	C	10/80
II.K.3.5.A		B&O TASK FORCE - AUTO TRIP OF RCP'S PROPOSED MODIFICATIONS.....	C	3/83
II.K.3.5.B		B&O TASK FORCE - AUTO TRIP OF RCP'S MODIFICATIONS.....	C	3/87
II.K.3.7		B&O TASK FORCE - EVALUATION OF PORV OPERATIONAL ABILITIES.....	C	9/81
II.K.3.9		B&O TASK FORCE - PID CONTROLLER MODIFICATION.....	NA	
II.K.3.10		B&O TASK FORCE - PROPOSED ANTICIPATORY TRIP MODIFICATIONS.....	NA	
II.K.3.11		B&O TASK FORCE - JUSTIFY USE OF CERTAIN PORV.....	NA	
II.K.3.12.A		B&O TASK FORCE - ANTICIPATORY TRIP ON TURBINE TRIP PROPOSED MODS.....	NA	
II.K.3.12.B		B&O TASK FORCE - ANTICIPATORY TRIP ON TURBINE TRIP INSTALL MODS.....	NA	
II.K.3.13.A		B&O TASK FORCE - HPCI & RCIC SYSTEM INITIATION LEVELS ANALYSIS.....	NA	
II.K.3.13.B		B&O TASK FORCE - HPCI & RCIC INITIATION LEVELS MODIFICATION.....	NA	

TMI-1

LICENSE IMPLEMENTATION STATUS

MULTI-PLANT  
ACTION NO.

ISSUE TITLE

ISSUE NUMBER	MULTI-PLANT ACTION NO.	ISSUE TITLE	LICENSE IMPLEMENTATION STATUS
*II.K.3.14	F044	B&O TASK FORCE - ISO CONDENSER ISOLATION ON HIGH RAD	NA
II.K.3.15	F045	B&O TASK FORCE - MODIFY HPCI & RCIC BRK DETECTION CIRCUITRY	NA
II.K.3.16A	F046	B&O TASK FORCE - CHALLENGE & FAILURE OF RELIEF VALVES STUDY	NA
II.K.3.16 B	F046	B&O TASK FORCE - CHALLENGE & FAILURE OF RELIEF VALVES MODIFICATIONS	NA
II.K.3.17	F047	B&O TASK FORCE - ECC SYSTEM OUTAGES	NA
II.K.3.18. A	F048	B&O TASK FORCE - ADS ACTUATION STUDY	C 9/81
II.K.3.18. B	F048	B&O TASK FORCE - ADS ACTUATION PROPOSED MODIFICATIONS	NA
II.K.3.18. C	F048	B&O TASK FORCE - ADS ACTUATION MODIFICATIONS	NA
*II.K.3.19	F049	B&O TASK FORCE - INTERLOCK RECIRCULATORY PUMP MODIFICATIONS	NA
*II.K.3.20	F049	B&O TASK FORCE - LOSS OF SVC WATER AT BRP	NA
II.K.3.21. A	F050	B&O TASK FORCE - RESTART OF CSS & LPCI LOGIC DESIGN	NA
II.K.3.21. B	F050	B&O TASK FORCE - RESTART OF CSS & LPCI LOGIC DESIGN MODIFICATIONS	NA
II.K.3.22. A	F051	B&O TASK FORCE - RCIC SUCTION VERIFICATION PROCEDURES	NA
II.K.3.22. B	F051	B&O TASK FORCE - RCIC SUCTION MODIFICATION	NA
II.K.3.24	F052	B&O TASK FORCE - SPACE COOLING FOR HPCI/RCI LOSS OF AC POWER	NA
II.K.3.25. A	F053	B&O TASK FORCE - POWER ON PUMP SEALS PROPOSED MODIFICATIONS	NA
II.K.3.25. B	F054	B&O TASK FORCE - POWER ON PUMP SEALS MODIFICATIONS	NA
II.K.3.27	F054	B&O TASK FORCE - COMMON REFERENCE LEVEL FOR BWRs	NA
II.K.3.28	F055	B&O TASK FORCE - QUALIFICATION OF ADS ACCUMULATORS	NA
*II.K.3.29	F056	B&O TASK FORCE - PERFORMANCE OF ISOLATION CONDENSERS	NA
II.K.3.30. A	F057	B&O TASK FORCE - SCHEDULE FOR OUTLINE OF SB LOCA MODEL	C 1/85
II.K.3.30. B	F057	B&O TASK FORCE - SB LOCA MODEL, JUSTIFICATION	C 8/85
II.K.3.30. C	F057	B&O TASK FORCE - SB LOCA METHODS NEW ANALYSES	C 12/86
II.K.3.31	F058	B&O TASK FORCE - COMPLIANCE WITH CFR 50.46	C 1/81
*II.K.3.40	F059	B&O TASK FORCE - RCP SEAL DAMAGE - COVERED BY II.K.2.16 AND II.K.3.25	C 1/81
*II.K.3.43	F059	B&O TASK FORCE - EFFECTS OF SLUG FLOW - COVERED BY II.K.2.15	C 1/81
II.K.3.44	F060	B&O TASK FORCE - EVALUATE TRANSIENT WITH SINGLE FAILURE	C 1/81
II.K.3.45	F060	B&O TASK FORCE - ANALYSES TO SUPPORT	NA
II.K.3.46	F061	RESPONSE TO LIST OF CONCERNS FROM ACRS CONSULTANT	NA
*II.K.3.57	F062	IDENTIFY WATER SOURCES PRIOR TO MANUAL ACTIVATION OF ADS	NA
III.A.1.1	F062	EMERGENCY PREPAREDNESS, SHORT TERM	C 7/81



TMI-1

ISSUE NUMBER	MULTI-PLANT ACTION NO.	ISSUE TITLE	LICENSEE IMPLEMENTATION STATUS	#
III.A.1.2.1		UPGRADE EMERGENCY SUPPORT FACILITIES - INTERIM TSC OSC & EOF	C	4/81
III.A.1.2.2		UPGRADE EMERGENCY SUPPORT FACILITIES-DESIGN-INCORP. INTO F063/F064/F065	C	-/83
(SEE F063, F064, F065)				
III.A.1.2.3		UPGRADE EMERGENCY SUPPORT FACILITIES - MODS INCORPOR. INTO F063, F064 & F065.	C	#
(SEE F063, F064, F065)				
III.A.2.1	F067	UPGRADE PREPAREDNESS - UPGRADE EMERGENCY PLANS TO APP. E. 10 CFR 50.	C	12/80
III.A.2.2	F068	UPGRADE PREPAREDNESS - METEOROLOGICAL DATA.	C	4/83
*III.D.1.1.1		PRIMARY COOLANT OUTSIDE CONTAINMENT - LEAK REDUCTION.	C	5/85
*III.D.1.1.2		PRIMARY COOLANT OUTSIDE CONTAINMENT - TECH SPECS.	C	8/82
III.D.3.3.1	F069	IMPLANT RAD. MONIT. - PROVIDE MEANS TO DETER. PRESENCE OF RADIOIODINE.	C	2/84
III.D.3.3.2	F070	IMPLANT RADIATION MONIT. - MODIFICATIONS TO ACCURATELY MEAS. IODINE.	C	2/84
III.D.3.4.1	F070	CONTROL ROOM HABITABILITY - REVIEW	C	5/86
*III.D.3.4.2		CONTROL ROOM HABITABILITY - SCHEDULE MODIFICATIONS.	C	2/85
*III.D.3.4.3		CONTROL ROOM HABITABILITY - IMPLEMENT MODIFICATIONS.	C	3/87
MPA-F008	F008	I.D.1.1 DETAILED CONTROL ROOM DESIGN REVIEW PROGRAM PLAN.	C	2/85
MPA-F063	F063	III.A.1.2 TECHNICAL SUPPORT CENTER.	C	11/83
MPA-F064	F064	III.A.1.2 OPERATIONAL SUPPORT CENTER.	C	4/83
MPA-F065	F065	III.A.1.2 EMERGENCY OPERATIONS FACILITY.	C	11/83
MPA-F071	F071	I.D.1.2 DETAILED CONTROL ROOM REVIEW (FOLLOWUP TO F-8)	C	2/85
MPA-B072	B072	MUREG-0737 TECH SPECS (GENERIC LETTERS 82-16 & 83-02)	C	-/82
MPA-B083	B083	TECH SPEC COVERED BY GENERIC LETTERS 83-26 & 83-37 FOR MUREG-0737.	C	12/88
67.4.1	G001	REACTOR COOLANT PUMP TRIP (GENERIC LETTER 85-12)	C	3/87

# For the purposes of this review, we understand that R.G. 1.97 modifications are excluded per NRC letter of April 14, 1989.