

APR 19 1989

In Reply Refer To:
Docket: 50-458

Gulf States Utilities
ATTN: Mr. James C. Deddens
Senior Vice President (RBNG)
P.O. Box 220
St. Francisville, Louisiana 70775

Gentlemen:

This documents a management meeting with GSU on April 7, 1989, in the NRC Region IV office. The meeting was held in response to our request to discuss the River Bend Station service water system corrosion control, inspection, and corrective actions programs.

The topics covered during your presentation are described in the enclosed meeting summary.

It is our opinion that the meeting was beneficial and has provided a better understanding of your service water and fire protection system corrosion control programs including your planned actions relating to determining operability of the systems, prior to resumption of operation, following the present refueling outage.

In accordance with Section 2.790 of the NRC's "Rules of Practice," Part 2, Title 10, Code of Federal Regulations, a copy of this letter will be placed in the NRC's Public Document Room.

Should you have any questions concerning this matter, we will be pleased to discuss them with you.

Sincerely,

Original Signed By
T. F. Westerman

L. J. Callan, Director
Division of Reactor Projects

8904260432 890419
PDR ADOCK 05000458
P PNU

Enclosure:
Meeting Summary

cc: (see next page)

RIV:DRP/C *[Signature]*
GLMadsen;df
4/13/89

C:DRP/C *[Signature]*
GLConstable
4/13/89

D:DRP/C *[Signature]*
LJCallan
4/14/89

1/1
IE45

Gulf States Utilities

-2-

cc w/enclosures:

Gulf States Utilities

ATTN: J. E. Booker, Manager-
River Bend Oversight

P.O. Box 2951

Beaumont, Texas 77704

Gulf States Utilities

ATTN: Les England, Director
Nuclear Licensing - RBNG

P.O. Box 220

St. Francisville, Louisiana 70775

Louisiana State University,
Government Documents Department

Louisiana Radiation Control Program Director

bcc to DMB (IE45)

bcc distrib. by RIV:

DRP

R. D. Martin, RA

Lisa Shea, RM/ALF

RPB-DRSS

Project Engineer (DRP/C)

W. Paulson, NRR Project Manager (MS: 13-D-18)

RRI

Section Chief (DRP/C)

MIS System

RSTS Operator

RIV File

DRS

MEETING SUMMARY

Licensee: Gulf States Utilities (GSU)

Facility: River Bend Station

License No.: NPF-45


Docket No.: 50-458

Subject: Service Water System Corrosion Program

On April 7, 1989, representatives of GSU met with Region IV personnel in the NRC office in Arlington, Texas. The meeting was held at the request of NRC Region IV.

Topics discussed included the service water and fire water systems corrosion control, inspection, and corrective actions programs. Included in the discussions were your planned actions for assuring operability of the systems prior to resumption of operation following the ongoing refueling outage and your plans for utilizing planned midrefueling cycle outages in the future.

It is our opinion that the meeting was beneficial and informative.



L. J. Callan, Director
Division of Reactor Projects

Attachments:

1. Attendance List
2. Meeting Agenda

ATTENDANCE LIST

Attendance at the GSU - NRC meeting on April 7, 1989, at the NRC Region IV office:

GSU

J. C. Deddens, Senior Vice President, River Bend Nuclear Group
T. F. Plunkett, Plant Manager
J. E. Booker, Manager, River Bend Oversight
L. A. England, Director, Nuclear Licensing
J. R. Hamilton, Director, Design Engineering
M. F. Sankovich, Manager, Engineering Department
C. W. Walker, Supervisor, Quality Control
J. G. Morris, Senior Mechanical Engineer

NRC, Region IV

L. J. Callan, Director, Division of Reactor Projects
J. L. Milhoan, Director, Division of Reactor Safety
T. F. Westerman, Acting Deputy Director, Division of Reactor Projects
J. P. Jaudon, Deputy Director, Division of Reactor Safety
G. L. Constable, Chief, Projects Section C
I. Barnes, Chief, Materials & Quality Programs Section
G. L. Madsen, Project Engineer
E. J. Ford, Senior Resident Inspector

NRC, NRR (by telecommunications)

D. L. Wigginton, Backup Project Manager
W. Hodges, Chief, Reactor Systems Branch
T. E. Collins, Section Chief, Reactor Systems Branch
J. A. Kudrick, Section Chief, Plant Systems Branch
F. J. Witt, Chemical Engineering Branch

AGENDA
APRIL 7, 1989
SERVICE WATER SYSTEM
CORROSION INSPECTION PROGRAM

- o Introductions L. A. England
- o Opening Remarks J. C. Deddens
- o Overview M. F. Sankovich
- o RBS Corrosion Program J. G. Morris
- o RF-2 Supplemental Evaluations M. F. Sankovich
 - Examples Found
 - Heat Exchanger Performance Trends
 - Valve Seat Leakage
 - Pipe/Weld Inspections/Integrity (J. R. Hamilton)
 - Instrument Line Inspections
 - Standby Service Water
- o Fire Protection System C. W. Walker
- o Future Plans J. C. Deddens