

NORTH ANNA 1 CYCLE 8 RPDC PATTERN AN CORE SURVEILLANCE REPORT  
June 5th, 1989

8906260207 890626  
PDR ADDCK 050003L :  
P PDC

## NORTH ANNA UNIT 1 CYCLE 8 CORE SURVEILLANCE REPORT

This Core Surveillance Report is provided in accordance with Section 6.9.1.7 of the North Anna Unit 1 Technical Specifications.

The burnup-dependent Cycle 8  $N(z)$  function for Technical Specification 4.2.2.2.C is shown in Figures 1-6.  $N(z)$  was calculated according to the procedure of VEP-NE-1-A.

The  $N(z)$  function\* will be used to confirm that the heat flux hot channel factor,  $FQ(z)$ , will be limited to the Technical Specifications values of

$$FQ(z) \leq \frac{2.19 K(z)}{P}, \quad P > 0.5 \text{ and}$$

$$FQ(z) \leq 4.38 K(Z), \quad P \leq 0.5.$$


The Cycle 8 Axial Flux Difference (AFD) limits for Technical Specification 3.2.1 are shown in Figure 7. These limits were calculated according to the methods of VEP-NE-1-A and are comparable to the Cycle 7 limits.

The limits on Axial Flux Difference assure that the  $FQ(z)$  upper bound envelope is not exceeded during either normal operation or in the event of xenon redistribution following power changes.

---

\*The  $N(z)$  function, when applied to a power distribution measured under equilibrium conditions, demonstrates that the initial conditions assumed in the LOCA analysis are met, along with the ECCS acceptance criteria of 10CFR50.46.

FIGURE 1 - N(Z) FUNCTION FOR N1C8 AT 2893 MW  
 FROM 0 to 1000 MWD/MTU BURNUP  
 TOP AND BOTTOM 15 PERCENT EXCLUDED  
 AS PER TECH SPEC 4.2.2.2.G



HEIGHT (FEET)	N(Z)
1.80	1.253
2.00	1.245
2.20	1.236
2.40	1.226
2.60	1.216
2.80	1.204
3.00	1.192
3.20	1.180
3.40	1.167
3.60	1.157
3.80	1.148
4.00	1.143
4.20	1.139
4.40	1.136
4.60	1.131
4.80	1.124
5.00	1.117
5.20	1.109
5.40	1.104
5.60	1.101
5.80	1.104
6.00	1.107
6.20	1.112
6.40	1.114
6.60	1.120
6.80	1.127
7.00	1.134
7.20	1.139
7.40	1.143
7.60	1.147
7.80	1.150
8.00	1.151
8.20	1.151
8.40	1.149
8.60	1.147
8.80	1.142
9.00	1.134
9.20	1.129
9.40	1.131
9.60	1.139
9.80	1.145
10.00	1.151
10.20	1.157

FIGURE 2 - N(Z) FUNCTION FOR N1C8 AT 2893 MW  
 FROM 1000 to 3000 MWD/MTU BURNUP  
 TOP AND BOTTOM 15 PERCENT EXCLUDED  
 AS PER TECH SPEC 4.2.2.2.G




FIGURE 3 - N(Z) FUNCTION FOR N1C8 AT 2893 MW  
 FROM 3000 to 5000 MWD/MTU BURNUP  
 TOP AND BOTTOM 15 PERCENT EXCLUDED  
 AS PER TECH SPEC 4.2.2.2.G




FIGURE 4 - N(Z) FUNCTION FOR NIC8 AT 2893 MW  
 FROM 5000 to 7000 MWD/MTU BURNUP  
 TOP AND BOTTOM 15 PERCENT EXCLUDED  
 AS PER TECH SPEC 4.2.2.2.G




FIGURE 5 - N(Z) FUNCTION FOR N1C8 AT 2893 MW  
 FROM 7000 to 15600 MWD/MTU BURNUP  
 TOP AND BOTTOM 15 PERCENT EXCLUDED  
 AS PER TECH SPEC 4.2.2.2.G




FIGURE 6 - N(Z) FUNCTION FOR NIC8 AT 2893 MW  
 FROM 15600 MWD/MTU BURNUP TO EOL  
 TOP AND BOTTOM 15 PERCENT EXCLUDED  
 AS PER TECH SPEC 4.2.2.2.G






FIGURE 7 - AXIAL FLUX DIFFERENCE LIMITS  
 AS A FUNCTION OF RATED THERMAL POWER  
 FROM 0 MWD/MTU BURNUP TO EOC  
 FOR NORTH ANNA UNIT 1 CYCLE 8

