

U. S. NUCLEAR REGULATORY COMMISSION

REGION III

Reports No. 50-266/89014(DRSS); 50-301/89013(DRSS)

Docket Nos. 50-266; 50-301

Licenses No. DPR-24; DPR-27

Licensee: Wisconsin Electric Power Company
231 West Michigan
Milwaukee, WI 53201

Facility Name: Point Beach Nuclear Plant, Units 1 and 2

Inspection Conducted: April 3 and 4, 1989

Date of Previous Security Inspection: February 6-21, 1989

Type of Inspection: Announced Reactive Physical Security Inspection

Inspector:

Terry J. Madeda
T. J. Madeda
Physical Security Inspector

4/18/89
Date

Approved By:

James R. Creed
James R. Creed, Chief
Safeguards Section

4/19/89
Date

Inspection Summary

Inspection on April 3 and 4, 1989 (Reports No. 50-266/89014(DRSS);
No. 50-301/89013(DRSS))

Areas Inspected: Included a review of two security events reported by the licensee regarding vital area barrier degradations.

Results: Two potential violations were identified and are noted below:

1. Physical Barrier - Vital Area: A penetration of a vital area barrier had not been adequately protected.
2. Physical Barrier - Vital Area: The material utilized to construct a vital area barrier was not of sufficient strength.

8904270233 890420
PDR ADOCK 05000266
Q PNU

Enclosure contains
SAFEGUARDS INFORMATION
Upon separation this
page is Decontrolled