ENCLOSURE

EXAMINATION REPORT 50-424/425/0L-88-03

Facility Licensee: Georgia Power Company P. O. Box 4545 Atlanta, GA 30302

Facility Name: Vogtle Electric Generating Plant

Facility Docket No.: 50-424 and 50-425

Operating tests were administered at Vogtle Electric Generating Plant near Waynesboro, Georgia.

12 APRIL 89 Chief Examiners: Date Signed Jesse A. Ariidsen Payne Date Signed Charles 4.13.89 Approved By: John Munro, Chief Date Signed Operator Licensing Section 1 Division of Reactor Safety

Summary:

.

Examinations were conducted on November 8 - 10 and December 5 - 7, 1988, and January 11 - 12, 1989. Operating tests were administered to 49 candidates; 48 of whom passed. Based on the results described above, 20 of 20 ROs passed and 28 of 29 SROs passed.

8904270370 890417 PDR ADDCK 05000424 PNU

REPORT DETAILS

1. Facility Employees Contacted:

*K. Holmes, Plant Training and Emergency Planning Manager *R. Dorman, Operations Superintendent of Training *D. Scukanec, Training Department Staff

*Attended Exit Meeting

2. Examiners:

*J. Arildsen, RII Examiner M. Ernstes, RII Examiner M. Morgan, RII Examiner C. Casto, RII Examiner A. Salyers, RII Examiner *D. Payne, RII Examiner F. Jaggar, INEL P. Isaksen, INEL

*Chief Examiners

3. Exit Meeting

At the conclusion of the site visit the examiners met with representatives of the plant staff to discuss the results of the examination.

There was a generic weakness noted during the oral examination. The area of below normal performance was in circuit breaker locations. This weakness was highlighted by very limited procedural guidance in this area. The facility had identified this item and procedural changes were in progress.

The cooperation given to the examiners and the effort to ensure an atmosphere in the control room conducive to oral examinations was also noted and appreciated.

The licensee did not identify as proprietary any of the material provided to our reviewed by the examiners.