

CATAWBA NUCLEAR STATION
MONTHLY OPERATING STATUS REPORT

April 1989

1. Personnel Exposure

For the month of April, no individual(s) exceeded 10 percent of their allowable annual radiation dose limit.

2. The total station liquid release for April has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for April has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

8906260291 890615
PDR ADOCK 05000413
R PDR