

UNITED STATES NUCLEAR REGULATORY COMMISSIONDETROIT EDISON COMPANYDOCKET NO. 50-341NOTICE OF WITHDRAWAL OF APPLICATION FOR
AMENDMENT TO FACILITY OPERATING LICENSE

The United States Nuclear Regulatory Commission (the Commission) has granted the request of the Detroit Edison Company and Wolverine Power Supply Cooperative, Inc. (the licensees) to withdraw its February 10, 1988 application for proposed amendment to Facility Operating License No. NPF-43 for the Fermi-2 Nuclear Power Plant, Unit No. 2, located in Monroe County, Michigan.

The proposed amendment would have revised the Technical Specifications to remove the requirement to perform 10 CFR Part 50, Appendix J, Type C leakage testing on the Residual Heat Removal Shutdown Cooling inboard isolation valves.

The Commission has previously issued a Notice of Consideration of Issuance of Amendment published in the FEDERAL REGISTER on May 16, 1988 (53 FR 17281). However, by letter dated April 5, 1989, the licensee withdrew the proposed change.


For further details with respect to this action, see the application for amendment dated February 10, 1988, and the licensee's letter dated April 5, 1989, which withdrew the application for license amendment. The above documents

8904270396 890420
PDR ADOCK 05000341
P PIC

are available for public inspection at the Commission's Public Document Room, 2120 L. Street, N.W., Washington, D.C., and the Monroe County Library System, 3700 S. Custer Road, Monroe, Michigan 48226.

Dated at Rockville, Maryland this day of .

FOR THE NUCLEAR REGULATORY COMMISSION



Lynn Kelly, Project Manager
Project Directorate III-1
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation