

Duke Power Company  
P.O. Box 33198  
Charlotte, N.C. 28242

Hal B. Tucker  
Vice President  
Nuclear Production  
(704)373-4531



**DUKE POWER**

April 26, 1989

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Subject: Duke Power Company  
McGuire Nuclear Station  
Docket No. 50-369  
Unit 1 Restart

This letter documents discussions I and several of my staff members held with D. B. Matthews and other NRC staff members during an April 25, 1989 telephone conference call. The subject of our call was the actions required prior to the restart of McGuire Unit 1 from the March 7, 1989 steam generator B tube rupture event. These actions were also discussed with the NRC on April 13, 1989 at a meeting held in White Flint and confirmed in an NRC letter dated April 19, 1989.

Based upon agreements reached during our April 25 conference call the following response to each of the actions contained the April 19 letter is provided.

(1) Further meetings and reporting regarding cause of the tube failure and integration of these results into effective corrective actions.

Response: We will meet with the NRC staff, again in White Flint, on May 5, 1989 to present and discuss the Unit 1 steam generator B tube report. The restart of Unit 1 is contingent upon receiving your concurrence at this meeting. We would like to do everything possible to facilitate the NRC's ability to support our restart effort. Prior to our meeting, we will talk with E. L. Murphy of the NRC staff daily to keep him informed of the steam generator tube report status. We will attempt to provide Emmett a draft of the report by May 3.

(2) Further meetings regarding tube plugs.

Response: The report mentioned in Item 1 will contain a section addressing tube plugs in the McGuire steam generators. We will also discuss the plugs during our presentations at the May 5 meeting.

(3) Completion of procedural changes for entry conditions into Emergency Operating Procedures as proposed during the meeting.

Response: We have addressed the procedure related actions from our April 13 meeting as well as the procedure related findings of the April 10, 1989 AIT report. These are hereby attached to this letter for NRC review.

8905010204 890426  
PDR ADDCK 05000369  
FDC

ZE26  
11


U. S. Nuclear Regulatory Commission  
Page Two  
April 26, 1989

(4) Completion of certain items from the NRC's Augmented Inspection Team Report of April 10, 1989 to be determined from your discussions with the Team Leader.

Response: We will coordinate the resolution of these items with the NRC Resident Inspector at McGuire.

We will rely upon the daily telephone calls mentioned in Item 1 to identify any considerations for changing the above schedule. Please let me know if there is any additional information we can provide prior to our May 5 meeting that will assist in expediting the NRC's review of the McGuire Unit 1 restart.

Very truly yours,



Hal B. Tucker

JSW/353/td

cc: Mr. S. D. Ebnetter  
U. S. Nuclear Regulatory Commission  
101 Marietta St., NW Suite 2900  
Atlanta, GA 30323

Mr. D. Hood, Project Manager  
Office of Nuclear Reactor Reg.  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

Mr. P. K. VanDoorn  
NRC Resident Inspector  
McGuire Nuclear Station

## McGuire Operations Response To Procedure Concerns and Findings from the AIT Audit

The following are McGuire Operations responses to the procedural concerns and findings addressed in the AIT Report. The concerns and findings will be listed first with the AIT Report page number and then McGuire's response. All responses will address the procedures as Unit 1 procedures but all statements are true for both Unit 1 and Unit 2 procedures.

### 1. Concern from page 13 and 14

Upon receipt of an alarm on the B steamline radiation monitor, 1-EMF-25, the reactor operator at the controls verified the validity of the alarm before checking other parameters. He then checked the pressurizer level, reactor coolant makeup flow, steam generator levels and main feedwater regulator valve positions. In addition to all these including a condition that the shift referred to as the "classical S/G tube leak symptoms", the "condenser air ejector exhaust high gas radiation" annunciator alarmed. The unit supervisor concluded that the unit was experiencing a S/G tube leak and directed that AP/10 be implemented. Two of the four symptoms listed in that procedure were received: steam line high radiation and air ejector high gaseous radiation. However, the symptoms identified in AP/10 do not include increasing S/G level, decreasing feedwater flow or feedwater valve position, although the shift crew stressed during interviews that these indications were the deciding parameters. The definitive SGTR symptoms which the operator relied on to determine which AP to use, feedwater flow and steam generator level, are included in step 6 of AP/10, well into the procedural instruction. Although this event fell within the intended boundaries of the Westinghouse Owners' Group guidelines for procedures, it was handled by independent operator diagnosis and resultant direct usage of a nonemergency operating procedure.

**Response:**

AP/1/A/5500/10 (NC System Leakage Within the Capacity of Both NV Pumps) has been rewritten and approved and now includes decreasing feedwater flow and feedwater regulation valve position as symptoms for Case I "Steam Generator Tube Leakage". See Attachment 1, AP/1/A/5500/10, page 5 of 41. In addition, it is questionable if this event fell within the intended boundaries of the Westinghouse Owners Groups (WOG) ERG's. The entry conditions for the Safety Injection portion of ERG E-0 are the plant specific setpoint or requirement for safety injection have been met, the SI annunciator light lit or SI pumps running. See Attachment 2, pages 2 and 3 of 6. During this transient, none of MNS SI setpoints were reached, the plant specific requirement of pressurizer level less than 5% was not reached and only two out of six SI pumps were running, the normal charging pump and the standby charging pump. In addition, the WOG background document for E-0 "Reactor Trip or Safety Injection" has a paragraph explaining that the operators are expected to take manual action for anomalous conditions during power operations. These actions would include taking manual control of the automatic control systems, turning on additional charging pumps, reducing power level, etc. If these types of actions do not alleviate the trend toward a reactor trip or safety injection, the operator is permitted to trip the reactor and, if necessary, actuate safety injection. See Attachment 2, page 4 of 6.

**2. Concern from page 14**

One of the immediate operator actions after identification of the incident and entry into AP/10 was to reduce electrical load by reducing main generator power. AP/10 does not give direction to accomplish this task. The operators stated that they knew from training that this action should be performed. They did not use any procedure for this action and, therefore, had to ask the unit supervisor to determine the rate at which he wanted the load reduced. The needed rate of load reduction was analyzed and determined by the unit supervisor. This analysis placed additional burden on this individual during response to the event.

**Response:**

AP/1/A/5500/10 did not require a generator load decrease nor did it give a rate for the load decrease. The operators have been trained to perform this task. In the new AP/10, a step to initiate a load decrease to remove the unit off line has been added. This step is prefaced by a note explaining the load reduction rate should be determined based on the leak size and on the ability to remove the unit in a controlled manner. See Attachment 1, pages 6 and 21 of 41.

**3. Concern from page 14 and 15**

The operators considered initiating SI. They concluded however, it would not be advantageous if SI were initiated. Additional CRO manpower would be required to monitor the successful initiation of SI. In addition, the operators were uneasy regarding the dependability of the RN supply to the unaffected unit due to logic wiring problems experienced in the past. They also considered SI, when not mandatory, to be an unnecessary challenge to safety related equipment (i.e., containment isolation and diesel generator start). This preference not to manually initiate SI is reflected both in their AP and in their training.

**Response:**

The operators were trying to state Duke's philosophy of not challenging safety systems if they are not needed. In stating this philosophy, the operators were trying to explain that when safety injection is initiated, it is an event unto itself in which hundreds of components are required to start, stop, realign, etc. All of these components must be verified to be functioning properly prior to proceeding with the procedure to mitigate the initial event. The operators gave the AIT Inspectors an example of an event on Unit 1, which was an intermittent ground in the A train solid state protection system cabinet. This intermittent ground gave a partial A train safety injection where only a portion of the A

train components realigned and no B train components realigned. This event caused significant operational problems for both the operating unit and the affected unit.

The operators are not uneasy about initiating safety injection if it is required by plant status or procedures. McGuire's procedures and training do not and have not discouraged the operators from initiating safety injection when required. The difference at McGuire was the threshold or setpoint at which manual safety injection should be initiated. The actuation of automatic safety injection is dictated by the accident analysis and the manual initiation setpoint was more conservative than the automatic setpoint.

4. Concern from page 15

In the "immediate actions" section of AP/10, "response not obtained" for the step that requires the operator to manually initiate SI, there is no guidance to the operator on where to enter the procedure for SI.

**Response:**

The step in AP/10 which requires the operator to manually initiate safety injection does not identify which step to enter EP/1/A/5000/01 "Safety Injection" because the procedure is entered at the beginning. This concept is a given concept in that if an operator either trips the reactor, initiates safety injection or receives an automatic signal, the operator proceeds to the beginning of either the reactor trip procedure or safety injection procedure.

5. Concern from page 15

Step 3 of AP-10 directed determination of whether S/G blowdown isolation was required based solely on whether 1-EMF-34 (blowdown sample high rad alarm) was lit. Since it was not lit the operator did not verify S/G auto isolation nor manually isolate blowdown from any of the generators.

**Response:**

AP/10 now has a step to isolate blowdown on the ruptured steam generator and does not rely solely on the EMF to isolate blowdown. See Attachment 1 page 7 of 41.

**6. Concern from page 15**

AP/10 step 3 uses 1-EMF-34 as the sole determinant of whether S/G blowdown isolation is required. Then, in step 7b, after identifying the affected generator, the procedure does not isolate blowdown on the affected generator as part of the generator's isolation. This is similar to McGuire's EP/04 where, after identifying the ruptured generator in step 1, the subsequent steps isolate main steam to the ruptured generator but does not isolate blowdown. This is a significant safety-related deviation from the Westinghouse Owners' Group guideline E-3, SGTR, which requires, after identifying the ruptured generator, that its blowdown be isolated.

**Response:**

AP/10 now has a step to isolate blowdown on the ruptured steam generator and does not rely solely on the EMF to isolate blowdown. See Attachment 1 page 7 of 41. EP/1/A/5000/04 "Steam Generator Tube Rupture" does not have a specific step to isolate blowdown on the ruptured steam generator because it is done automatically by safety injection and checked by EP/1/A/5000/01, "Safety Injection". The check of the ESF Monitor Light Panel in EP/01 verifies that Containment Phase A Isolation Train A/B have been aligned properly and if the Phase A components have not been aligned the operator manually aligns those misaligned components. The steam generator blowdown valves do get isolated on a Phase A Containment Isolation signal. Therefore this action is done automatically and verified by the operator. See Attachment 3 page 3 of 3. Hence, this is not a safety significant deviation from the WOG guidelines.

7. Concern from page 15

Early in the implementation of AP-10 the shift manager (STA) entered the control room and began monitoring the critical safety functions of SPDS. This was an appropriate action but not specified by the procedure. Also, although the licensee has indicated that they have a fully operational SPDS, there were two parameters that were inaccurately displayed by SPDS during the event because of faulty computer logic. NC integrity was being displayed as a "red path" (extreme challenge to this safety function; immediate operator action is required) and, core cooling was being displayed as a "yellow path"; indicating that this critical safety function was in an off-normal state and might require operator attention. The AIT was informed that there were several software problems with the SPDS.

**Response:**

McGuire's SPDS is operable but the McGuire Operator Aid Computer is not safety related. Operations has an emergency procedure EP/1/A/5000/10, "Critical Safety Function Status Trees" which is the controlling procedure for monitoring Critical Safety Functions which uses SPDS as a convenient aid if the OAC is available. See Attachment 4. In the case where a software problem with the computerized SPDS gives an invalid alarm, the operators would check to see if the alarm is valid utilizing the status trees. If the alarm was invalid as it was in the AIT examples, the operators would ignore it and notify reactor group of the problem as was done in this case.

8. Concern from page 15 and 16

At step 7 of AP/10 the operator was directed to "shut down and cooldown the unit using OP/1/A/6100/02, Controlling Procedure for Unit Shutdown", in conjunction with the remaining steps of AP/10. This OP is about 50 pages long, yet no direction is given to the operator in AP/10 regarding which page or section of the OP to enter. Thus, the operator entered the procedure where he felt it was appropriate.

**Response:**

The last step in AP/10 now has the operator utilize one of the three emergency subprocedures for cooling down the ruptured steam generator EP/1/A/5000/4.1 "SGTR Cooldown Using Steam Dump, EP/1/A/5000/4.2 "SGTR Cooldown Using Backfill" or EP/1/A/5000/4.3 "SGTR Cooldown Using Blowdown". In conjunction, the operator is referred to OP/1/A/6100/02 "Controlling Procedure for Unit Shutdown" Enclosure 4.2 to perform applicable steps. EP/4.1, EP/4.2 and EP/4.3 are entered at the first step so no entry step reference is needed. See Attachment 1, page 14 of 41. There is no consistent way of addressing which step in OP/02 to enter due to the nature of every transient being different and having the plant end up in a slightly different status as far as what components are running, etc. To put this situation in perspective, at this time in the procedure, primary pressure and the ruptured steam generator pressure are equalized and the primary system is cooled down below the saturation temperature and pressure for steam line PORV's or safety reliefs to lift. The immediate transient has been handled and cooldown options are being decided. A licensed operator is capable of deciding where OP/02 should be entered to match where the plant is currently. In addition, the EP subprocedure is the controlling procedure with the shutdown OP being used for reference.

**9. Concern from page 16**

After the unit was off line, AP/10 directed the operator to isolate the affected steam generator. AP/10, at step 7b, directs the operator to "Close (main steam) isolation and bypass valves". By training and convention the operator knew this meant to open the by-pass, close the MSIV, then slowly close the by-pass to prevent a pressure transient.

**Response:**

The operator opened the MSIV bypass valves before closing the MSIV to avoid a pressure transient to prevent a pressure spike which could have

lifted the steamline PORV or Safety Reliefs. Even though this opened another steamline valve the MSIV's and MSIV bypass valves are fail close valves. This action adds approximately 20 seconds to isolating the steamline which is well worth the effort to avoid lifting a steamline PORV or Safety which would cause a direct release to the public. Also, the ruptured steam generator steamline was isolated within 11 minutes of the leak which is well within our safety analysis assumed time of 30 minutes.

**10. Concern from page 16**

Near the end of AP/10, the operator was directed to "dump steam to condenser by slowly opening steam isolate bypass valve on ruptured generator". Due to the brevity and lack of specificity of this instruction the operator opted to reference EP/4.1 where there was more detailed guidance. One of the difficulties of this procedural transition (or parallel usage) is that the two types of documents may not have a consistent set of definitions. For example, AP/10 step 7d refers to "...faulted S/G pressure..." when referring to the generator with the tube leak and at point 7f of the same page refers to the "ruptured" generator as the one with the tube leak. The EPs carefully use these terms to indicate a generator with a secondary leak as "faulted" whereas "ruptured" is used to refer to a generator with a primary to secondary leak through one or more tubes. Also, the concurrent use of procedures increases the physical and mental burden of the US who performed as the "Procedure Reader".

**Response:**

The last step in AP/10 now has the operator utilize one of the three steam generator tube rupture cooldown subprocedures. See Attachment 1, page 14 of 41. These procedures offer more detailed guidance on cooling the ruptured steam generator. As far as the concern over the lack of consistent definitions, the one example addressed in the report was an error in our procedure. McGuire Operations strives for consistency not only among our emergency procedures but all of our procedures.

11. Concern from page 17

Step, 7.f.1 of AP/10, listed an alternative to dumping steam from the ruptured generator to the condenser, that alternative would be blowing down through the BB recycle system. Due to the operators lack of confidence in the BB recycle system's Hx integrity they chose to dump steam to the condenser.

**Response:**

This concern was initiated by the Technical Support Center not the operators. The TSC had confidence in the BB recycle Hx integrity for short term use but not long term use. To put this in perspective, long term use would be identified as use for a period of greater than a week. The decision to not use the BB recycle system was based on the fact that the TSC determined blowing down the ruptured steam generator through normal blowdown was a better option. In addition, the ruptured steam generator was not steamed to the condenser after it was isolated. This statement in the AIT Report is in error.

12. Concern from page 16

Step 7.f.1, unlike the step in EP/4.1, makes no reference to performing an offsite dose calculation prior to dumping steam from a ruptured generator to the condenser. EP/4.1 contains a caution indicating that such a calculation should be done. The shift supervisor indicated at the time that he did not intend to have the dose calculation performed prior to steaming because EP/4.1 stated "should" and therefore was not a requirement.

**Response:**

The last step in AP/10 now has the operator utilize one of the three steam generator tube rupture cooldown subprocedures. If the operator chooses EP/4.1, that subprocedure has always contained the caution that

an offsite dose evaluation (not a calculation) should be performed prior to using the procedure. This caution is consistent with the WOG guidelines which state that the evaluation should be done. See Attachment 2, pages 5 and 6 of 6.

13. Concern from page 16 and 17

Cooldown per OP/02 was delayed initially since primary boron sample results were not available until 2 hrs and 44 minutes after the trip (2:30 a.m.). The Boron sample concentration was not high enough to allow cooldown below 200°F so cooldown was not resumed. Boron concentration was high enough to initiate cooldown to an intermediate temperature but the operators were unaware of this option until 3 hrs 34 minutes after the trip. Cooldown was started 5 minutes after this option was realized.

**Response:**

The shutdown OP and the reactivity balance OP have been changed to clarify the operator's ability to cooldown to intermediate temperatures as long as shutdown margin is maintained for those intermediate temperatures. See Attachment 5.

14. Concern from page 17

After the reactor trip, primary system pressure was maintained above 1000 psig while S/G B pressure decreased to approximately 800 psig. This continued for 4 3/4 hours. This was because step 2.33 of OP/02 and the cooldown curves require primary system temperature to be below 425° prior to decreasing pressure below 1000 psig (LOCA FSAR requirement). The operators did not become aware of a note immediately before step 2.33 allowing pressure to be reduced to 750 psi with shift supervisor approval under extenuating circumstances.

**Response:**

With the clarification that the cooldown can be initiated to intermediate temperatures, the plant should not get in a position that the cooldown curve requirement at 425°F and 1000 psig would be a problem. In addition, this incident will be covered in operator requalification to further make the operators aware of the note allowing the shift supervisor to reduce primary pressure to 750 psig under extenuating circumstances.

**15. Concern from page 17**

Prior to commencing cooldown using S/G backfill (10:15 a.m.), the SRI asked the reactor engineer if shutdown margin projections had been made due to the impending dilution. The engineer indicated that operations personnel had indicated they did not need one but he thought it was a good idea. He then provided the information.

**Response:**

Operations personnel in the TSC were well aware of the need for increased boron concentration needs for the impending dilution due to S/G backfill. This was addressed in EP/4.2. Operations personnel apparently failed to communicate this fact to the Reactor Engineer. The Operations personnel were taking the shutdown boron concentration given by the Reactor Engineer and adding the required boron concentration addition.

**16. Concern from page 17**

The procedure finally selected by the TSC to depressurize the NC System and S/G B was EP/4.2, "SGTR Cooldown Using Backfill". Step 9 of EP/4.2 (checking for void in upper head) contains a sub step (b) that requires the operator to continue monitoring for upper head void while going on to the next step in the procedure. This does not assure that attention is given to monitoring for voids while going on to another major action (i.e., NC system depressurization).

**Response:**

The step in EP/4.2 will be clarified to continue monitoring for upper head voids during the remainder of the procedure. This was understood before but not clearly stated in the procedure.

**17. Concern from page 17 and 18**

Based on a review of the sequence of events, operator and plant personnel interviews, and a control room walkthrough with members of the operating crew, the AIT concluded that considering the training and procedure impediments the operating crew performed adequately in mitigating this particular event. The crew followed steps prescribed in the station procedures, however, the procedures, were found to have significant weaknesses which could result in unnecessary releases of radioactivity to the environment should future SGTR events occur. The mitigative strategy which McGuire used for coping with this event deviated substantially from the Westinghouse Owners' Group Emergency Response Guidelines.

**Response:**

The event was handled extremely well by the operating crew. Decisions were made in the TSC over which cooldown option to use for the ruptured steam generator. Procedures needed and have been enhanced but most of the enhancement is in procedure structure. The comment that the mitigative strategy deviated substantially from the WOG guidelines has been addressed by Concern 1.

**18. Finding from page 28**

The operating crew performed adequately in mitigating this event despite procedural weaknesses which caused the operator to select portions of additional procedures that contained more detailed guidance.

**Response:**

As stated in Concern 17, the operating crew performed outstandingly, not adequately. In addition, Operations personnel realized that enhancements need to be made to some of Operations' procedures and have enhanced or are enhancing procedures from the lessons which were learned from this event.

**19. Finding from page 28**

Operators failed to promptly identify the magnitude of the reactor coolant leak, to cooldown and to equalize pressure.

**Response:**

Operations did not identify the magnitude of the leak immediately. Identifying the exact magnitude of a leak while pressurizer level is decreasing due to the leak and primary system cooldown due to a load decrease, charging is being increased, letdown is being decreased and the Volume Control Tank level is changing is difficult. The operators concern was, "Is the leak greater than 50 gpm (Alert Classification) and if greater than 50 gpm can pressurizer level be maintained?" Quantifying whether the leak is a 150 gpm leak or 450 gpm leak is not utmost in the operator's mind nor is it of utmost importance. The operator must first control the plant and then worry about quantifying the exact leakage rate.

The operator did cooldown and depressurize the primary system to the ruptured steam generator pressure promptly. The resultant cooldown to cold shutdown was done in a controlled deliberate manner at the direction of the TSC to minimize possible errors which could result in unnecessarily jeopardizing the plant or the public. In a steam generator tube rupture event, the critical action is to equalize ruptured steam generator pressure with primary pressure. The resultant cooldown can and should be done in a calm, slow, deliberate manner.

20. Finding from page 28

Procedures and training discouraged operators from safety injecting. Although SI was not needed in this event, procedures and training should be reviewed to assure operators will SI when appropriate in the future.

**Response:**

Procedure and training do not and have not discouraged the operator from initiating safety injection when safety injection is required. Training has been done on our procedures and has supported our procedures. AP/10 is and was one of the most widely and often used procedures during simulator requal training. The difference at McGuire was at which point the operator was required to initiate manual safety injection. McGuire chose to have the operator maximize charging by reducing letdown flow, starting a second charging pump and opening the high head injection line isolation valves. If pressurizer level still decreased to less than 5% level the operator would manually activate safety injection. The revised AP/10 has been written to allow the operator to start the second charging pump, reduce or isolate letdown flow but will not allow manually opening the high head injection line isolation valves. See Attachment 1 pages 5 and 6 of 41.

21. Finding from page 28

Operators lacked confidence that certain systems would function following an SI, also considered unnecessary challenge to safety related equipment.

**Response:**

Refer to Concern 3.

22. Finding from page 28

The McGuire strategy for coping with this event deviates from the WOG guidelines in several significant aspects. Overall it addresses to an accident which is within the scope of the WOG EOPs. Guidelines for emergency operating procedures as an abnormal event rather than an emergency.

**Response:**

Refer to Concern 1.

23. Finding from page 28

Some important operator actions required to mitigate the event are not specified in AP/10. Among these are reduction in load, monitoring of critical safety functions, isolation of the affected generator, depressurization by dumping steam to the condenser and offsite dose calculation prior to dumping steam to the condenser from the affected generator.

**Response:**

Refer to Concerns 2, 5, 6, 8 and 12. Also SPDS is monitored on transfers out of EP/1 "Safety Injection". Since we have changed AP/10 so the high head injection line isolation valves can not be manually opened, for a leak greater than the capacity of the normal charging line safety injection will be manually initiated and the operator is directed to EP/01.

24. Finding from page 29

The transitions from AP/10 to other procedures are lacking in detail or not identified at all. Among these are:

- ♦ AP/01, "Rx trip" procedure
- ♦ OP/02, "Controlling Procedure for Unit Shutdown"
- ♦ EP/4.1, "SGTR Cooldown Using Steam Dump"
- ♦ EP/4.2, "SGTR Cooldown Using Backfill"
- ♦ EP/4.3, "SGTR Cooldown Using Blowdown"

**Response:**

Refer to Concerns 4 and 8.

**25. Finding from page 29**

AP/10 and EP/4.3 contain steps directing the operator to use the Blowdown Recycle System which could potentially result in establishing an unmonitored release pathway.

**Response:**

AP/10 now directs the operator to utilize one of the three steam generator tube rupture subprocedures to cooldown the rupture steam generator. OP/1/A/6250/08 "Steam Generator Blowdown" will be changed to have health physics personnel take grab samples if the BB Recycle Hx is in use. EP/4.3 places the BB Recycle Hx in service per OP/08. The BB Recycle Hx's on both Unit 1 and Unit 2 were taken out of service and red tagged to the Operations Superintendent on 4/21/89. These Hx's will be placed back in service after the procedures are changed. Operations and Radiation Protection procedures will be changed by May 5, 1989.

**26. Finding from page 29**

AP/10 does not required an assessment of offsite dose prior to dumping steam from the affected generator to the condenser.

**Response:**

See Concern 12.

**27. Concern from page 29**

System crossties caused increased radiological problems.

**Response:**

An additional Enclosure, Enclosure 6 "Minimizing Secondary Side Contamination" has been added to AP/10 to minimize (as much as possible) secondary side contamination due to system crossties. See Attachment 1, pages 39, 40 and 41 of 41.

**28. Finding from page 29**

Operators were not knowledgeable of two important provisions for cooling down and depressurizing in unusual situations. Specifically, these were (1) boron concentration required for intermediate temperature cooldown and, (2) procedural option to depressurize to 750 psi before cooling down.

**Response:**

See Concerns 13 and 14.

**29. Finding from page 29**

AP/04 does not isolate blowdown on the ruptured generator. This is a significant safety-related deviation.

**Response:**

See Concern 6.

**30. Finding from page 29**

The overall mitigative strategy used to deal with this >500 gpm tube rupture deviates substantially from the WOG Emergency Response Guidelines.

**Response:**

See Concern 1.

In addition to the responses on the AIT Report, the commitment on procedural enhancements from the April 13, 1989 Duke Power presentation to the NRC staff have been included. Attachment 6 has those commitments. The procedure changes which were made previously are in Attachment 5. The procedure enhancement to AP/10 which were scheduled to be completed by May 1, 1989 are done and are shown on Attachment 1. The procedure enhancements which were scheduled for a June 30, 1989 completion are working now.

**List of Attachments**

**Attachment 1** - Revised AP/1/A/5000/10 "NC System Leakage Within The Capacity of Both MV Pumps"

**Attachment 2** - Selected Pages From The Westinghouse Owners' Group Emergency Response"

Attachment 3 - Selected Pages from EP/1/A/5000/01 "Safety Injection

Attachment 4 - EP/1/A/500/10 "Critical Safety Function Status Trees"

Attachment 5 - Selected Pages From OP/1/A/6100/02 "Controlling Procedure for Unit Shutdown" and OP/0/A/6100/06 "Reactivity Balance Calculation"

Attachment 6 - Procedural Commitments Made in the April 13, 1989 Washington, D.C. Duke Power Presentation to the NRC Staff

Attachment 7 - Superceded Copy of AP/1/A/5000/10 and Selected Pages From the Superceded OP/1/A/6100/02

# Attachment 1

Revised AP/1/A/5000/10 "NC System Leakage Within The Capacity  
of Both NV Pumps.

INFORMATION ONLY

Duke Power Company  
PROCEDURE PROCESS RECORD(1) ID No. AP/1/A/5500/10  
Change(s) 0 to 0  
0 Incorporated

## PREPARATION

(2) Station McGuire Nuclear Station(3) Procedure Title NC System Leakage Within The Capacity of Both NV Pumps(4) Prepared By Len Firebaugh Date 3/1/89(5) Reviewed By Michael Weiner Date 4/26/89Cross-Disciplinary Review By \_\_\_\_\_ N/R MN

(6) Temporary Approval (if necessary)

By \_\_\_\_\_ (SRO) Date \_\_\_\_\_

By \_\_\_\_\_ Date \_\_\_\_\_

(7) Approved By Bruce T. Davis Date 4/26/89

(8) Miscellaneous

Reviewed/Approved By ETQS mw 4/26/89 Date \_\_\_\_\_

Reviewed/Approved By \_\_\_\_\_ Date \_\_\_\_\_

(9) Comments (For procedure reissue indicate whether additional changes, other than previously approved changes, are included. Attach additional pages, if necessary.)

Additional Changes Included. ☒ Yes☐ No

(10) Compared with Control Copy \_\_\_\_\_ Date \_\_\_\_\_

(11) Requires change to FSAR not identified in 10CFR50.59 evaluation? ☐ Yes

If "yes", attach detailed explanation.

☒ No

## Completion

(12) Date(s) Performed \_\_\_\_\_

(13) Procedure Completion Verification

☐ Yes ☐ N/A Check lists and/or blanks properly initialed, signed, dated or filled in N/A or N/R, as appropriate?☐ Yes ☐ N/A Listed enclosures attached?☐ Yes ☐ N/A Data sheets attached, completed, dated and signed?☐ Yes ☐ N/A Charts, graphs, etc. attached and properly dated, identified and marked?☐ Yes ☐ N/A Procedure requirements met?

Verified By \_\_\_\_\_ Date \_\_\_\_\_

(14) Procedure Completion Approved \_\_\_\_\_ Date \_\_\_\_\_

(15) Remarks (attach additional pages, if necessary)

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN THE CAPACITY OF BOTH NV PUMPS	PAGE NO. i
----------------	---	---------------

## TABLE OF CONTENTS

	<u>Page</u>
A. <u>Purpose</u>	1
Case I Steam Generator Tube Leakage	2
Case II NC System Leakage	12

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN THE CAPACITY OF BOTH NV PUMPS	PAGE NO. 1 OF 23
----------------	---	---------------------

A. Purpose

This procedure covers the required operator actions for NC leakage greater than Tech Specs but where the Charging Pumps are capable of maintaining Pzr water level and the Pzr heaters are capable of maintaining system pressure under the following conditions:

- Case I     Steam Generator Tube Leakage
- Case II    NC System Leakage

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS Case I Steam Generator Tube Leakage	PAGE NO. 2 OF 23
----------------	--	---------------------

ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
B. <u>Symptoms</u>	
<ul style="list-style-type: none"> <li>◆ "1EMF 33, Cond Air Eject Exh Hi Rad" alarm</li> <li>◆ "1EMF 34, S/G Sample Hi Rad" alarm</li> <li>◆ "1EMF 24, 25, 26, 27 S/G A, B, C, D Steamline Hi Rad" alarm</li> <li>◆ Increase in frequency of auto makeup to VCT</li> <li>◆ Feedwater flow and CF Reg valve position indication decreasing in any S/G.</li> </ul>	
C. <u>Immediate Actions</u>	
1. Check Pzr level - AT OR INCREASING TO PROGRAMMED LEVEL.	<p>IF level decreasing, <u>THEN</u> perform the following to maintain level:</p> <ul style="list-style-type: none"> <li>a. Ensure 1NV-238 (Charging Line Flow Control) opening in "Auto".</li> <li>b. Start additional NV Pump.</li> <li>c. Reduce letdown to 45 GPM orifice or isolate letdown if necessary.</li> </ul> <p>IF level decreases below 5%, <u>THEN</u> manually trip Reactor and initiate SI. <u>GO TO</u> EP/1/A/5000/01, SAFETY INJECTION.</p>
2. Check Pzr pressure - AT OR INCREASING TO 2235 PSIG.	<p>IF less than 2210 PSIG, <u>THEN</u> ensure backup heaters on.</p> <p>IF pressure approaches 1945 PSIG, <u>THEN</u> trip Reactor.</p>
D. <u>Subsequent Actions</u>	
<p><u>CAUTION</u> If Pzr level cannot be maintained, (less than 5% and decreasing) then SI should be manually initiated.</p>	
1. Announce occurrence on paging system.	

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS Case I Steam Generator Tube Leakage	PAGE NO. 3 OF 23
----------------	--	---------------------

ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
2. Check Pzr level - STABLE OR INCREASING.	IF level decreasing with maximum charging flow, <u>THEN</u> manually trip Reactor and initiate SI. <u>GO TO</u> EP/1/A/5000/01, SAFETY INJECTION.
<p><u>NOTE</u> Load reduction rate should be determined based on leak rate flow and on ability to take the unit off line in a controlled manner.</p>	
3. Begin unit load reduction to remove unit off line.	
4. <u>WHEN</u> "VCT Level" less than 16%, <u>THEN</u> open 1NV-221A or 222B (NV Pumps Suct From FWST).	
5. Begin emergency boration for SDM considerations during cooldown in step 11.	
6. <u>REFER TO</u> RP/0/A/5700/00, CLASSIFICATION OF EMERGENCY.	
7. Identify ruptured S/G: <ul style="list-style-type: none"> <li>♦ Check S/G levels - ANY INCREASING IN AN UNCONTROLLED MANNER</li> <li style="text-align: center;">OR</li> <li>♦ Check 1EMF-24, 25, 26, 27, S/G A(B, C, D) Steamline Hi Rad monitors - ANY ABOVE NORMAL</li> <li style="text-align: center;">OR</li> <li>♦ Check CF Flow - LOWER IN ANY S/G COMPARED TO ALL</li> <li style="text-align: center;">OR</li> <li>♦ <u>PER</u> OP/1/A/6250/08, STEAM GENERATOR BLOWDOWN, ENCLOSURE 4.3.</li> </ul>	Do not proceed until ruptured S/G is identified.

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS Case I Steam Generator Tube Leakage	PAGE NO. 4 OF 23
----------------	--	---------------------

ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
<p>8. After unit is off line, isolate flow from ruptured S/G:</p> <p>a. Close MSIV and MSIV Bypass valves on ruptured S/G.</p> <p>b. Close steamline drain on ruptured S/G:</p> <ul style="list-style-type: none"> <li>◆ 1SM-83, 84, 95, 101(A(B,C,D) SM Line Drain).</li> </ul> <p>c. Isolate blowdown on ruptured S/G.</p> <p>d. Dispatch operator to locally close valves on ruptured S/G:</p> <ul style="list-style-type: none"> <li>◆ 1SA-1 (SM 1C To TD CA Pump Manual Isol) and 1SA-77 (SM 1C To TD CA Pump Loop Seal Isol)</li> <li>◆ 1SA-2 (SM 1B To TD CA Pump Manual Isol) and 1SA-78 (SM 1B To TD CA Pump Loop Seal Isol).</li> </ul>	<p>a. Close MSIV and MSIV Bypass valves on nonruptured S/G. Close the following to isolate the SM header:</p> <ul style="list-style-type: none"> <li>◆ Condenser and Atmospheric Dump valves</li> <li>◆ 1SM-14 (SM To CSAE)</li> <li>◆ 1SM-15 (SM To 2ND STG RHTRS)</li> <li>◆ 1AS-12 (SM To AS)</li> <li>◆ 1TL-3 (SM To Stm Seal Isol).</li> </ul> <p>Dispatch operator to locally close:</p> <ul style="list-style-type: none"> <li>◆ 1SP-1 (SM To CF Pump 1A Isol)</li> <li>◆ 1SP-2 (SM To CF Pump 1B Isol).</li> </ul>

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case I  
Steam Generator Tube LeakagePAGE NO.  
5 OF 23

## ACTION/EXPECTED RESPONSE

## RESPONSE NOT OBTAINED

- e. Maintain ruptured S/G pressure  
- LESS THAN 1125 PSIG:

- 1) Verify SM PORVs in "Auto" and closed.
- 2) Open MSIV Bypass valve to maintain pressure.

- 1) IF SM PORV fails to close at 1092 PSIG, THEN close its SM PORV Isol valve.
- 2) IF condenser not available, THEN verify SM PORV cycles to prevent opening safety valves.

9. Check ruptured S/G level:

- a. "S/G NR Lvl" - GREATER THAN 5%
- b. Stop feed flow to ruptured S/G.

- a. Maintain feed flow to ruptured S/G until level greater than 5%.

10. Check intact S/G levels:

- a. "S/G NR Lvl" - GREATER THAN 5%.
- b. Control feed flow to maintain levels - AT NO LOAD.

- a. Maintain total feed flow greater than 450 GPM until level greater than 5% in at least one intact S/G.

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case I  
Steam Generator Tube Leakage

PAGE NO.  
6 OF 23

## ACTION/EXPECTED RESPONSE

## RESPONSE NOT OBTAINED

**CAUTION** ♦ Isolation of the ruptured S/G steam lines must be complete before continuing to step 11.

- ♦ Administrative cooldown rate of 50°F/hr may be exceeded during cooldown in step 11.

**NOTE** ♦ Blocking the steamline low pressure SI signal will enable the steamline pressure rate, main steam isolation signal.

- ♦ Cooldown and depressurization in steps 11 and 12 should be performed concurrently to minimize break flow while maintaining subcooling.

11. Initiate NC System cooldown:

- a. Maintain cooldown to ensure NC System stays 20°F subcooled until depressurization in step 12 is completed.

- b. Dump steam to condenser from intact S/Gs.

- b. Dump steam from intact S/Gs SM PORVs.

- c. WHEN "Pzr Press" less than 1955 PSIG, THEN verify "P-11 Pressurizer S/I Block Permissive" status light is lit.

- 1) Depress the following "Block" pushbuttons and verify "Blocked" lights - LIT:

- ♦ "Pzr SI Trn A (B) Block"
- ♦ "Stm Line SI Trn A (B) Block".

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS Case I Steam Generator Tube Leakage	PAGE NO. 7 OF 23
----------------	--	---------------------

ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
<p>12. Depressurize NC System to minimize break flow:</p> <p>a. Normal Pzr spray - AVAILABLE</p> <p>b. Depressurize until any of the following are satisfied before continuing with this procedure:</p> <ul style="list-style-type: none"><li>◆ NC pressure - LESS THAN RUPTURED S/G PRESSURE</li><li>OR</li><li>◆ Ruptured S/G level - CONSTANT OR DECREASING</li><li>OR</li><li>◆ Pzr level - GREATER THAN 95%.</li></ul> <p>c. Close spray valves or PORV.</p>	<p>a. IF letdown in service, <u>THEN</u> use NV Aux spray.</p> <p>IF letdown not in service, <u>THEN</u> use one Pzr PORV.</p> <p>IF no Pzr PORVs available, <u>THEN</u> use NV Aux spray.</p> <p>c. Stop NC Pump in loop with open spray valve or close Pzr PORV Isol valve for any PORV that will not close.</p>

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS Case I Steam Generator Tube Leakage	PAGE NO. 6 OF 23
----------------	--	---------------------

ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
<p>_____ 13. Check if charging flow can be reduced:</p> <ul style="list-style-type: none"><li>a. Pzr level - GREATER THAN 25% AND INCREASING</li><li>b. Reduce charging flow to maintain Pzr level constant.</li></ul>	<ul style="list-style-type: none"><li>a. Maintain charging flow until level greater than 25%.</li></ul>
<p>_____ 14. Check VCT Makeup Control System:</p> <ul style="list-style-type: none"><li>a. <u>IF</u> started, <u>THEN</u> stop emergency borating when SDM is adequate <u>PER</u> Data Book Table 6.5.</li><li>b. Ensure makeup set for greater than NC System boron concentration.</li><li>c. Ensure "NC Sys M/U Controller" in "Auto" and place "NC System Makeup" switch to "Start".</li></ul>	

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOT. NV PUMPS Case I Steam Generator Tube Leakage	PAGE NO. 9 OF 23
----------------	--	---------------------

ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
<p>15. Establish Letdown:</p> <ol style="list-style-type: none"> <li>Open letdown line isolation valves:               <ul style="list-style-type: none"> <li>◆ 1NV-1A and 2A (NC L/D Isol To Regn Hx)</li> <li>◆ 1NV-7B (Letdown Cont Isol Outside).</li> </ul> </li> <li>Place 1NV-124 (Letdown Press Control) in "Man" and close.</li> <li>Crack open 1NV-459A (A L/D Orifice Outlet Flo Cntrl) and adjust 1NV-124 to maintain "L/D Press" at 350 PSIG.</li> <li><u>WHEN</u> pressure can be maintained without continual adjustment to 1NV-124, <u>THEN</u> slightly open 1NV-459A a little more while monitoring pressure.</li> <li>Continue above procedure until pressure stabilizes quickly after 1NV-459A adjustments and desired flow is achieved.</li> <li>After letdown line is pressurized align letdown valves for desired flowrate:               <ul style="list-style-type: none"> <li>◆ 75 GPM, 1NV-458A (B L/D Orif Otlt Cont Isol) - OPEN/CLOSED</li> <li>◆ 45 GPM, 1NV-457A (C L/D Orif Otlt Cont Isol) - OPEN/CLOSED</li> <li>◆ Variable, 1NV-459A (A L/D Orif Otlt Cont Isol) - CLOSED.</li> </ul> </li> <li>Verify "L/D Press" at 350 PSIG and place 1NV-124 in "Auto".</li> </ol>	<p>Establish excess letdown:</p> <ol style="list-style-type: none"> <li>Ensure open:               <ul style="list-style-type: none"> <li>◆ 1KC-305B (Excess Letdn Hx Sup , Otsd Isol)</li> <li>◆ 1KC-315B (Excess L/D Hx Ret Hdr C/I Otsd)</li> <li>◆ 1NV-94A and 95B (NC Pmps Seal Ret C/I Inside/Otsd).</li> </ul> </li> <li>Place 1NV-27B (Excess L/D Hx Otlt 3-Way Cntrl) to "VCT" position.</li> <li>Open 1NV-24B and 25B (C NC Loop To Exs L/D Hx Isol).</li> <li>Slowly open 1NV-26 (Excess L/D Hx Outlet Cntrl) to maintain "Excess L/D Hx Temp" less than 200°F.</li> </ol>

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS Case I Steam Generator Tube Leakage	PAGE NO. 10 OF 23
----------------	--	----------------------

ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
<p>16. Maintain stable plant conditions:</p> <ul style="list-style-type: none"> <li>a. NC pressure - STABLE</li> <li>b. Pzr level - 25%</li> <li>c. Intact S/G levels - AT NO LOAD</li> <li>d. NC temperatures - STABLE.</li> </ul>	<ul style="list-style-type: none"> <li>a. Operate Pzr heaters and sprays.</li> <li>b. Control charging and letdown.</li> <li>c. Control feed flow.</li> <li>d. Operate Condenser Dumps.</li> </ul>
<p>17. Minimize secondary side contamination:</p> <ul style="list-style-type: none"> <li>a. If available transfer AS header supply to Unit 2:           <ul style="list-style-type: none"> <li>1) Close 1AS-9 (C Htr Bleed to AS) and 1AS-12 (SM To AS).</li> <li>2) Open 1HM-95 (AS To A &amp; B FWPT).</li> </ul> </li> <li>b. <u>IF</u> B S/G ruptured, dispatch operator to locally close 1SM-85 (Stm Line 1B DH Drn Orifice Inlet).</li> <li>c. <u>REFER TO</u> Enclosure 6.</li> </ul>	<ul style="list-style-type: none"> <li>a. Dispatch operator to locally place Aux Electric Boiler in operation <u>PER</u> OP/1/A/6250/07B, AUX ELECTRIC BOILERS, Enclosure 4.2, then do the following:           <ul style="list-style-type: none"> <li>1) Close 1AS-9 (C Htr Bleed to AS) and 1AS-12 (SM To AS).</li> <li>2) Open 1HM-95 (AS To A &amp; B FWPT).</li> </ul> </li> </ul>

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS Case I Steam Generator Tube Leakage	PAGE NO. 11 OF 23
----------------	--	----------------------

## ACTION/EXPECTED RESPONSE

## RESPONSE NOT OBTAINED

- CAUTION ♦ If any NC Pump is running, then the preferred cooldown method is EP/1/A/5000/4.2, SGTR COOLDOWN USING BACKFILL.
- ♦ If water may exist in main steamlines, then EP/1/A/5000/4.1 SGTR COOLDOWN USING STEAM DUMP should not be used.
- ♦ It is strongly recommended that the condenser be available if EP/1/A/5000/4.1, SGTR COOLDOWN USING STEAM DUMP is used. Otherwise an evaluation of using the ruptured S/G SM PORV must be made.

18. Continue plant cooldown to cold shutdown:

a. Select cooldown method for ruptured S/G:

- ♦ EP/1/A/5000/4.1, SGTR  
COOLDOWN USING STEAM DUMP

OR

- ♦ EP/1/A/5000/4.2, SGTR  
COOLDOWN USING BACKFILL

OR

- ♦ EP/1/A/5000/4.3, SGTR  
COOLDOWN USING BLOWDOWN.

b. REFER TO OP/1/A/6100/02,  
CONTROLLING PROCEDURE FOR  
UNIT SHUTDOWN, Enclosure  
4.2 and perform applicable  
steps.

END

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS Case II NC System Leakage	PAGE NO. 12 OF 23
----------------	--	----------------------

ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
<p>B. <u>Symptoms</u></p> <ul style="list-style-type: none"> <li>◆ Increase in frequency of auto makeup to VCT</li> <li>◆ Increased leakrate results from PT/1/A/4150/01B, REACTOR COOLANT LEAKAGE CALCULATIONS</li> <li>◆ Increased radiation from any of the following:               <ul style="list-style-type: none"> <li>◆ "1EMF38 Containment Part Hi Rad" alarm</li> <li>◆ "1EMF39 Containment Gas Hi Rad" alarm</li> <li>◆ "1EMF40 Containment Iodine Hi Rad" alarm</li> <li>◆ "EMF41 Aux Bldg Vent Hi Rad" alarm</li> <li>◆ "1EMF46 A(B) Train A(B) KC Hi Rad" alarm.</li> </ul> </li> <li>◆ Increased levels in any of the following:               <ul style="list-style-type: none"> <li>◆ "Cont Flr/Equip Sump A(B) Level"</li> <li>◆ ND and NS Sump</li> <li>◆ NCDT</li> <li>◆ RHT</li> <li>◆ KC Surge Tank</li> <li>◆ PRT.</li> </ul> </li> <li>◆ Increased temperatures on any of the following:               <ul style="list-style-type: none"> <li>◆ "Pzr PORV Disch Hi Temp" alarm</li> <li>◆ "Pzr Safety Discharge Hi Temp" alarm</li> <li>◆ "Rx Vessel Flange Leak Off Hi Temp" alarm</li> <li>◆ "Letdown Relief Hi Temp" alarm.</li> <li>◆ PRT</li> <li>◆ Containment.</li> </ul> </li> <li>◆ "NC Pump A(B,C,D) Thermal Barrier Outlet Hi Flow" computer alarm</li> <li>◆ Letdown or charging line flow or pressure abnormal.</li> </ul>	

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS Case II NC System Leakage	PAGE NO. 13 OF 23
----------------	--	----------------------

ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
<b>C. <u>Immediate Actions</u></b>	
1. Check Pzr level - AT OR INCREASING TO PROGRAMMED LEVEL.	<u>IF</u> level decreasing, <u>THEN</u> perform the following to maintain level:  a. Ensure 1NV-238 (Charging Line Flow Control) opening in "Auto".  b. Start additional NV Pump.  c. Reduce letdown to 45 GPM orifice or isolate letdown if necessary.  <u>IF</u> level decreases below 5%, <u>THEN</u> manually trip Reactor and initiate SI. <u>GO TO</u> EP/1/A/5000/01, SAFETY INJECTION.  <u>IF</u> less than 2210 PSIG, <u>THEN</u> ensure backup heaters on.  <u>IF</u> pressure approaches 1945 PSIG, <u>THEN</u> trip Reactor.
2. Check Pzr pressure - AT OR INCREASING TO 2235 PSIG.	
<b>D. <u>Subsequent Actions</u></b>	
<u>CAUTION</u> If Pzr level cannot be maintained, (less than 5% and decreasing) then Safety Injection should be manually initiated.	
1. Announce occurrence on paging system.	
2. Check Pzr level - STABLE OR INCREASING.	<u>IF</u> level decreasing with maximum charging flow, <u>THEN</u> manually trip Reactor and initiate SI. <u>GO TO</u> EP/1/A/5000/01, SAFETY INJECTION.
3. <u>REFER TO</u> RP/0/A/5700/00, CLASSIFICATION OF EMERGENCY.	
4. <u>WHEN</u> "VCT Level" less than 16%, <u>THEN</u> open 1NV-221A or 222B (NV Pumps Suct From FWST).	

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS Case II NC System Leakage	PAGE NO. 14 OF 23
----------------	--	----------------------

ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
<p>5. Check if Containment ventilation isolation required:</p> <ul style="list-style-type: none"><li>a. 1EMF 38, 39 or 40 - IN ALARM</li><li>b. Stop VP Fans.</li><li>c. Stop any VQ release in progress.</li></ul>	<p>a. <u>GO TO</u> step 6.</p>
<p>6. Check "EMF41 Aux Bldg Vent Hi Rad" - IN ALARM</p> <ul style="list-style-type: none"><li>a. Verify "1ABF-D-3 VA Filter Exh Bypass Dmpr Trn A(B)" closed lights - LIT.</li><li>b. Verify "2ABF-D-3 VA Filter Exh Bypass Dmpr Train A(B)" closed lights - LIT.</li></ul>	<p><u>GO TO</u> step 7.</p>
<p>7. Check "1EMF-46 KC Hx Outlet" - IN ALARM</p> <ul style="list-style-type: none"><li>a. Dispatch operator to locally verify 1KC-122 (KC Surge Tank Vent) - CLOSED.</li></ul>	<p><u>GO TO</u> step 8.</p>

AP/1'A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case II  
NC System LeakagePAGE NO.  
15 OF 23

## ACTION/EXPECTED RESPONSE

## RESPONSE NOT OBTAINED

8. Check "NC Pmp A(B, C, D) Therm Bar KC Outlet Flow" computer alarm - IN ALARM

GO TO step 9.

- a. Verify the following valve closes on affected pump:

♦ A, 1KC-394A (A NC Pump Therm Bar Otlt)

OR

♦ B, 1KC-364B (B NC Pump Therm Bar Otlt)

OR

♦ C, 1KC-345A (C NC Pump Therm Bar Otlt)

OR

♦ D, 1KC-413B (D NC Pump Therm Bar Otlt).

- b. Verify "1A(B, C, D) NC Pump L/B Temp" remains less than 225°F.

b. IF greater than 225°F, THEN trip NC Pump.

9. IF required to stop leak, THEN isolate letdown:

GO TO step 10.

- a. ~~Close~~ 1NV-1A and 2A (NC L/D Isol to Regen Hx) to isolate ~~normal~~ letdown.

- b. Verify charging flow - DECREASING TO MINIMUM.

b. Take manual control and reduce charging flow to 32 GPM.

- c. Establish excess letdown PER OP/1/A/6200/01, CHEMICAL AND VOLUME CONTROL, Enclosure 4.8.

- d. Power operation may continue as long as NC System activity and chemistry requirements are met.

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS Case II NC System Leakage	PAGE NO. 16 OF 23
----------------	--	----------------------

ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
<p>10. IF required to stop leak, THEN isolate normal charging.</p> <p>a. Isolate letdown:</p> <p>1) Close 1NV-1A and 2A (NC L/D Isol To Regen Hx).</p> <p>b. Isolate charging:</p> <p>1) Close 1NV-244A and 245B (Charging Line Cont Isol Otsd)</p> <p>2) Manually throttle 1NV-238 (Charging Line Flow Control) to maintain 8 GPM seal injection flow per NC Pump.</p> <p>c. Establish excess letdown <u>PER</u> OP/1/A/6200/01, CHEMICAL AND VOLUME CONTROL, Enclosure 4.2.</p> <p>d. Power operation may continue as long as NC System activity and chemistry requirements are met.</p>	<p><u>GO TO</u> step 11.</p>

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS Case II NC System Leakage	PAGE NO. 17 OF 23
----------------	--	----------------------

ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
<p>11. Attempt to identify and isolate leak:</p> <p>a. Check "Pzr PORV Disch Hi Temp" - IN ALARM</p> <p>1) Verify Pzr PORV's - CLOSED</p> <p>2) Determine which valve is leaking by monitoring "PORV Relief Valve Temp" while cycling a PORV isolation and its sample valve one at a time:</p> <ul style="list-style-type: none"><li>◆ 1NC-33A (Pzr PORV Isol) and 270 (Pzr Relief Hrd Sample Isol)</li><li>◆ 1NC-35B (Pzr PORV Isol) and 269 (Pzr Relief Hdr Sample Isol)</li><li>◆ 1NC-31B (Pzr PORV Isol) and 271 (Pzr Relief Hrd Sample Isol).</li></ul> <p>b. Check "Cold Leg Accumulator Level" - INCREASING</p> <p>1) Close Accumulator isolation valve</p> <p style="text-align: center;">OR</p> <p>Drain accumulator <u>PER</u> OP/1/A/6200/09, ACCUMULATOR OPERATION, Enclosure 4.2.</p> <p>c. Check "Pzr Relief Tank Level (Temp)" - INCREASING ABOVE NORMAL</p> <p>1) Check inputs to PRT <u>PER</u> Enclosure 1.</p>	<p>a. <u>GO TO</u> step b.</p> <p>1) Close Pzr PORV's.</p> <p>b. <u>GO TO</u> step c.</p> <p>c. <u>GO TO</u> step d.</p>

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS Case II NC System Leakage	PAGE NO. 18 OF 23
----------------	--	----------------------

ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
d. Check NCDT level or temperature - INCREASING ABOVE NORMAL	d. <u>GO TO</u> step e.
1) Check inputs to NCDT <u>PER</u> Enclosure 2.	
e. Check "Cont Flr/Eqp Sump A(B) Level" - INCREASING ABOVE NORMAL	e. <u>GO TO</u> step f.
1) Check inputs to sumps <u>PER</u> Enclosure 3.	
f. Check inputs to Aux Building Sumps from NV System <u>PER</u> Enclosure 4.	f. <u>GO TO</u> step g.
g. Check ND System - IN SERVICE	g. <u>GO TO</u> step 12.
1) Check inputs to Aux Building Sumps from ND System <u>PER</u> Enclosure 5.	
12. IF leak can not be isolated <u>AND</u> unit shutdown is required, <u>THEN</u> notify NRC via red phone <u>PER</u> RP/0/A/5700/10, NRC IMMEDIATE NOTIFICATION REQUIREMENTS.	IF leak is isolated, <u>THEN</u> consult Unit 1 Operations Manager for further actions and end this procedure.
<u>NOTE</u> Load reduction rate should be determined based on leak rate flow and on ability to take the unit off line in a controlled manner.	
13. Begin unit load reduction to remove unit off line.	
14. Check NC Pumps - ALL RUNNING.	Start all available NC Pumps <u>PER</u> OP/1/A/6150/02A, NC PUMP OPERATION.

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS Case II NC System Leakage	PAGE NO. 19 OF 23
----------------	--	----------------------

ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
<p><u>NOTE</u> ♦ Blocking the steamline low pressure SI signal will enable the steamline pressure rate, main steam isolation signal.</p> <p>♦ If an NC Pump is running, administrative cooldown rate of 50°F/HR may be exceeded in the following steps.</p>	
<p>15. Begin NC System cooldown to 200°F:</p>	
<p>a. <u>REFER TO</u> OP/1/A/6100, 02, CONTROLLING PROCEDURE FOR UNIT SHUTDOWN, Enclosure 4.2 and perform applicable steps.</p> <p>b. Maintain cooldown rate - LESS THAN 100°F/HR (50°F/HR with no NC Pumps running)</p> <p>c. Dump steam to condenser.</p> <p>d. Control CA flow to maintain "S/G NR Lv1" - AT NO LOAD.</p> <p>e. Maintain NC System boron concentration - GREATER THAN SDM REQUIREMENTS OF DATA BOOK TABLE 6.5.</p> <p>f. <u>WHEN</u> "Pzr Press" less than 1955 PSIG, <u>THEN</u> verify "P-11 Pressurizer S/I Block Permissive" status light is lit.</p>	<p>c. Dump steam using SM PORVs.</p>
<p>1) Depress the following "Block" pushbuttons and verify "Blocked" lights - LIT:</p> <p>♦ "Pzr SI Trn A (B) Block"</p> <p>♦ "Stm Line SI Trn A (B) Block".</p>	<p>f. Continue with step 16.</p>

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS Case II NC System Leakage	PAGE NO. 20 OF 23
----------------	--	----------------------

ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
<p>16. Check if cold leg accumulators should be isolated:</p> <p>a. NC System subcooling - GREATER THAN 0°F</p> <p style="text-align: center;">AND</p> <p>NC pressure - LESS THAN 1000 PSIG</p> <p>b. Place the following switches to "Enable" and close the respective valve:</p> <ul style="list-style-type: none"> <li>◆ "Pwr Discon For 1NI-54A"</li> <li>◆ "Pwr Discon For 1NI-76A"</li> <li>◆ "Pwr Discon For 1NI-65B"</li> <li>◆ "Pwr Discon For 1NI-88B".</li> </ul>	<p>a. Continue with this procedure while monitoring pressure and subcooling.</p> <p><u>WHEN</u> both conditions are met, <u>THEN</u> do step b.</p> <p>b. Vent any unisolated accumulator:</p> <p>1) Open isolation valve on affected accumulator:</p> <ul style="list-style-type: none"> <li>◆ 1NI-50 (A CL Accum N2 Supply Isol)</li> <li>◆ 1NI-61 (B CL Accum N2 Supply Isol)</li> <li>◆ 1NI-72 (C CL Accum N2 Supply Isol)</li> <li>◆ 1NI-84 (D CL Accum N2 Supply Isol)</li> </ul> <p>2) Open 1NI-83 (CL Acc N2 Hdr Atmos Vent Isol).</p>
<p>17. Check if one NV Pump should be stopped:</p> <p>a. NC System subcooling - GREATER THAN 50°F</p> <p style="text-align: center;">AND</p> <p>Pzr level - GREATER THAN 5%</p> <p>b. Both NV Pumps - RUNNING</p> <p>c. Stop one NV Pump.</p>	<p>a. Continue dumping steam.</p> <p><u>WHEN</u> subcooling greater than 50°F <u>AND</u> Pzr level greater than 5% <u>THEN GO TO</u> step b.</p> <p>b. <u>GO TO</u> step 19.</p>

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS Case II NC System Leakage	PAGE NO. 21 OF 23
----------------	--	----------------------

ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
<p>18. Check NC System conditions:</p> <p>a. Subcooling - GREATER THAN 0°F</p> <p style="text-align: center;">AND</p> <p>Pzr level - GREATER THAN 5%</p> <p>19. Adjust charging flow to maintain NC System subcooling and Pzr level during cooldown.</p>	<p>a. Restart NV Pump and continue dumping steam.</p> <p><u>WHEN</u> NC System subcooling greater than 75°F  <u>AND</u> Pzr level greater than 5%  <u>THEN RETURN TO</u> step 17.</p>
<p>20. Establish letdown:</p> <p>a. Open letdown line isolation valves:</p> <ul style="list-style-type: none"> <li>◆ 1NV-1A and 2A (NC L/D Isol To Regen Hx)</li> <li>◆ 1NV-7B (Letdown Cont Isol Outside).</li> </ul> <p>b. Place 1NV-124 (Letdown Press Control) in "Man" and close.</p> <p>c. Crack open 1NV-459A (A L/D Orif Outlet Flow Cntrl) and adjust 1NV-124 to maintain "L/D Press" at 350 PSIG.</p> <p>d. <u>WHEN</u> pressure can be maintained without continual adjustment to 1NV-124, <u>THEN</u> slightly open 1NV-459A a little more while monitoring pressure.</p> <p>e. Continue above procedure until pressure stabilizes quickly after 1NV-459A adjustments and desired flow is achieved.</p>	<p>Establish excess letdown:</p> <p>1) Ensure open:</p> <ul style="list-style-type: none"> <li>◆ 1KC-305B (Excess Letdn Hx Sup Ottd Isol)</li> <li>◆ 1KC-315B (Excess L/D Hx Ret Hdr C/I Ottd)</li> <li>◆ 1NV-94A (NC Pumps Seal Ret C/I Inside)</li> <li>◆ 1NV-95B (NC Pumps Seal Ret C/I Ottd).</li> </ul> <p>2) Place 1NV-27B (Excess L/D Hx Otlt 3-Way Cntrl) to "VCT" position.</p> <p>3) Open 1NV-24B and 25B (C NC Loop To Exs L/D Hx Isol).</p> <p>4) Slowly open 1NV-26 (Excess L/D Hx Outlet Cntrl). Adjust valve to maintain "Excess L/D Hx Temp" less than 200°F.</p>

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS Case II NC System Leakage	PAGE NO. 22 OF 23
----------------	--	----------------------

ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
<p>f. After letdown line is pressurized align letdown valves for desired flowrate:</p> <ul style="list-style-type: none"> <li>◆ 75 GPM - 1NV-458A (B L/D Orif Otl't Cont Isol) - OPEN/CLOSED</li> <li>◆ 45 GPM - 1NV-457A (C L/D Orif Otl't Cont Isol) - OPEN/CLOSED</li> <li>◆ Variable - 1NV-459A (A L/D Orif Otl't Cont Isol) - CLOSED.</li> </ul> <p>g. Verify "L/D Press" at 350 PSIG and place 1NV-124 in "Auto".</p>	
<p>21. Control Pzr pressure:</p> <p>a. Energize Pzr heaters and operate normal spray to maintain pressure within Data Book Curve 1.6.</p>	<p>a. <u>IF</u> letdown in service, <u>THEN</u> use 1NV-21A (NV Spray To Pzr Isol).  <u>IF</u> letdown not in service, <u>THEN</u> use one Pzr PORV.</p>
<p>22. Maintain NC System subcooling - GREATER THAN 50°F.</p>	<p>Establish 50°F subcooling:</p> <p>a. Limit NC System cooldown rate to less than 100°F/HR (50°F/HR if no NC Pumps running).</p> <p>b. Dump steam to condenser</p> <p style="text-align: center;">OR</p> <p>Dump steam with SM PORVs.</p> <p><u>IF</u> cooldown is not adequate to restore subcooling, <u>THEN</u> increase NC System pressure.</p>

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case II  
NC System LeakagePAGE NO.  
23 OF 23

## ACTION/EXPECTED RESPONSE

## RESPONSE NOT OBTAINED

23. Check if ND System can be placed in service:

- a. NC hot leg temperatures - LESS THAN 350°F

AND

NC pressure - LESS THAN 385 PSIG

- b. Place ND System in service PER OP/1/A/6200/04, RESIDUAL HEAT REMOVAL, Enclosure 4.1.

- a. Continue dumping steam. Do not proceed until conditions met.

- b. Continue dumping steam while trying to place ND System in service.

24. Prior to going below 300°F place low temperature over pressure protection system in service:

- a. NC pressure - LESS THAN 325 PSIG
- b. Place "PORV Overpress Protection Select 1NC-34A (23B)" switch to "Low Press".
- c. Verify 1NI-430A and 431B (N<sub>2</sub> To 1NC-34A (32B) From A(B) CL Accum) - OPEN.

25. Use ND System and S/Gs to continue cooldown to less than 200°F.

26. WHEN NC System cooldown complete, THEN stop NC Pumps AND depressurize to stop break flow.

27. Evaluate long term plant status:

- a. Further actions should be at the discretion of the TSC.

END

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACTIY OF BOTH NV PUMPS  
Case II - Enclosure 1  
Possible NC System Leakage Paths To PRT

PAGE NO.

1 OF 2

Valve Number	Nomenclature	Position	Initial
POSSIBLE NC SYSTEM LEAKAGE PATHS TO PRT			
OUTSIDE CONTAINMENT			
OUTSIDE CONTAINMENT			
1ND-56	ND HX 1A OUTLET TO NI SYSTEM COLD LEG INJECTION SAFETY RELIEF		
1ND-61	ND HX OUTLET TO NI SYSTEM HOT LEG INJECTION SAFETY RELIEF		
1ND-64	ND HX 1B OUTLET TO NI SYSTEM COLD LEG INJECTION SAFETY RELIEF		
1NS-2	NS PUMP 1B SUCTION SAFETY RELIEF		
1NS-19	NS PUMP 1A SUCTION SAFETY RELIEF		
1NI-102	SAFETY INJECTION PUMPS SUCTION HDR SAFETY RELIEF		
1NI-119	SAFETY INJECTION PUMP 1A DISCHARGE SAFETY RELIEF		
1NI-151	SAFETY INJECTION PUMP 1B DISCHARGE SAFETY RELIEF		
1NI-161	SAFETY INJECTION PUMPS COLD LEG INJECTION HDR SAFETY RELIEF		
1NV-229	CENTRIFUGAL CHARGING PUMPS SUCTION HDR SAFETY RELIEF		
INSIDE CONTAINMENT			
1NC-1	PZR RELIEF VALVE		
1NC-2	PZR RELIEF VALVE		
1NC-3	PZR RELIEF VALVE		
1NC-32B	PZR PORV		
1NC-34A	PZR PORV		
1NC-36B	PZR PORV		
1NC-43	PRESSURIZER #1 VENT		
1NC-119	PRESSURIZER #1 SEAL LOOP DRAIN HEADER		

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACTIY OF BOTH NV PUMPS  
Case II - Enclosure 1  
Possible NC System Leakage Paths To PRT

PAGE NO.

2 OF 2

## VALVE CHECKLIST

VALVE NUMBER

NOMENCLATURE

INITIAL

1NC-272A,C TRN 1A HEAD VENT TO PRT ISOL

1NC-274B TRN 1B HEAD VENT TO PRT ISOL

1ND-3 NC LOOP 3 DISCHARGE TO ND SYSTEM SAFETY RELIEF

1NV-6 LETDOWN LINE SAFETY RELIEF

1NV-93 NC PUMPS SEAL RETURN HDR SAFETY RELIEF

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case II - Enclosure 2  
Possible NC System Leakage Paths To NCDT

PAGE NO.  
1 OF 1

VALVE NUMBER	NOMENCLATURE	VALVE LOCATION	POSITION	INITIAL
--------------	--------------	----------------	----------	---------

## Possible NC System Leakage Paths To NCDT

1NV-27B	Excess L/D Hx Otlt 3-Way Cntrl	RB Pipechase 105°	VCT	
1NI-224	Accumulator 1A Drain Isol	RB 725' 40°	Closed	
1NI-226	Accumulator 1B Drain Isol	RB 725' 140°	Closed	
1NI-228	Accumulator 1C Drain Isol	RB 725' 220°	Closed	
1NI-230	Accumulator 1D Drain Isol	RB 725' 317°	Closed	
1NB-352	Reactor Makeup Water Storage Tank #1 Outlet Relief To NCDT			

NC Pump	1A #3 Seal			
NC Pump	1A Standpipe			
NC Pump	1B #3 Seal			
NC Pump	1B Standpipe			
NC Pump	1C #3 Seal			
NC Pump	1C Standpipe			
NC Pump	1D #3 Seal			
NC Pump	1D Standpipe			
	Valve Steam Leakoff from			
	RB valves			
	Rx Vessel Head O Ring Seal			

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS Case II - Enclosure 3 Possible NC System Leakage Paths to Containment Sumps	PAGE NO. 1 OF 1
----------------	--	--------------------

# VALVE CHECKLIST

[illegible]

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS Case II - Enclosure 4 Possible NV System Leakage Paths in Auxiliary Building	PAGE NO. 1 OF 6
----------------	---	--------------------

## VALVE CHECKLIST

VALVE NUMBER	NOMENCLATURE	VALVE LOCATION	POSITION	INITIAL
--------------	--------------	----------------	----------	---------

NOTE This Enclosure is to be used as a guide. Consideration should be given to any recent change in NV System alignment.

Check Seal Leakoff on following valves:

ND & NS ROOMS SUMP

1NV-95B	NC Pumps Seal Ret C/I	744' Midget Hole		
	OTSD			

1NV-127A	L/D Hx Outlet 3-Way Temp	NC FILTER ROOM		
	Cntrl			

1NV-137A	NC Filters OTLT 3 Way	Outside VCT Rm. So. Wall		
	Cntrl			

1NV-141A	VCT Outlet Isolation	OTSD S Wall of VCT		
		under grating		

1NV-142B	VCT Outlet Isol	OTSD SE Wall of VCT		
		under grating		

1NV-803	PD Pump Outlet Isol	722' S. of PD Pump		
---------	---------------------	--------------------	--	--

1NV-219	PD Pump Disch Isol	PD Pump Rm		
---------	--------------------	------------	--	--

1NV-240	Regen Hx Tube Inlet Cntrl	722 HH-59 & JJ-60		
	Isol			

1NV-241	Seal Inj Flow Control	Above BW Pumps		
---------	-----------------------	----------------	--	--

1NV-242	Regen Hx Tube Side Inlt	Above BW Pumps		
	Cntrl Isol			

1NV-243	Regen Hx Tube Side Inlt	Above BW Pumps		
	Cntrl Bypass			

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS Case II - Enclosure 4 Possible NV System Leakage Paths in Auxiliary Building	PAGE NO. 2 OF 6
----------------	---	--------------------

VALVE NUMBER	NOMENCLATURE	VALVE LOCATION	POSITION	INITIAL
1NV-244A	Charging Line Cont Isol OTSD	Above BW Pumps		
1NV-245B	Charging Line Cont Isol OTSD	West of BW Pumps		
1NV-431	Seal Water Inj Filters Bypass	A Seal Inj Rm		
1NV-230	Cent Charging Pump B Suct		726' SE of 1B CCP 12'	
		Off floor		
1NV-224	Cent Charging Pump A Suct. 726' HH-57 & JJ-58 W of 1B CCP 12' Off Floor			
1NV-804	Cent Charging Pump B Outlet Isol	Right of 1B CCP		
1NV-232	Cent Charging Pump B Disch	724' NW of 1B CCP		
1NV-226	Cent Charging Pump A Disch	726' NE of 1B CCP		
1NV-802	Cent Charging Pump A Outlet Isol	NE 5' Above 1A CCP		
1NV-235	Cent Charging Pump B To Seal Inj Filter	NW of 1B CCP		
1NV-236	Cent Charging Pump A To Seal Inj Filter	NE of 1A CCP		
1NV-237	Cent Charging Pumps Disch N of PD Pump To Control Isol			
1NV-238	Charging Line Flow Control	N of PD Pump		
1NV-239	Cent Charging Pumps Disch			

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case II - Enclosure 4  
Possible NV System Leakage Paths in Auxiliary Building

PAGE NO.

3 OF 6

VALVE NUMBER	NOMENCLATURE	VALVE LOCATION	POSITION	INITIAL
--------------	--------------	----------------	----------	---------

## Control Isol

1NV-347	NR System Flow Control	Seal Inj Filter Room		
---------	------------------------	----------------------	--	--

1NV-121	ND Letdown Control			
---------	--------------------	--	--	--

1NV-221A	NV Pumps Suct From FWST	20' N of BW Pump		
----------	-------------------------	------------------	--	--

1NV-222B	NV Pumps Suct From FWST	20' N of BW Pump		
----------	-------------------------	------------------	--	--

## RECYCLE HOLDUP TANK

1NV-7B	Letdown Cont Isol Outside			
--------	---------------------------	--	--	--

1NV-8	L/D Reheat Hx Tubeside	SE of L/D Hx		
-------	------------------------	--------------	--	--

Back pressure Cntrl Isol

1NV-9	L/D Reheat Hx Tubeside	W of L/D Hx		
-------	------------------------	-------------	--	--

Back pressure Cntrl Isol

1NV-10	L/D Reheat Hx Tubeside	W of L/D Hx		
--------	------------------------	-------------	--	--

Back Pressure Cntrl Isol

1NV-11	L/D Reheat Hx Tubeside	SW of L/D Hx		
--------	------------------------	--------------	--	--

Back Pressure Cntrl Isol

1NV-476	LP Letdown Control Inlet	S of L/D Hx		
---------	--------------------------	-------------	--	--

Isol

1NV-124	Letdown Press Control	L/D Hx Rm		
---------	-----------------------	-----------	--	--

1NV-477	LP Letdown Control	L/D Hx Rm		
---------	--------------------	-----------	--	--

Outlet Isol

Check vent and drain boundary valves closed:

## WASTE DRAIN TANK

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case II - Enclosure 4  
Possible NV System Leakage Paths in Auxiliary Building

PAGE NO.  
4 OF 6

VALVE NUMBER	NOMENCLATURE	VALVE LOCATION	POSITION	INITIAL
1NV-184	Letdown Hx Tube Drain To WDT	L/D Hx Rm	CLOSED	
1NV-205	Seal Water Filter Drain To WDT	Seal Ret Filter Rm	CLOSED	
1NV-272	PD Pump Drain To WDT	Otsd PD Pump Rm	CLOSED	
1NV-310	Seal Water Inj Filters Drain To WDT	B Seal Inj Rm	CLOSED	
1NV-299	Charging Pump B Drain To WDT	E of 1B CCP	CLOSED	
1NV-330	NC Filter Drain To WDT	E of B NC Filters	CLOSED	
1NV-356	Mixed And Cation Bed Demin Outlet Line Drain To WDT	A Mixed Bed Rm	CLOSED	
WASTE EVAPORATOR FEED TANK				
1NV-181	Letdown Hx Tube Overflow	L/D Hx Rm	CLOSED	
1NV-185	Letdown Hx Tube Drain To WEFT	LD Hx Rm	CLOSED	
1NV-145	VCT Outlet Drain	Below VCT	CLOSED	
1NV-210	Seal Water Hx Tube Overflow		CLOSED	
1NV-204	Seal Water Filter Drain To WEFT		CLOSED	
1NV-215	Seal Water Hx Tube Drain TO WEFT	Seal Water Hx Rm	CLOSED	
1NV-309	Seal Water Inj Filters	B Seal Inj Filter Rm	CLOSED	

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case II - Enclosure 4  
Possible NV System Leakage Paths in Auxiliary Building

PAGE NO.  
5 OF 6

VALVE NUMBER	NOMENCLATURE	VALVE LOCATION	POSITION	INITIAL
	Drain To WEFT			
1NV-329	NC Filters Drain To WEFT	B NC Filter Rm	CLOSED	
1NV-335	Mixed Bed Demin A Backflush			
	Drain			
1NV-333	Mixed Bed Demin A Backflush		CLOSED	
	Outlet Isol			
1NV-340	Mixed Bed Demin B	B Mixed Bed Rm	CLOSED	
	Backflush Outlet Isol			
1NV-373	Mixed Bed Demin B	B Mixed Bed Rm	CLOSED	
	Outlet Line Drain			
1NV-365	Cation Bed Demin	733 Pipechase between NR &	CLOSED	
	Sluicing Resin Isol	NV DIM		
1NV-354	Mixed Bed Demin A Outlet	A Mixed Bed Rm	CLOSED	
	Line Drain			
1NV-366	Cation Bed Demin Outlet	Cation Bed Rm	CLOSED	
	Line Drain			
1NV-357	Mixed & Cation Bed	A Mixed Bed Rm	CLOSED	
	Demins Outlet Line Drain			
	To WEFT			
	WASTE EVAPORATOR FEED TANK SUMP A			
1NV-296	Charging Pump B Overflow		CLOSED	
1NV-300	Charging Pump B Drain To		CLOSED	
	WEFT Sump A			
1NV-285	Charging Pump A Overflow		CLOSED	
1NV-289	Charging Pump A Drain To		CLOSED	
	WEFT Sump A			



AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
CASE II - Enclosure 5  
Possible ND System Leakage Paths in Auxiliary Building

PAGE NO.  
1 OF 2

VALVE NUMBER	NOMENCLATURE	VALVE LOCATION	POSITION	INITIAL
--------------	--------------	----------------	----------	---------

ND & NS ROOMS SUMP Check seal leakoff on following valves

1ND-4B B ND Pmp Suct From FWST Aux 695' FF-59 & GG-60

Or NC

1ND-19A A ND Pmp Suct From FWST Aux 695' GG-59 & HH-60

Or NC

1ND-9 ND Pump B Disch N of Pump 12' up

1ND-24 ND Pump A Disch W of Pump 12' up

1ND-26 ND Hx A Inlet E of Hx 6' up

1ND-14 B ND Hx Outlet Aux 733' LL-61

1ND-29 A ND Hx Outlet Aux 733' LL-60 & MM-61

1ND-30A Train 1A ND To Hot Leg Aux 733' LL-60 & MM-61

Isol

1ND-58A Train 1A ND To NV & NI Aux 733' LL-60 & JJ-61

Pumps

1ND-15B Train 1B ND To Hot Leg Aux 733' KK-60 & LL-61

Isol

1ND-35 ND To FWST Isol 15' E of KK-59, 12' up

1ND-34 A & B ND Hx Bypass Aux 733 KK-60 & LL-61

1ND-33 A ND Hx Bypass Aux 733 LL-60 & MM-61

1ND-18 B ND Hx Bypass Aux 733 KK-60 & LL-61

1ND-11 ND Hx B Inlet W of Hx 4' up

1NI-173A Train 1A ND To A & B CL Aux 733' FF-59 & GG-60

1NI-178B Train 1B ND To C&D CL Aux 733' HH-60 & JJ-61

1NI-184B RB Sump To Train 1B ND Aux 716' EE-58 & FF-59

& NS

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
CASE II - Enclosure 5  
Possible ND System Leakage Paths in Auxiliary Building

PAGE NO.

2 OF 2

VALVE NUMBER	NOMENCLATURE	VALVE LOCATION	POSITION	INITIAL
--------------	--------------	----------------	----------	---------

1NI-185A	RB Sump To Train 1A ND & NS	Aux 716' FF-59 & GG-60		
----------	--------------------------------	------------------------	--	--

WASTE EVAPORATOR FEED TANK Check Drain Boundary Valves Closed

1ND-52	ND HX A Drain Hdr	S of Hx	Closed	
1ND-46	ND Hx B Drain Hdr	S of Hx	Closed	

ND &amp; NS ROOMS SUMP

1ND-51	ND Pump A Drain Hdr	SW of Pump	Closed	
1ND-45	ND Pump B Drain Hdr	S of Pump	Closed	
1ND-69	ND & NS System Drain	RB 860' Rx Dome	Closed	

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS Enclosure 6 Minimizing Secondary Side Contamination	PAGE NO. 1 OF 3
----------------	--	--------------------

1. Notify the following to initiate their S/G tube leak response procedures:  
HP Shift (4282)  
RDW Shift (4305)  
CT Lab (4362).
2. Minimize draining into Turbine Building Sump by dispatching operator to locally perform the following:
  - A) Secure CSAE drains to TB sump as follows:  
Open 1CS-26 (CSAE After Condenser Drn Isol)  
Close: 1ZJ-24 (CSAE 1A After Condenser Lo Pt Drn)  
1ZJ-25 (CSAE 1B After Condenser Lo Pt Drn)  
1ZJ-26 (CSAE 1C After Condenser Lo Pt Drn).
  - B) Align WZ Sump Pumps to pump to Unit 2 only:
    - 1) In WZ Sump A place Pump A in "Off" and Pump B in "Auto".
    - 2) In WZ Sump B place Pump A in "Auto" and Pump B in "Off".
    - 3) IF either Unit 2 pump is out of service, THEN manually pump only enough water to Unit 1 to keep Hi level alarm cleared.
  - C) Secure any other components draining into TB Sump.
  - D) Open 1CS-62 (NB + WL Cond To Unit 2 CST) and close 1CS-61 (NB + WL Cond To Unit 1 CST)
  - E) Align 1CB-197 (Aux Electric Boiler Blowdown 3 Way Divert) to Unit 2 Turbine Building Sump when it has been determined that blowdown is not contaminated.
  - F) Align Aux Electric Boiler Feed Pumps miniflow to Unit 2 CST:
    - a. Open 1CB-108 (Aux Electric Blr A and B Feed Pump Miniflow to Unit CST Isol)
    - b. Close 1CB-101 (Aux Electric Blr A and B Feed Pump Miniflow to Unit 1 CST Isol).

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Enclosure 6  
Minimizing Secondary Side Contamination

PAGE NO.

2 OF 3

G) Align Aux Electric Boiler Feed Pump Suction to Unit 2 UST or YM:

a. Open 1CB-93 (Unit 2 UST To Any Electric Blr Isol)

OR

1CB-135 (Demin Water to Aux Electric Blr Isol)

b. Close 1CB-91 (Unit 1 UST To Aux Electric Blr Isol).

3. IF Unit 2 condensate available to supply CA storage tank, THEN dispatch operator to locally perform the following:

A) Throttle open 1CA-158 (Unit 2 CM To CA Storage Tank Isol) and close 1CA-157 (Unit 1 CM TO CA Storage Tank Isol).

B) Open 1CA-154 (CA Storage Tank Overflow To Unit 2 CST Isol) and close 1CA-153 (CA Storage Tank Overflow To Unit 1 CST Isol).

4. Close 1CA-6 (CA Sup From CA Storage Tank).

CAUTION Constant communication should be maintained with Radwaste Chemistry if pumpover from Turbine Bldg sump to Floor Drain Tank is required.

5. TB Sump will overflow into hotwell pit. If equipment damage in hotwell pit is imminent (Amertap pumps) and before pump out to RC is allowed, then locally realign to pump to Floor Drain Tank as follows:

A) Close 1WP-6 (TB Sump Pumps Dis. To WC Isol)

B) Verify Radwaste Chemistry has made alignment to FDT and pump over only enough volume to prevent equipment damage in hotwell pit.

C) When Radwaste Chemistry can no longer receive water to Waste System, stop the pump over from Turbine Bldg. Sump. If pump out to WC is not possible per HP, prepare for flooding of equipment in hotwell sump. (Amertap etc.).

6. When HP sample results allow pumping to RC, manually pump out sump PER OP/1/B/6400/01A, CONDENSER CIRCULATING WATER AND LOW LEVEL INTAKE, Enclosure 4.11.

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS Enclosure 6 Minimizing Secondary Side Contamination	PAGE NO. 3 OF 3
----------------	--	--------------------

ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
7. <u>IF</u> Unit 1 CST is in danger of overflowing or if Unit 2 is in danger of losing condensate, <u>THEN</u> coordinate with HP to pump to Unit 2 CST <u>PER</u> OP/1/A/6250/01, CONDENSATE AND FEEDWATER, Enclosure 4.10.	
8. Realign the following for normal operation as required after condition is cleared:	
A) CSAE drains to TB sump	
B) WZ Pumps to Auto	
C) TB Sump Pumps	
D) CA Storage Tank supply and overflow to desired unit	
E) Open 1CA-6 (CA Sup From CA Storage Tank).	
F) NB and WL evaporator condensate to desired unit	
G) Aux Electric Boiler to desired unit.	

**Attachment 2**

Selected Pages from the Westinghouse Owners' Group Emergency  
Response Guidelines.

Number E-0	Title REACTOR TRIP OR SAFETY INJECTION	Rev.Issue/Date HP-Rev.1A 1 July 1987
---------------	---	--

**A. PURPOSE**

This guideline provides actions to verify proper response of the automatic protection systems following manual or automatic actuation of a reactor trip or safety injection, to assess plant conditions, and to identify the appropriate recovery guideline.

**B. SYMPTOMS OR ENTRY CONDITIONS**

- 1) The following are symptoms that require a reactor trip, if one has not occurred:  
[Enter plant specific setpoints and requirements].
- 2) The following are symptoms of a reactor trip:
  - a. Any reactor trip annunciator lit.
  - b. Rapid decrease in neutron level indicated by nuclear instrumentation.
  - c. All shutdown and control rods are fully inserted. Rod bottom lights are lit.
- 3) The following are symptoms that require a reactor trip and safety injection, if one has not occurred:  
[Enter plant specific setpoints and requirements].
- 4) The following are symptoms of a reactor trip and safety injection:
  - a. Any SI annunciator lit.
  - b. SI pumps running.
  - a. [Enter plant specific list].

## 1. INTRODUCTION

Guideline E-0, REACTOR TRIP OR SAFETY INJECTION, provides actions to verify proper response of the automatic protection systems following manual or automatic actuation of a reactor trip or safety injection, to assess plant conditions, and to identify the appropriate Optimal Recovery Guideline.

Guideline E-0 is to be entered when any of the following occur:

- 1) A reactor trip is required as determined by plant specific setpoints or requirements being exceeded.
- 2) A reactor trip has occurred as determined by the plant annunciators, neutron flux instrumentation, and control rod position indicators.
- 3) A safety injection is required as determined by plant specific setpoints or requirements being exceeded.
- 4) A safety injection has occurred as determined by the plant annunciators, SI pump status, or other plant specific means.

Once E-0 is entered, it is not exited until there is a direct transition to an Optimal Recovery Guideline (ORG) as directed by the symptoms being monitored in E-0 or to a Function Restoration Guideline (FRG) as directed by the Critical Safety Function Status Trees or symptoms being monitored in E-0.

## 2. DESCRIPTION

Guideline E-0, REACTOR TRIP OR SAFETY INJECTION, provides the operator with the necessary guidance to verify that all automatic actions have occurred as designed and presents the diagnostic sequence to be followed in the identification of the appropriate Optimal Recovery Guideline. These include:

1. ECA-0.0, LOSS OF ALL AC POWER
2. ES-0.1, REACTOR TRIP RESPONSE
3. E-1, LOSS OF REACTOR OR SECONDARY COOLANT
4. E-2, FAULTY STEAM GENERATOR ISOLATION
5. E-3, STEAM GENERATOR TUBE RUPTURE
6. ES-1.1, SI TERMINATION
7. ECA-1.2, LOCA OUTSIDE CONTAINMENT

It is expected that the operator will attempt to take manual actions to correct for anomalous conditions during power operation. Such actions would include taking manual control of the automatic control systems, turning on additional charging pumps, reducing power level, etc. If these types of actions do not alleviate the trend toward a reactor trip or safety injection, the operator is permitted to trip the reactor and, if necessary, actuate safety injection.

The reactor protection equipment is designed to safely shut down the reactor in the event that the anomalous condition cannot be corrected. The safety injection system is designed to provide emergency core cooling water and boration to maintain a safe reactor shutdown condition. The plant safeguards systems operate with offsite electrical power or from onsite emergency diesel-electric power, should offsite power not be available. The operator will enter E-0 on ~~a reactor trip or~~ safety injection, whether the signal was automatic or a result of manual actuation.

Through symptom-based diagnosis, the operator is directed to the proper Optimal Recovery Guideline to facilitate optimal recovery. Transient descriptions are provided in the appropriate background documents.

Number <b>ES-3.3</b>	Title <b>POST-SGTR COOLDOWN USING STEAM DUMP</b>	Rev.Issue/Date <b>HP-Rev.1A 1 July 1987</b>
-------------------------	---	--

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
<p><b>CAUTION</b></p> <ul style="list-style-type: none"> <li>o Steam should not be released from any ruptured SG if water may exist in its steamline.</li> <li>o An offsite dose evaluation should be completed prior to using this guideline.</li> </ul> <p><b>NOTE</b> Foldout page should be open.</p>		
<b>1</b>	<b>Turn On PRZR Heaters As Necessary To Saturate PRZR Water At Ruptured (SG)s Pressure</b>	
<b>2</b>	<p><b>Check If SI Accumulators Should Be Isolated:</b></p> <ul style="list-style-type: none"> <li>a. Check the following: <ul style="list-style-type: none"> <li>o RCS subcooling based on core exit TCs - GREATER THAN (1)*F [(2)*F FOR ADVERSE CONTAINMENT]</li> <li>o PRZR level - GREATER THAN (3)% [(4)% FOR ADVERSE CONTAINMENT]</li> </ul> </li> <li>b. Check power to isolation valves - AVAILABLE</li> <li>c. Close all SI accumulator isolation valves</li> </ul>	<ul style="list-style-type: none"> <li>a. Go to ECA-3.1, SGTR WITH LOSS OF REACTOR COOLANT SUBCOOLED RECOVERY DESIRED, Step 1.</li> <li>b. Restore power to isolation valves.</li> <li>c. Vent any unisolated accumulators.</li> </ul>
<b>3</b>	<p><b>Verify Adequate Shutdown Margin:</b></p> <ul style="list-style-type: none"> <li>a. Sample ruptured SG(s)</li> <li>b. Sample RCS</li> <li>c. Shutdown margin - ADEQUATE</li> </ul>	<ul style="list-style-type: none"> <li>c. Borate as necessary.</li> </ul>

STEP DESCRIPTION TABLE FOR ES-3.3    STEP 1 - CAUTION 2

CAUTION:    An offsite dose evaluation should be completed prior to using the guideline.

PURPOSE:    To alert the operator that this guideline will result in releases of radiological effluents. The consequences of this release should be evaluated before using this guideline

BASIS:

Subsequent steps require the release of contaminated steam from the ruptured steam generator. The potential radiological consequences of this action should be evaluated to minimize offsite exposures and demonstrate conformance to 10CFR20 limitations, if possible. This evaluation should consider pre-event primary coolant activity, meteorological conditions, and steam release path.

ACTIONS:

Alert appropriate plant personnel

INSTRUMENTATION:

N/A

CONTROL/EQUIPMENT:

N/A

KNOWLEDGE:

N/A

PLANT-SPECIFIC INFORMATION:

N/A

Attachment 3

Selected Pages from EP/1/A/5000/01 "Safety Injection".

## PREPARATION

## INFORMATION ONLY

- (2) STATION McGuire Nuclear
- (3) PROCEDURE TITLE Safety Injection
- (4) PREPARED BY Len Firebaugh DATE 2/24/88
- (5) REVIEWED BY Bill Pitea DATE 3-30-88
- Cross-Disciplinary Review By \_\_\_\_\_ N/R BP
- (6) TEMPORARY APPROVAL (If Necessary)
- By \_\_\_\_\_ (SRO) DATE \_\_\_\_\_
- By \_\_\_\_\_ DATE \_\_\_\_\_
- (7) APPROVED BY Bruce Travis DATE 4/13/88
- (8) MISCELLANEOUS
- Reviewed/Approved By EQS Bill Pitea DATE 3-30-88
- Reviewed/Approved By \_\_\_\_\_ DATE \_\_\_\_\_
- (9) COMMENTS (For procedure reissue indicate whether additional changes, other than previously approved changes, are included. Attach additional pages, if necessary.) ADDITIONAL CHANGES INCLUDED ☒ Yes ☐ No
- (10) COMPARED WITH CONTROL COPY \_\_\_\_\_ DATE \_\_\_\_\_

## COMPLETION

- (11) DATE(S) PERFORMED \_\_\_\_\_
- (12) PROCEDURE COMPLETION VERIFICATION
- ☐ Yes ☐ N/A Check lists and/or blanks properly initialed, signed, dated or filled in N/A or N R, as appropriate?
- ☐ Yes ☐ N/A Listed enclosures attached?
- ☐ Yes ☐ N/A Data sheets attached, completed, dated and signed?
- ☐ Yes ☐ N/A Charts, graphs, etc. attached and properly dated, identified and marked?
- ☐ Yes ☐ N/A Acceptance criteria met?
- VERIFIED BY \_\_\_\_\_ DATE \_\_\_\_\_
- 3) PROCEDURE COMPLETION APPROVED \_\_\_\_\_ DATE \_\_\_\_\_
- (14) REMARKS (Attach additional pages, if necessary.)

EP/1/A/5000/01

## SAFETY INJECTION

PAGE NO.

3 OF 12

## ACTION/EXPECTED RESPONSE

## RESPONSE NOT OBTAINED

5. Verify Load Sequencers actuated:

Manually initiate SI.

- Status light "E/S Load Seq Actuated Train A" - LIT
- Status light "E/S Load Seq Actuated Train B" - LIT.

D. Subsequent Actions

1. Initiate RP/0/A/5700/01, NOTIFICATION OF UNUSUAL EVENT.

CAUTION Monitor lights may not be aligned properly for other than initial entry into this procedure.

2. Check ESF Monitor Light Panel:

a. Groups 1, 2, 5, 7 - DARK

a. Manually align equipment as required.

IF "Safety Inject Train A/B" lit, THEN check OAC Tech Spec program 13 to determine misaligned valves

IF OAC is out of service, THEN complete Enclosure 2.

b. Groups 3 AND 6 - LIT

b. Manually open valves in group 3 AND/OR close valves in group 6 as required.

c. Ss and St components in group 4 - LIT.

c. Manually align equipment as required.  
IF "Cont Isol Phase A Train A/B" NOT lit, THEN manually initiate Phase A isolation.  
IF still NOT lit, THEN check OAC Tech Spec program 13 to determine misaligned valves.

Attachment 4

EP/1/A/5000/10 "Critical Safety Function Status Trees"

INFORMATION ONLY

Form 34731 (10-81)  
(Formerly SPD-1002-1)

DUKE POWER COMPANY  
PROCEDURE PREPARATION  
PROCESS RECORD

(1) ID No: EP/1/A/5000/10  
Change(s) 0 to  
0 Incorporated

- (2) STATION: McGuire
- (3) PROCEDURE TITLE: Critical Safety Function Status Trees
- (4) PREPARED BY: Len Firebaugh DATE: November 26, 1984
- (5) REVIEWED BY: AD Hill DATE: 11-30-84
- Cross-Disciplinary Review By: \_\_\_\_\_ N/R: ADH
- (6) TEMPORARY APPROVAL (IF NECESSARY):
- By: \_\_\_\_\_ (SRO) Date: \_\_\_\_\_
- By: \_\_\_\_\_ Date: \_\_\_\_\_
- (7) APPROVED BY: George E. Cox Date: 11/30/84
- (8) MISCELLANEOUS:
- Reviewed/Approved By: \_\_\_\_\_ Date: \_\_\_\_\_
- Reviewed/Approved By: \_\_\_\_\_ Date: \_\_\_\_\_

Form 34912 (8-82)

EP/1/A/5000/10  
REV 0

CRITICAL SAFETY FUNCTION STATUS TREES

PAGE NO.  
1 OF 5

A. Purpose

To provide guidance on how to monitor the plant safety status by use of logic diagrams that cover the six basic safety functions.

B. Entry Conditions

- o EP/1/A/5000/01, SAFETY INJECTION, step 21, when SI cannot be terminated and cause has not been determined
- o On any transition out of EP/1/A/5000/01, SAFETY INJECTION.

Form 34913 (8-82)

EP/1/A/5000/10  
REV 0

## CRITICAL SAFETY FUNCTION STATUS TREES

PAGE NO.  
2 OF 5

## ACTION/EXPECTED RESPONSE

## RESPONSE NOT OBTAINED

C. Immediate Actions

None

D. Subsequent Actions

## 1. Critical Safety Functions

- a. The six Critical Safety Functions (CSF) and associated procedures in order of priority are:

- 1) Subcriticality -  
EP/1/A/5000/11,  
SUBCRITICALITY
- 2) Core Cooling -  
EP/1/A/5000/12, CORE  
COOLING
- 3) Heat Sink -  
EP/1/A/5000/13, SECONDARY  
HEAT SINK
- 4) Integrity -  
EP/1/A/5000/14, NC SYSTEM  
INTEGRITY
- 5) Containment -  
EP/1/A/5000/15,  
CONTAINMENT
- 6) Inventory -  
EP/1/A/5000/16, NC  
SYSTEM INVENTORY.

- b. Each CSF has a corresponding status tree to enable the function to be monitored and to warn the operator if a safety parameter is being challenged. (Enclosures 1-6)

Form 34913 (8-82)

EP/1/A/5000/10  
REV 0

CRITICAL SAFETY FUNCTION STATUS TREES

PAGE NO.  
3 OF 5

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

2. The CSF status trees should be monitored as follows:
  - a. Normally the CSFs are continuously monitored and displayed in the Control Room by the OAC. Any change in state of the CSF will be alarmed on the computer and the alarm video displays will change color. Tech Spec Programs 21 through 26 should be used to determine which EP to implement.
  - b. IF the OAC is unavailable, THEN status trees should be monitored manually as follows:
    - 1) Monitor status trees (Enclosure 1-6) when a SI signal is present and log status on Enclosure 7.
    - 2) Tree scanning should be continuous if any condition is coded higher than yellow or there is a significant change in plant status.
    - 3) IF no condition is coded higher than yellow, THEN tree scanning intervals should not exceed 10 minutes.

NOTE Operator discretion is required in use of status trees. It is possible certain accidents might produce non-green status conditions which cannot be corrected.

3. The rules of priority for implementing EPs referenced by the status trees are as follows:
  - a. The importance of any non-green

Form 34913 (8-82)

EP/1/A/5000/10  
REV 0

CRITICAL SAFETY FUNCTION STATUS TREES

PAGE NO.  
4 OF 5

ACTION/EXPECTED RESPONSE

RESPONSE NOT OBTAINED

condition relative to any other condition of the same color is indicated by the order of the trees as given in step 1a.

- b. IF a red path is encountered, THEN initiate indicated procedure to defend or recover the challenged CSF:
  - 1) A red CSF requires immediate attention and departure from any conflicting Emergency Procedure in effect.
  - 2) IF during execution of a lower priority red path procedure, a red path of higher priority arises, THEN address the higher priority red path first.
- c. IF an orange path is encountered, THEN note associated procedure AND check remaining trees for a red path.  
IF NO red path exists  
THEN initiate appropriate orange path procedure:
  - 1) An orange CSF requires prompt attention and departure from any conflicting Emergency Procedure in effect.
  - 2) When highest priority orange path procedure is complete, scan trees for a red path before going to next orange path procedure.
  - 3) IF during the execution of an orange path procedure, a red path arises, THEN suspend orange AND implement red path procedure.
- d. IF a yellow path is encountered,

Form 34013 (B-82)

EP/1/A/5000/10  
REV 0

## CRITICAL SAFETY FUNCTION STATUS TREES

PAGE NO  
5 OF 5

## ACTION/EXPECTED RESPONSE

## RESPONSE NOT OBTAINED


THEN note nature of deficiency of  
CSF AND check remaining trees  
for a higher priority.  
WHEN practical initiate actions  
needed to fully restore indicated CSF.


END

EP/1/A/5000/10

CRITICAL SAFETY FUNCTION STATUS TREES  
ENCLOSURE 1 — SUBCRITICALITY

PAGE NO.  
1 OF 1





EP/1/A/5000/10	CRITICAL SAFETY FUNCTION STATUS TREES ENCLOSURE 2 — CORE COOLING	PAGE NO. 2 OF 2
----------------	---	--------------------

**RVLS D/P  
SETPOINTS FOR  
DEGRADED CORE COOLING**


Number of NC Pumps Running	Channel A with NC Pump A		Channel B with NC Pump C	
	Running	Not Running	Running	Not Running
4	80%	—	80%	—
3	60%	35%	60%	35%
2	45%	23%	45%	23%
1	35%	15%	35%	15%

EP/1/A/5000/10


CRITICAL SAFETY FUNCTION STATUS TREES  
ENCLOSURE 3 — HEAT SINK

PAGE NO.

1 OF 1



EP/1/A/5000/10	CRITICAL SAFETY FUNCTION STATUS TREES ENCLOSURE 4 — INTEGRITY	PAGE NO. 1 OF 2
----------------	--	--------------------




EP/1/A/5000/10

CRITICAL SAFETY FUNCTION STATUS TREES  
ENCLOSURE 4 — INTEGRITY

PAGE NO.  
2 OF 2


P/T ALARM CRITERIA FOR  
EP/1/A/5000/14.1 AND EP/1/A/5000/14.2  
(COOLDOWN GREATER THAN 100°F/HR)



EP/1/A/5000/10

CRITICAL SAFETY FUNCTION STATUS TREES  
ENCLOSURE 5 — CONTAINMENT


PAGE NO.  
1 OF 1



EP/1/A/5000/10

CRITICAL SAFETY FUNCTION STATUS TREES  
ENCLOSURE 6 -- INVENTORY

PAGE NO.  
1 OF 1



Form 34812 (8-82)

EP/1/A/5000/10 REV 0	CRITICAL SAFETY FUNCTION STATUS TREES Enclosure 7 Status Tree Log	PAGE NO. 1 OF 1
-------------------------	---	--------------------

R - Red  
O - Orange  
Y - Yellow  
G - Green

[illegible]

Performed by: \_\_\_\_\_ Date: \_\_\_\_\_

## **Attachment 5**

Selected Pages From OP/1/A/6100/02 "Controlling Procedure  
For Unit Shutdown" and OP/0/A/6100/06 "Reactivity Balance  
Calculation"

Duke Power Company  
PROCEDURE PROCESS RECORD(1) ID No. QP/1/A/6100/02  
Change(s) 0 to  
72 Incorporated

## PREPARATION

- (2) Station McGuire Nuclear Station
- (3) Procedure Title Controlling Procedure for Unit Shutdown
- (4) Prepared By Len Firebaugh Date 3/30/89
- (5) Reviewed By [Signature] Date 4/3/89  
Cross-Disciplinary Review By \_\_\_\_\_ N/R JD
- (6) Temporary Approval (if necessary)  
By \_\_\_\_\_ (SRO) Date \_\_\_\_\_  
By \_\_\_\_\_ Date \_\_\_\_\_
- (7) Approved By [Signature] Date 4/6/89
- (8) Miscellaneous  
Reviewed/Approved By Michael Weiner Date 4/4/89  
Reviewed/Approved By ETOS Date 4/3/89
- (9) Comments (For procedure reissue indicate whether additional changes, other than previously approved changes, are included. Attach additional pages, if necessary.)  
Additional Changes Included. ☒ Yes  
☐ No
- (10) Compared with Control Copy \_\_\_\_\_ Date \_\_\_\_\_
- (11) Requires change to FSAR not identified in 10CFR50.59 evaluation? ☐ Yes  
If "yes", attach detailed explanation. ☒ NO
- Completion**
- (12) Date(s) Performed \_\_\_\_\_
- (13) Procedure Completion Verification  
☐ Yes ☐ N/A Check lists and/or blanks properly initialed, signed, dated or filled in N/A or N/R, as appropriate?  
☐ Yes ☐ N/A Listed enclosures attached?  
☐ Yes ☐ N/A Data sheets attached, completed, dated and signed?  
☐ Yes ☐ N/A Charts, graphs, etc. attached and properly dated, identified and marked?  
☐ Yes ☐ N/A Procedure requirements met?  
Verified By \_\_\_\_\_ Date \_\_\_\_\_
- (14) Procedure Completion Approved \_\_\_\_\_ Date \_\_\_\_\_
- (15) Remarks (attach additional pages, if necessary)

2.15.1.1 Ensure the "Operation Selector" for all 6 detectors is in the "Off" position.

2.15.1.2 Open and tag the 120 VAC main power breaker on the panel.

2.16 Begin boration of the NC System per OP/1/A/6150/09 (Boron Concentration Control) to ensure that the SDM requirements of Data Book Table 6.5 can be maintained during cooldown.

2.17 Have IAE do the following:

2.17.1 When the neutron level decays to the normal shutdown counts, verify "High Flux At Shutdown" alarm bistable is set at one-half decade above normal shutdown source counts, and reinstate "High Flux At Shutdown" alarm.

2.18 After the "High Flux At Shutdown" alarm has been reinstated, insert the Shutdown Banks per OP/1/A/6150/08 (Rod Control).

2.19 Remove both MG sets from service per OP/1/A/6150/08 (Rod Control).

2.20 As soon as access to lower containment is possible, close INC-24 (Reactor Vessel Head Gasket Leakoff Drain Manual Block) to prevent NCDT H<sub>2</sub> from escaping to containment during cooldown.

2.21 Place Acoustic Emission Leak Monitor in "Manual" to prevent spurious alarms during shutdown.

2.22 If required, perform PY/1/A/4250/01A (Main Steam Isolation Valve Movement Test)

CAUTION Ensure VCT Makeup blended flow boron concentration is adjusted to a value greater than required SDM boron concentration whenever VCT makeup controls are set for normal makeup.

# Duke Power Company Procedure Major Change PROCESS RECORD

 (1) ID No. CP/O/A/6100/06  
 Change No. 35  
 Permanent/Restricted To \_\_\_\_\_

 (2) Station M'GUIRE  
 (3) Procedure Title REACTIVITY BALANCE CALCULATION

 (4) Section(s) of Procedure Affected: SECTION 4.2, ENCLOSURE 5.5, ENCLOSURE 5.7  
 (5) Description of Change: (Attach additional pages, if necessary).

- A) AFTER THE FOURTH SENTENCE IN THE NOTE AT THE BEGINNING OF SECTION 4.2, ADD
- "It is permissible to calculate Shutdown Margin for an intermediate temperature per Section 4.2.1. However, before cooling down below this temperature, Shutdown Margin shall be re-calculated for a new intermediate temperature per Section 4.2.1 or for cooldown below 200°F per Section 4.2.3. In either case, Shutdown Margin must be calculated per Section 4.2.3 prior to cooldown below 200°F."
- B) ON ENCLOSURE 5.5, CHANGE "NOTE" to "NOTES" and number existing note as 1).
- C) ADD TO NOTES AT TOP OF ENCLOSURE 5.5:
- 2) This enclosure is to be used to calculate Shutdown Margin for temperatures between 200°F and 557°F.
  - 3) Prior to cooling down below 200°F, Shutdown Margin must be calculated per Enclosure 5.7.
- D) ADD TO TOP OF ENCLOSURE 5.7:
- Note: This enclosure is to be used to calculate Shutdown Margin prior to cooling down below 200°F.

(6) Reason for Change

To clarify the use of Enclosures 5.5 and 5.7 for calculating Shutdown Margin

 (7) Prepared By M. R. Little Date 4/4/89

(8) 10CFR50.59 Evaluation

Attach completed 10CFR50.59 evaluation form.

 (9) Requires change to FSAR not identified in 10CFR50.59 evaluation? ☐ Yes  
 If "yes", attach detailed explanation. ☒ No

(10) Reviewed By \_\_\_\_\_ Date \_\_\_\_\_

 Cross-Disciplinary Review By O - R 4/4/89 N/R OPS

(11) Temporary Approval (if necessary)

By \_\_\_\_\_ (SRO) Date \_\_\_\_\_

By \_\_\_\_\_ Date \_\_\_\_\_

 (12) Approved By [Signature] Date 4/5/89

(13) Miscellaneous

Reviewed/Approved By \_\_\_\_\_ Date \_\_\_\_\_

Reviewed/Approved By \_\_\_\_\_ Date \_\_\_\_\_

DUKE POWER COMPANY  
PROCEDURE MAJOR CHANGE  
PROCESS RECORD CONTINUATION FORM

ID No: OP/O/A/6100/06  
Change No: 35  
Page 2 of 2

5) CONTINUED

E) In ENCLOSURE 5.5, RENUMBER STEP 12. as 12.a. AND ADD  
" 12.b. If NC Boreon concentration (E. above) is less than Adjusted  
Shutdown Boreon Concentration (10. above) and Temperature (3. above)  
is between 550°F and 557°F, then Shutdown Margin may  
be recalculated per Enclosure 5.6. "

F) In ENCLOSURE 5.5, ADD AFTER STEP 11,  
" NOTE: Perform either 12.a or 12.b "

Duke Power Company  
PROCEDURE PROCESS RECORD

CONTROL COPY

(1) ID No. OP/O/A/6100/06  
Change(s) 0 to  
33 Incorporated

## PREPARATION

(2) Station McGuire(3) Procedure Title Reactivity Balance Calculation(4) Prepared By M. As. Kline Date 10/20/88(5) Reviewed By L. J. Kline Date 10/24/88Cross-Disciplinary Review By [Signature] N/R 12/9/88

(6) Temporary Approval (if necessary)

By \_\_\_\_\_ (SRO) Date \_\_\_\_\_

By \_\_\_\_\_ Date \_\_\_\_\_

(7) Approved By Bruce Hamilton Date 11/9/88

(8) Miscellaneous

Reviewed/Approved By M. S. Kitting Date 12/9/88

Reviewed/Approved By \_\_\_\_\_ Date \_\_\_\_\_

(9) Comments (For procedure reissue indicate whether additional changes, other than previously approved changes, are included. Attach additional pages, if necessary.)

Additional Changes Included. ☒ Yes☐ No

(10) Compared with Control Copy \_\_\_\_\_ Date \_\_\_\_\_

(11) Requires change to FSAR not identified in 10CFR50.59 evaluation? ☐ Yes

If "yes", attach detailed explanation.

☒ No

## Completion

(12) Date(s) Performed \_\_\_\_\_

(13) Procedure Completion Verification

☐ Yes ☐ N/A Check lists and/or blanks properly initialed, signed, dated or filled in N/A or N/R, as appropriate?☐ Yes ☐ N/A Listed enclosures attached?☐ Yes ☐ N/A Data sheets attached, completed, dated and signed?☐ Yes ☐ N/A Charts, graphs, etc. attached and properly dated, identified and marked?☐ Yes ☐ N/A Procedure requirements met?

Verified By \_\_\_\_\_ Date \_\_\_\_\_

(14) Procedure Completion Approved \_\_\_\_\_ Date \_\_\_\_\_

(15) Remarks (attach additional pages, if necessary)

- 4.1.2.1 Determine 557°F rod worth of control rods at their present position from Data Book Curve 6.3.3.
- 4.1.2.8 Obtain maximum reactivity effect of flux redistribution at zero power at any time in core life from note at bottom of Data Book Table 6.3.2.
- 4.1.2.9 Sum values obtained in Steps 4.1.2.5, 4.1.2.6, 4.1.2.7, and 4.1.2.8.
- 4.1.2.10 Determine required shutdown margin by adding value of 4.1.2.4 to 1300 pcm. Value in Step 4.1.2.9 shall be more positive than this value per MNS Technical Specification 3.1.1.1. If value in Step 4.1.2.9 is not more positive than this value, borate per appropriate Station procedure.
- 4.1.2.11 Forward a copy of all completed Enclosure(s) 5.4 to Reactor Unit by next working day.

## 4.2 Unit Shutdown

### CAUTION

Perform all shutdown margin calculations and adjust boron concentration prior to cooling down below 550°F.

NOTE: For temperatures between 200°F and 557°F, shutdown margin calculations should be performed per Section 4.2.1. If temperature will remain between 500°F and 557°F and calculations of Section 4.2.1 show inadequate shutdown margin exists, then shutdown margin may be calculated with credit for xenon included. In this case, perform Section 4.2.2. If cooldown below 200°F is expected, shutdown margin should be calculated per Section 4.2.3. If shutdown banks are to be withdrawn prior to adjusting NC boron concentration per ECR, criticality may be possible even though adequate shutdown margin exists. Ensure criticality will not occur by completing Section 4.2.4.

It is permissible to calculate 4.2.1 Shutdown Margin for an intermediate temperature per Section 4.2.1. However, before cooling down below this temperature, shutdown margin shall be re-calculated for a new intermediate temperature per Section 4.2.1 or for cooldown below 200°F per Section 4.2.3. In either case, Shutdown Margin must be calculated per Section 4.2.3 prior to cooldown below 200°F.

CH# 35  
RTK  
4/10/89

Unit shutdown, Tave > 200°F, No Xenon Credit included

Complete Enclosure 5.5 as follows:

- 4.2.1.1 Record unit and cycle.
- 4.2.1.2 Record cycle burnup from OAC points P1457 and P1458.

OP/0/A/6100/06  
Page \_\_\_\_ of \_\_\_\_ENCLOSURE 5.5  
SHUTDOWN MARGIN - UNIT SHUTDOWN,  
TAVE >200°F, NO XENON CREDIT INCLUDED

NOTES: 1) Perform prior to cooling down below 550°F.  
2) This enclosure is to be used to calculate Shutdown Margin for temperatures between 200°F and 557°F.  
3) Prior to cooling down below 200°F, Shutdown Margin must be calculated per Enclosure 5.7.

CH 235  
MTX  
4/6/89

1. Unit \_\_\_\_\_ Cycle \_\_\_\_\_
2. Cycle Burnup \_\_\_\_\_ EFPD \_\_\_\_\_ MWD/MTU
3. Lowest Temperature Expected \_\_\_\_\_ °F
4. 1.3% Shutdown Margin Boron  
(from tabular data Data Book Curve 6.5 for burnup 2. above  
and temperature 3. above). \_\_\_\_\_ ppm

5. NC Boron Concentration \_\_\_\_\_ ppm

NOTE: If one or more rods are known to be inoperable, perform Steps 6. through 9. Otherwise mark Steps 6., 7. and 8. as N/A, mark Step 9. as 0 ppm and proceed to Step 10.

6. Number of known inoperable rods \_\_\_\_\_ inoperable rods
7. Stuck Rod Worth (from Data Book Table 6.3.2 line B  
interpolated to present burnup 2. above) \_\_\_\_\_ pcm
8. Differential Boron Worth (from Data Book Curve 6.2  
for present burnup 2. above) \_\_\_\_\_ pcm/ppm
9. Stuck Rod Penalty  
(  $\frac{6. \text{ above} \times 7. \text{ above}}{8. \text{ above}}$  ) \_\_\_\_\_ ppm
10. Adjusted Shutdown Boron Concentration  
(4. above + 9. above) \_\_\_\_\_ ppm

11. If NC Boron Concentration (5. above) is greater than or equal to Adjusted Shutdown Boron Concentration (10. above), adequate shutdown margin exists at temperature 3. above.

CH 235  
MTX  
4/6/89

NOTE: Perform either 12.a. or 12.b.

- 12.a. If NC Boron concentration (5. above) is less than Adjusted Shutdown Boron Concentration (10. above) and it is desired to decrease temperature to that of 3. above, then NC Boron Concentration must be adjusted equal to or greater than 10. above.
- 12.b. If NC Boron concentration (5. above) is less than adjusted Shutdown Boron Concentration (10. above) and Temperature (3. above) is between 500°F and 557°F, then Shutdown Margin may be recalculated per Enclosure 5.6.

Calculated By \_\_\_\_\_ Date/Time \_\_\_\_\_ / \_\_\_\_\_

Checked By \_\_\_\_\_ Date/Time \_\_\_\_\_ / \_\_\_\_\_

CH 235  
MTX  
4/6/89

13. Forward a copy of all completed Enclosure(s) 5.5 to Reactor Unit by next working day.

ENCLOSURE 5.7  
SHUTDOWN MARGIN - UNIT SHUTDOWN,  
TAVE < 200°F, NO XENON  
CREDIT INCLUDED

OP/0/A/6100/06  
Page 1 of 1

NOTE: This enclosure is to be used to calculate Shutdown Margin prior to cooling down below 200°F.

CH-35  
NOTE  
4/6/89

1. Unit \_\_\_\_\_ Cycle \_\_\_\_\_
2. Cycle Burnup \_\_\_\_\_ EFPD \_\_\_\_\_ MWD/MTU
3. NC Boron Concentration \_\_\_\_\_ ppm
4. Shutdown Boron Concentration \_\_\_\_\_ ppm  
(from tabular data of Data Book Curve 6.5, 1.0% shutdown at 68°F or 1.3% shutdown at 200°F, whichever is greater)


NOTE: If one or more rods are known to be inoperable, perform Steps 5. through 8. Otherwise, mark Steps 5., 6. and 7. as N/A, mark Step 8. as 0 ppm and proceed to Step 9.

5. Number of known inoperable rods \_\_\_\_\_ inoperable rods
6. Stuck Rod Worth (from Data Book Table 6.3.2 line B interpolated to present burnup 2. above) - \_\_\_\_\_ pcm
7. Differential Boron Worth (from Data Book Curve 6.2 for present burnup 2. above) - \_\_\_\_\_ pcm/ppm
8. Stuck Rod Penalty  
(  $\frac{5. \text{ above} \times 6. \text{ above}}{7. \text{ above}}$  ) + \_\_\_\_\_ ppm
9. Adjusted Shutdown Boron Concentration \_\_\_\_\_ ppm  
(4. above + 8. above)
10. If NC Boron Concentration (3. above) is greater than or equal to Adjusted Shutdown Boron Concentration (9. above), adequate shutdown margin exists for cooldown.
11. If NC Boron concentration (3. above) is less than Adjusted Shutdown Boron Concentration (9. above) and it is desired to cooldown below 200°F, then NC Boron Concentration must be adjusted equal to or greater than 9. above.

Calculated By \_\_\_\_\_ Date/Time: \_\_\_\_\_/\_\_\_\_\_/\_\_\_\_\_  
Checked By \_\_\_\_\_ Date/Time: \_\_\_\_\_/\_\_\_\_\_/\_\_\_\_\_

12. Forward a copy of all completed Enclosure(s) 5.7 to Reactor Unit by next working day.

DOWN BORON CONCENTRATION (ppm)



OP/1/A/6100/22  
ENCLOSURE 4.3  
CURVE 8.8  
SHUTDOWN BORON CONCENTRATION  
ARI, NO XENON  
UNIT 1 CYCLE 8

NOTE: 100 FPM CONSERVATIVE  
NOTE: INCLUDES 1 STICK PWR

24#92  
LK  
11/25/88

OP/1/A/6100/22  
Enclosure 4.3  
CURVE 6.5  
SHUTDOWN BORON CONCENTRATION  
ARI. NO XENON  
MOORE 1 CYCLE 6

1.3% Shutdown Margin

C4#94  
C6  
9/12/8

BURNUP  
(EFPD)

200 225 250 275 300 325 350 375 400 425 450 475 500 525 550 557

CORE AVERAGE TEMP. (° F)

0	1523	1512	1501	1490	1479	1468	1457	1446	1435	1424	1413	1401	1389	1376	1353	1359
20	1471	1459	1447	1436	1424	1412	1400	1388	1376	1363	1350	1337	1323	1308	1293	1299
40	1421	1409	1396	1384	1372	1359	1346	1333	1319	1305	1291	1276	1260	1244	1227	1222
60	1373	1360	1347	1334	1321	1308	1294	1280	1265	1250	1234	1217	1200	1182	1163	1157
80	1327	1314	1300	1287	1273	1258	1244	1228	1213	1196	1179	1161	1142	1122	1102	1096
100	1282	1268	1255	1240	1226	1211	1195	1179	1162	1144	1126	1106	1086	1065	1043	1036
120	1239	1225	1210	1196	1180	1164	1148	1131	1113	1094	1075	1054	1032	1010	986	979
140	1197	1182	1167	1152	1136	1119	1102	1084	1065	1046	1025	1003	980	956	930	923
160	1156	1141	1125	1109	1093	1075	1057	1039	1019	998	976	953	929	904	877	869
180	1116	1100	1084	1068	1050	1032	1013	994	973	952	929	905	879	853	824	816
200	1076	1060	1043	1026	1008	990	970	950	928	906	882	857	830	802	772	763
220	1037	1020	1003	985	967	947	927	906	883	860	836	810	782	752	721	711
240	997	980	963	944	925	905	884	862	839	815	790	763	734	703	669	660
260	958	941	922	903	884	863	841	818	794	770	743	715	685	653	618	608
280	916	900	882	862	842	820	798	774	750	724	697	668	637	603	566	556
300	878	859	840	820	799	777	754	730	704	678	650	620	587	552	514	503
320	837	818	798	778	756	734	710	685	658	631	602	571	537	501	461	449
340	794	775	755	734	712	689	664	639	611	583	553	521	486	448	407	394
360	751	732	711	690	667	643	618	591	563	534	503	469	433	394	351	338
372	724	705	684	662	639	615	589	562	533	504	472	438	400	360	316	303

\* NO XE, BQ SM

NOTE: MOST REACTIVE ROD STUCK OFF

C4#92  
9/12/8

OP/1/A/6100/22  
ENCLOSURE 4.3  
CURVE 6.5  
SHUTDOWN BORON CONCENTRATION  
ARI, NO XENON  
MOORE 1 CYCLE 6

10% Shutdown Margin

Ck #94  
LC  
9/11/87

CORE AVERAGE TEMP. (° F)

BURNUP (EFPD)	68	70	80	90	100	110	120	130	140	150	160	170	180	190	200
0	1553	1552	1549	1545	1541	1537	1533	1529	1525	1520	1516	1512	1507	1503	1498
20	1503	1502	1498	1494	1490	1486	1482	1478	1474	1469	1465	1460	1456	1451	1446
40	1455	1454	1450	1446	1442	1438	1434	1429	1425	1420	1416	1411	1406	1401	1396
60	1409	1408	1404	1400	1395	1391	1387	1382	1378	1373	1369	1364	1359	1354	1349
80	1365	1364	1359	1355	1351	1346	1342	1337	1333	1328	1323	1318	1313	1308	1303
100	1322	1321	1316	1312	1307	1303	1298	1294	1289	1284	1279	1274	1269	1264	1258
120	1280	1279	1275	1270	1266	1261	1256	1252	1247	1242	1237	1231	1226	1221	1215
140	1239	1238	1234	1229	1225	1220	1215	1211	1206	1200	1195	1190	1184	1179	1173
160	1199	1198	1194	1190	1185	1180	1175	1170	1165	1160	1155	1149	1143	1138	1132
180	1160	1159	1155	1151	1146	1141	1136	1131	1126	1120	1115	1109	1103	1098	1092
200	1122	1121	1117	1112	1108	1103	1098	1092	1087	1081	1075	1070	1064	1058	1052
220	1083	1083	1079	1074	1069	1064	1059	1054	1048	1042	1036	1030	1024	1019	1013
240	1045	1045	1041	1036	1031	1026	1021	1015	1009	1004	997	991	985	979	973
260	1007	1007	1003	998	993	988	983	977	971	965	959	952	946	940	934
280	969	968	964	960	955	950	944	938	932	926	920	913	907	901	894
300	930	930	925	921	916	911	905	899	893	886	880	874	867	861	854
320	891	890	886	881	876	871	865	859	853	846	840	833	827	820	814
340	851	850	846	841	836	830	824	818	812	806	799	792	785	779	772
360	810	809	804	799	794	788	783	776	770	764	757	750	743	736	729
372	785	784	779	774	768	763	757	751	744	739	731	724	717	710	703

\* NO XE, EQ SM

NOTE: MOST REACTIVE ROD STUCK OUT

NOTE: 100 PPM CONSERVATIVE

Ck #92  
LC  
12/23/87

**Attachment 6**

Procedural Commitments Made in the April 13, 1989  
Washington, D.C. Duke Power Presentation to the NRC Staff

## EMERGENCY PROCEDURES

### - ERG DEVIATION DOCUMENT

- Projected Schedule for Completion

Deviation document scheduled completion is June 30, 1989.

It was Duke's opinion that a deviation document did exist and that we shared Catawba's documentation. This was based on the fact that both sites share a common design and similar safety analysis.

- Safety Injection Initiation

McGuire has changed the threshold for manual initiation of safety injection. The previous threshold was pressurizer level less than five percent after a second charging pump was started and cold leg injection valves were opened; the new threshold is pressurizer level decreasing after a second charging is started and injecting through the normal charging flow path.

- Other Procedure Enhancements

- I. Procedure changes already completed

- A. OP/1,2/A/6100/02, "Controlling Procedure for Unit Shutdown"

- 1. Revised procedure step to more clearly allow cooldown initiation prior to meeting the Shutdown Margin for Cold Shutdown as long as Shutdown Margin is maintained throughout the cooldown.

- B. OP/0/A/6100/06, "Reactivity Balance Calculation"

- 1. Revised procedure step to more clearly allow cooldown initiation prior to meeting the Shutdown Margin for Cold Shutdown as long as Shutdown Margin is maintained throughout the cooldown.

- II. Procedure changes to be completed by May 1, 1989

- A. AP/1,2/A/5500/10, "NC System Leakage Within the Capacity of Both NV Pumps - Case 1 Steady Generator Tube Leakage"

- 1. Revised procedure to require operator to initiate manual Safety Injection and go to EP/1,2/A/5000/01 instead of manually opening NI-9A and NI-10B (NC Cold Leg Injection from NV) when maximum charging is not maintaining pressurizer level.

2. Revised subsequent actions to more clearly resemble EP/1,2/A/5000/04, "Steam Generator Tube Rupture".
  3. Revised the last step to direct the operator to cooldown the ruptured Steam Generator using EP/1,2/A/5000/4.1, "SGTR Cooldown Using Steam Dump", EP/1,2/A/5000/4.2, "SGTR Cooldown Using Backfill" or EP/1,2/A/5000/4.3, "SGTR Cooldown Using Blowdown".
  4. Added new step to begin unit load reduction.
  5. Added new step and enclosure to minimize secondary contamination.
  6. Added Caution to allow operator to exceed 50°F/hr cooldown rate.
  7. Added step to isolate blowdown on the ruptured steam generator.
- B. AP/1,2/A/5500/10, "NC System Leakage Within the Capacity of Both NV Pumps - Case 2 Reactor Coolant System Leakage"
1. Revised procedure to require operator to initiate manual Safety Injection and go to EP/1,2/A/5000/01, "Safety Injection" instead of manually opening NI-9A and NI-10B (NC Cold Leg Injection from NV) when maximum charging is not maintaining pressurizer level.
  2. Revised subsequent actions to more closely resemble EP/1,2/A/5000/2.2, "Post LOCA Cooldown and Depressurization"

III. Procedure changes to be implemented with the Emergency and Abnormal Procedure total reissue currently scheduled for June 30, 1989 (waiting on simulator for validation)

- A. EP/1,2/A/5000/04, "Steam Generator Tube Rupture"
1. All Reactor Coolant Pumps are left operating for cooldown.
  2. New enclosure for minimizing secondary contamination.
- B. EP/1,2/A/5000/4.2, "SGTR Cooldown Using Backfill"
1. Revised procedure step to more clearly allow cooldown initiated as long as Shutdown Margin is maintained throughout the cooldown.

2. Revised procedure to stop the reactor coolant pump on the ruptured Steam Generator after placing residual heat removal in service. This helps maintain ruptured Steam Generator pressure elevated and hence Reactor Coolant System pressure to allow Reactor Coolant Pumps on the intact steam generators to be operated until the Reactor Coolant System Temperature is less 160°F.
- C. EP/1,2/A/5000/4.3, "SGTR Cooldown Using Blowdown"
1. Revising entire procedure to utilize normal Blowdown instead of the Blowdown Recycle System.
- D. AP/1,2/A/5500/01, "Reactor Trip"
1. Deleting procedure and incorporating Reactor Trip in EP/1,2/A/5000/01, "Safety Injection".

Attachment 7

Superceded Copy of AP/1/A/5000/10 and Selected Pages  
From the Superceded OP/1/A/6100/02

DUKE POWER COMPANY  
PROCEDURE PROCESS RECORDChange(s) 0  
0 IncorporatedPREPARATION**INFORMATION ONLY**(2) STATION McGuire Nuclear(3) PROCEDURE TITLE NC System Leakage Within Capacity of Both NV Pumps(4) PREPARED BY Len Firebaugh DATE 1/29/88(5) REVIEWED BY D-R DATE 3-3-88Cross-Disciplinary Review By N/R OW

(6) TEMPORARY APPROVAL (If Necessary)

By \_\_\_\_\_ (SRO) DATE \_\_\_\_\_

By \_\_\_\_\_ DATE \_\_\_\_\_

(7) APPROVED BY Bruce Travis DATE 3/4/88

(8) MISCELLANEOUS

Reviewed/Approved By \_\_\_\_\_ DATE \_\_\_\_\_

Reviewed/Approved By RH ETL DATE 3-4-88(9) COMMENTS (For procedure reissue indicate whether additional changes, other than previously approved changes, are included.  
Attach additional pages, if necessary.) ADDITIONAL CHANGES INCLUDED. ☒ Yes ☐ No

(10) COMPARED WITH CONTROL COPY \_\_\_\_\_ DATE \_\_\_\_\_

COMPLETION

(11) DATE(S) PERFORMED \_\_\_\_\_

(12) PROCEDURE COMPLETION VERIFICATION

- ☐ Yes ☐ N/A Check lists and/or blanks properly initialed, signed, dated or filled in N/A or N/R, as appropriate?
- ☐ Yes ☐ N/A Listed enclosures attached?
- ☐ Yes ☐ N/A Data sheets attached, completed, dated and signed?
- ☐ Yes ☐ N/A Charts, graphs, etc. attached and properly dated, identified and marked?
- ☐ Yes ☐ N/A Acceptance criteria met?

VERIFIED BY \_\_\_\_\_ DATE \_\_\_\_\_

(13) PROCEDURE COMPLETION APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

(14) REMARKS (Attach additional pages, if necessary.)

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN THE CAPACITY OF  
BOTH NV PUMPSPAGE NO.  
i

## TABLE OF CONTENTS

	<u>Page</u>
A. <u>Purpose</u>	1
Case I Steam Generator Tube Leakage	2
Case II NC System Leakage	7
Case III Letdown Or Charging Line Break	11
Case IV Leakage Into KC System	15

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN THE CAPACITY OF  
BOTH NV PUMPSPAGE NO.  
1 OF 17A. Purpose

This procedure covers the required operator actions for NC leakage greater than Tech Specs but where the Charging Pumps are capable of maintaining PZR water level and the PZR heaters are capable of maintaining system pressure under the following conditions:

- Case I Steam Generator Tube Leakage
- Case II NC System Leakage
- Case III Letdown Or Charging Line Leakage
- Case IV Leakage Into KC System.

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case I  
Steam Generator Tube Leakage

PAGE NO.  
2 OF 17

## ACTION/EXPECTED RESPONSE

## RESPONSE NOT OBTAINED

B. Symptoms

- "1EMF-33, Cond AE Exh Hi Gas Rad" alarm
- "1EMF-34, SG Sample Hi Rad" alarm
- "1EMF-24 25 26 27 Steam Line Hi Rad" alarm
- Increase in frequency of auto makeup to VCT.

C. Immediate Actions

1. Check Pzr Level - AT OR INCREASING TO PROGRAMMED LEVEL.

IF level decreasing, THEN perform the following to maintain level:

- a. Ensure #1 PD Pump speed increasing OR 1NV-238 (Charging Line Flow Control) opening.
- b. Start additional NV Pumps
- c. Reduce letdown to 45 GPM orifice.

IF level decreases below 5%, THEN manually initiate SI AND go to EP/1/A/5000/01, SAFETY INJECTION.

2. Check Pzr Press - AT OR INCREASING TO 2235 PSIG.

IF less than 2210 PSIG, THEN ensure backup heaters on.  
IF pressure approaches 1945 PSIG, THEN trip Reactor  
AND refer to AP/1/A/5500/01, REACTOR TRIP.

D. Subsequent Actions

CAUTION If Pzr level cannot be maintained, (less than 5% and decreasing) then SI should be manually initiated.

1. Announce occurrence on paging system.

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case I  
Steam Generator Tube Leakage

PAGE NO.  
2 OF 17

## ACTION/EXPECTED RESPONSE

## RESPONSE NOT OBTAINED

2. Check Pzr Level - STABLE OR INCREASING.

IF level decreasing with maximum charging flow, THEN:

- a. Manually trip Turbine AND Reactor
- b. Open 1NI-9A AND 10B (NC Cold Leg Inj From NV).
- c. Swap charging pump suction to FWST:
  - 1) Open 1NV-221A AND 222B (NV Pumps Suct From FWST)
  - 2) Close 1NV-141A AND 142B (VCT Outlet Isol).

3. Check if S/G blowdown isolation required:

- a. "1EMF-34 S/G Sample Hi Rad" alarm - LIT
- b. Verify S/G BB Auto Isol valves - CLOSED:
  - S/G A, 1BB-119
  - S/G B, 1BB-120
  - S/G C, 1BB-121
  - S/G D, 1BB-122.

- a. Go to step 4.
- b. Manually close valves.

4. Refer to RP/O/A/5700/01, NOTIFICATION OF UNUSUAL EVENT.

5. Notify HP to determine activity released from air ejectors.

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case I  
Steam Generator Tube Leakage

PAGE NO.

4 OF 17

## ACTION/EXPECTED RESPONSE

## RESPONSE NOT OBTAINED

## 6. Identify affected S/G:

- Decrease in CF flow
- Increase in S/G level
- Increase in S/G pressure
- Per OP/1/A/6250/08, STEAM GENERATOR BLOWDOWN.

7. Perform the following steps in conjunction with shutdown and cooldown of unit per OP/1/A/6100/02, CONTROLLING PROCEDURE FOR UNIT SHUTDOWN:

a. IF Unit 2 available to supply AS header, THEN:

## 1) Ensure the following valves - OPEN:

- 1AS-74 (Unit 1 Aux Stm Hdr Isol)
- 2AS-74 (Unit 2 Aux Stm Hdr Isol)
- 1AS-253 (Unit 1 And 2 Aux Stm Hdr Crosstie)

2) Close 1AS-9 (C-Htr Bleed to AS) AND 1AS-12 (SM To AS).

## 3) Open 1HM-95 (AS To "A" and "B" FWPT)

## 4) Locally verify proper operation of 2AS-11 (Unit 2 Main Steam To Aux Steam Hdr Control).

## a. Supply AS header with Aux Electric Boiler:

## 1) Place boilers in operation per OP/1/B/6250/07B, AUX ELECTRIC BOILER

## 2) Ensure open:

- 1AS-74 (Unit 1 Aux Stm Hdr Isol)
- 2AS-74 (Unit 2 Aux Stm Hdr Isol)
- 1AS-253 (Unit 1 And 2 Aux Stm Hdr Crosstie)

## 3) Open 1AS-120 (Aux Elec Blr A And B To AS Isol)

4) Close 1AS-9 (C Htr Bleed to AS) AND slowly throttle closed 1AS-12 (SM To AS)

## 5) Open 1HM-95 (AS To "A" and "B" FWPT).

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case I  
Steam Generator Tube LeakagePAGE NO.  
5 OF 17

## ACTION/EXPECTED RESPONSE

## RESPONSE NOT OBTAINED

b. After unit is off line,  
isolate affected S/G:

- S/G 1A
  - 1) Close SM Isol AND Bypass Valves, 1SM-7AB, 12
  - 2) Control feed flow to maintain S/G NR Lvl greater than 38%.
- S/G 1B
  - 1) Close SM Isol AND Bypass Valves, 1SM-5AB, 11
  - 2) Control feed flow to maintain S/G NR Lvl greater than 38%.
  - 3) Locally close 1SA-2 (SM To #1 TD CA Pump)
- S/G 1C
  - 1) Close SM Isol AND Bypass Valves, 1SM-3AB, 10
  - 2) Control feed flow to maintain S/G NR Lvl greater than 38%.
  - 3) Locally close 1SA-1 (SM To #1 TD CA Pump)
- S/G 1D
  - 1) Close SM Isol AND Bypass Valves, 1SM-1AB, 9
  - 2) Control feed flow to maintain S/G NR Lvl greater than 38%.

c. Cooldown NC System to less than 507°F.

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case I  
Steam Generator Tube LeakagePAGE NO.  
6 OF 17

## ACTION/EXPECTED RESPONSE

- d. Reduce NC System pressure to faulted S/G pressure while blocking SI per shutdown procedure.
- e. Continue plant cooldown per shutdown procedure.
- f. Depressurize NC System and ruptured S/G simultaneously:

- 1) Dump steam to condenser by slowly opening SM Isol Bypass valve on ruptured S/G.

OR

Initiate blowdown to recycle system per OP/1/A/6250/08 S/G BLOWDOWN.

- 2) Reduce NC pressure to maintain equal to ruptured S/G pressure.

END

## RESPONSE NOT OBTAINED

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case II  
NC System Leakage

PAGE NO.

7 OF 17

## ACTION/EXPECTED RESPONSE

## RESPONSE NOT OBTAINED

B. Symptoms

- Increase in frequency of auto makeup to VCT
- Increased leakrate results from PT/1/A/4150/01B, REACTOR COOLANT LEAKAGE CALCULATIONS
- Cont Flr/Eqp Sump Level increase
- "1EMF-38 Containment HI Part Rad" alarm
- "1EMF-39 Containment HI Gas Rad" alarm
- "1EMF-40 Containment HI Iod Rad" alarm
- "Pzr PORV Disch Hi Temp" alarm
- "Pzr Safety Discharge Hi Temp" alarm
- PRT temperature increase
- PRT level increase
- Containment temperature increase
- Containment humidity increase
- "Rx Vessel Flange Leak Off Hi Temp" alarm

C. Immediate Actions

1. Check Pzr Level - AT OR INCREASING TO PROGRAMMED LEVEL.

IF level decreasing, THEN perform the following to maintain level:

- a. Ensure #1 PD Pump speed increasing OR INV-238 (Charging Line Flow Control) opening.
- b. Start additional NV Pumps
- c. Reduce letdown to 45 GPM orifice.

IF level decreases below 5%, THEN manually initiate SI AND go to EP/1/A/5000/01, SAFETY INJECTION.

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case II  
NC System Leakage

PAGE NO.

8 OF 17

## ACTION/EXPECTED RESPONSE

## RESPONSE NOT OBTAINED

2. Check Pzr Press - AT OR INCREASING TO 2235 PSIG.

IF less than 2210 PSIG, THEN ensure backup heaters on.  
IF pressure approaches 1945 PSIG, THEN trip Reactor  
AND refer to AP/1/A/5500/01, REACTOR TRIP.

D. Subsequent Actions

CAUTION If Pzr level cannot be maintained, (less than 5% and decreasing) then Safety Injection should be manually initiated.

1. Announce occurrence on paging system.

2. Check Pzr Level - STABLE OR INCREASING.

IF level decreasing with maximum charging flow, THEN:

- a. Manually trip Turbine AND Reactor
- b. Open INI-9A AND 10B (NC Cold Leg Inj From NV).
- c. Swap charging pump suction to FWST:
  - 1) Open INV-221A AND 222B (NV Pumps Suct From FWST)
  - 2) Close INV-141A AND 142B (VCT Outlet Isol).

3. Check if Containment ventilation isolation required:

- a. EMF 38, 39 OR 40 - IN ALARM
- b. Stop VP Fans.
- c. Stop any VQ release in progress.

- a. Go to step 4.

4. Refer to RP/0/A/5700/01, NOTIFICATION OF UNUSUAL EVENT.

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case II  
NC System Leakage

PAGE NO.

9 OF 17

## ACTION/EXPECTED RESPONSE

## RESPONSE NOT OBTAINED

5. Attempt to identify and isolate leak:

a. Check "Pzr PORV Disch Hi Temp"  
- IN ALARM

1) Verify Pzr PORV's - CLOSED

2) Monitor PORV Relief Valve  
Temp and cycle Pzr PORV Isol  
AND Relief Hdr Sample valves  
to determine leak path:

- 1NC-33A AND 270
- 1NC-35B AND 269
- 1NC-31B AND 271.

b. Check Cold Leg Accumulator  
Level - INCREASING

1) Close CL Accum Disch Isol  
Valve

OR

Drain accumulator per  
OP/1/A/6200/09, ACCUMULATOR  
OPERATION.

c. Check Pzr Relief Tank Level  
OR Temp - INCREASING ABOVE  
NORMAL

1) Check inputs to PRI per  
Enclosure 1.

a. Go to Step b.

1) Close Pzr PORV's.

b. Go to step c.

c. Go to step d.

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case II  
NC System Leakage

PAGE NO.

10 OF 17

## ACTION/EXPECTED RESPONSE

- d. Check NCDT level OR temperature  
- INCREASING ABOVE NORMAL

1) Check inputs to NCDT per  
Enclosure 2.

- e. Check Cont Flr/Equip Sump Level -  
INCREASING ABOVE NORMAL

1) Check inputs to sumps per  
Enclosure 3.

- f. Check inputs to Aux Building  
Sumps from NV System per  
Enclosure 4.

- g. Check ND System - IN SERVICE

1) Check inputs to Aux Building  
Sumps from ND System per  
Enclosure 5.

## RESPONSE NOT OBTAINED

- d. Go to step e.

- e. Go to step f.

- f. Go to step g.

- g. Go to step 6.

6. IF unit shutdown is required by Tech  
Specs, THEN notify NRC via red phone  
per RP/0/A/5700/10, NRC IMMEDIATE  
NOTIFICATION REQUIREMENTS.

END

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case III  
Letdown Or Charging Line Leakage

PAGE NO.

11 OF 17

## ACTION/EXPECTED RESPONSE

## RESPONSE NOT OBTAINED

B. Symptoms

- VCT level decrease or abnormal increase in frequency of auto makeup
- Increase levels in:
  - ND/NS Sump
  - NCDT
  - RHT
- "EMF-41 Aux Bldg Hi Gas Rad" alarm
- "Letdown Relief Tri Temp" alarm.
- Letdown or charging flows abnormal.

C. Immediate Actions

1. Check Pzr Level - AT OR INCREASING TO PROGRAMMED LEVEL.

IF level decreasing, THEN perform the following to maintain level:

- a. Ensure #1 PD Pump speed increasing OR INV-238 (Charging Line Flow Control) opening.
- b. Start additional NV Pumps
- c. Reduce letdown to 45 GPM orifice.

IF level decreases below 5%, THEN manually initiate SI AND go to EP/1/A/5000/01, SAFETY INJECTION.

2. Check Pzr Press - AT OR INCREASING TO 2235 PSIG.

IF less than 2210 PSIG, THEN ensure backup heaters on.  
IF pressure approaches 1945 PSIG, THEN trip Reactor  
AND refer to AP/1/A/5500/01, REACTOR TRIP.

D. Subsequent Actions

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS Case III Letdown Or Charging Line Leakage	PAGE NO. 12 OF 17
----------------	--	----------------------

## ACTION/EXPECTED RESPONSE

## RESPONSE NOT OBTAINED

CAUTION If PZR level cannot be maintained, (less than 5% and decreasing) then Safety Injection should be manually initiated.

\_\_\_\_\_ 1. Announce occurrence on paging system.

\_\_\_\_\_ 2. Check PZR Level - STABLE OR INCREASING.

IF level decreasing with maximum charging flow, THEN:

a. Manually trip Turbine AND Reactor.

b. Open 1NI-9A AND 10B (NC Cold Leg Inj From NV).

c. Swap charging pump suction to FWST:

1) Open 1NV-221A AND 222B (NV Pumps Suct From FWST)

2) Close 1NV-141A AND 142B (VCT Outlet Isol).

\_\_\_\_\_ 3. Check "EMF-41 Aux Bldg Hi Gas Rad" - IN ALARM

Go to step 4.

a. Verify 1ABF-D-3 VA Filter Exh Bypass Dmpr Trn A/B closed lights - LIT.

b. Verify 2ABF-D-3 VA Filter Exh Bypass Dmpr Trn A/B closed lights - LIT.

\_\_\_\_\_ 4. Refer to RP/0/A/5700/01, NOTIFICATION OF UNUSUAL EVENT.

\_\_\_\_\_ 5. Attempt to identify and isolate leak.

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case III  
Letdown Or Charging Line Leakage

PAGE NO.

13 OF 17

## ACTION/EXPECTED RESPONSE

## RESPONSE NOT OBTAINED

6. Check if letdown should be isolated:

- a. Leak on letdown line that can NOT be isolated by any other means
- a. Go to step 7.
- b. Isolate normal letdown:
  - 1) Close:
    - INV-1A (NC L/D Isol to Regen Hx)
    - INV-2A (NC L/D Isol to Regen Hx)
    - INV-241 (Seal Inj Flow Control).
- c. Adjust PD Pump speed Control  
OR  
Manually throttle INV-238  
(Charging Line Flow Control)  
to maintain 8 GPM seal  
injection flow per NC Pump.
- d. Establish excess letdown  
per OP/1/A/6200/01,  
CHEMICAL AND VOLUME CONTROL.
- e. Power operation may continue as  
long as NC System activity and  
chemistry requirements are met.

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case III  
Letdown Or Charging Line Leakage

PAGE NO.

14 OF 17

## ACTION/EXPECTED RESPONSE

## RESPONSE NOT OBTAINED

7. Check if charging headers should be isolated:

a. Leak on charging line that can NOT be isolated by any other means

a. IF leak can be isolated, THEN operation may continue.

b. Isolate letdown:

1) Close NC L/D Isol to Regen Hx valves:

- 1NV-1A
- 1NV-2A

c. Isolate charging:

1) Close Charging Line Cont Isol OTSD valves:

- 1NV-244A
- 1NV-245B.

2) Adjust PD Pump speed control  
OR  
Manually throttle 1NV-238 (Charging Line Flow Control) to maintain 8 GPM seal injection flow per NC Pump

d. Establish excess letdown per OP/1/A/6200/01, CHEMICAL AND VOLUME CONTROL.

e. Power operation may continue as long as NC System activity and chemistry requirements are met.

END

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case IV  
Leakage Into KC System

PAGE NO.  
15 OF 17

## ACTION/EXPECTED RESPONSE

## RESPONSE NOT OBTAINED

B. Symptoms

- Increase in KC Surge Tank Level
- "EMF-46 Comp Cool Hi Rad" alarm
- "NC Pump Thermal Barrier Outlet Hi Flow" alarm
- Increased frequency of Auto Makeup To VCT.

C. Immediate Actions

1. Check Pzr Level - AT OR INCREASING TO PROGRAMMED LEVEL.

IF level decreasing, THEN perform the following to maintain level:

- a. Ensure #1 PD Pump speed increasing OR INV-238 (Charging Line Flow Control) opening.
- b. Start additional NV Pumps
- c. Reduce letdown to 45 GPM orifice.

IF level decreases below 5%, THEN manually initiate SI AND go to EP/1/A/5000/01, SAFETY INJECTION.

2. Check Pzr Press - AT OR INCREASING TO 2235 PSIG.

IF less than 2210 PSIG, THEN ensure backup heaters on.  
IF pressure approaches 1945 PSIG, THEN trip Reactor  
AND refer to AP/1/A/5500/01, REACTOR TRIP.

D. Subsequent Actions

1. Announce occurrence on paging system.

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case IV  
Leakage Into KC System

PAGE NO.

16 OF 17

## ACTION/EXPECTED RESPONSE

## RESPONSE NOT OBTAINED

2. Check Pzr Level - STABLE OR INCREASING.

IF level decreasing with maximum charging flow, THEN:

- a. Manually trip Turbine AND Reactor
- b. Open 1NI-9A AND 10B (NC Cold Leg Inj From NV).
- c. Swap charging pump suction to FWST:
  - 1) Open 1NV-221A AND 222B (NV Pumps Suct From FWST)
  - 2) Close 1NV-141A AND 142B (VCT Outlet Isol).

3. Check "EMF-46 KC Hx Outlet" - IN ALARM

Go to step 4.

- a. Locally verify 1KC-122 (KC Surge Tank Vent) - CLOSED.

4. Check if any high "NC Pmp Therm Bar KC Outlet Flow" computer alarm is in:

Go to step 5.

- a. Verify NC Pump Therm Bar Otlt valve closes on affected pump:

- A, 1KC-394A
- B, 1KC-364B
- C, 1KC-345A
- D, 1KC-413B.

- b. Verify NC Pump L/B Temp remains less than 225°F.

- b. IF greater than 225°F, THEN trip NC Pump.

5. Refer to RP/0/A/5700/01, NOTIFICATION OF UNUSUAL EVENT.

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case IV  
Leakage Into KC System

PAGE NO.

17 OF 17

## ACTION/EXPECTED RESPONSE

## RESPONSE NOT OBTAINED

6. IF leak in Letdown Hx, THEN:

a. Close:

- INV-457A, 458A, 459A, (L/D Orif Otlr Cont Isol)
- INV-241 (Seal Inj Flow Control).

b. Adjust PD Pump speed control  
OR  
Manually throttle INV-238  
(charging Line Flow Control)  
to maintain 8 GPM seal  
injection flow per NC Pump

c. Establish excess letdown per  
OP/1/A/6200/01, CHEMICAL AND  
VOLUME CONTROL

d. Power operation may continue as  
long as NC System activity and  
chemistry requirements are met.

END

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case II - Enclosure 1  
Possible NC System Leakage Paths To PRT

PAGE NO.  
1 OF 2

VALVE NUMBER	NOMENCLATURE	INITIAL
--------------	--------------	---------

	POSSIBLE NC SYSTEM LEAKAGE PATHS TO PRT	
--	---	--

	OUTSIDE CONTAINMENT	
--	---------------------	--

	OUTSIDE CONTAINMENT	
--	---------------------	--

1ND-56	ND HX 1A OUTLET TO NI SYSTEM COLD LEG INJECTION SAFETY RELIEF	
--------	---	--

1ND-61	ND HX OUTLET TO NI SYSTEM HOT LEG INJECTION SAFETY RELIEF	
--------	---	--

1ND-64	ND HX 1B OUTLET TO NI SYSTEM COLD LEG INJECTION SAFETY RELIEF	
--------	---	--

1NS-2	NS PUMP 1B SUCTION SAFETY RELIEF	
-------	----------------------------------	--

1NS-19	NS PUMP 1A SUCTION SAFETY RELIEF	
--------	----------------------------------	--

1NI-102	SAFETY INJECTION PUMPS SUCTION HDR SAFETY RELIEF	
---------	--	--

1NI-119	SAFETY INJECTION PUMP 1A DISCHARGE SAFETY RELIEF	
---------	--	--

1NI-151	SAFETY INJECTION PUMP 1B DISCHARGE SAFETY RELIEF	
---------	--	--

1NI-161	SAFETY INJECTION PUMPS COLD LEG INJECTION HDR SAFETY RELIEF	
---------	---	--

1NV-229	CENTRIFUGAL CHARGING PUMPS SUCTION HDR SAFETY RELIEF	
---------	--	--

	INSIDE CONTAINMENT	
--	--------------------	--

1NC-1	PZR RELIEF VALVE	
-------	------------------	--

1NC-2	PZR RELIEF VALVE	
-------	------------------	--

1NC-3	PZR RELIEF VALVE	
-------	------------------	--

1NC-32B	PZR PORV	
---------	----------	--

1NC-34A	PZR PORV	
---------	----------	--

1NC-36B	PZR PORV	
---------	----------	--

1NC-43	PRESSURIZER #1 VENT	
--------	---------------------	--

1NC-119	PRESSURIZER #1 SEAL LOOP DRAIN HEADER	
---------	---------------------------------------	--

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case II - Enclosure 1  
Possible NC System Leakage Paths To PRTPAGE NO.  
2 OF 2

VALVE NUMBER

NOMENCLATURE

INITIAL

1NC-272A,C TRN 1A HEAD VENT TO PRT ISOL

1NC-274B TRN 1B HEAD VENT TO PRT ISOL

1ND-3 NC LOOP 3 DISCHARGE TO ND SYSTEM SAFETY RELIEF

1NV-6 LETDOWN LINE SAFETY RELIEF

1NV-93 NC PUMPS SEAL RETURN HDR SAFETY RELIEF

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS

Case II - Enclosure 2

Possible NC System Leakage Paths To NCDT

PAGE NO.  
1 OF 1

VALVE NUMBER	NOMENCLATURE	VALVE LOCATION	POSITION	INITIAL
--------------	--------------	----------------	----------	---------

Possible NC System Leakage Paths To NCDT

INV-27B	Excess L/D Hx Otlt 3-Way Cntrl	RB Pipechase 105°	VCT	
---------	-----------------------------------	-------------------	-----	--

INI-224	Accumulator 1A Drain Isol	RB 725' 40°	Closed	
---------	------------------------------	-------------	--------	--

INI-226	Accumulator 1B Drain Isol	RB 725' 140°	Closed	
---------	------------------------------	--------------	--------	--

INI-228	Accumulator 1C Drain Isol	RB 725' 220°	Closed	
---------	------------------------------	--------------	--------	--

INI-230	Accumulator 1D Drain Isol	RB 725' 317°	Closed	
---------	------------------------------	--------------	--------	--

INB-352	Reactor Makeup Water Storage Tank #1 Outlet Relief To NCDT			
---------	--	--	--	--

NC Pump	1A #3 Seal			
---------	------------	--	--	--

NC Pump	1A Standpipe			
---------	--------------	--	--	--

NC Pump	1B #3 Seal			
---------	------------	--	--	--

NC Pump	1B Standpipe			
---------	--------------	--	--	--

NC Pump	1C #3 Seal			
---------	------------	--	--	--

NC Pump	1C Standpipe			
---------	--------------	--	--	--

NC Pump	1D #3 Seal			
---------	------------	--	--	--

NC Pump	1D Standpipe			
---------	--------------	--	--	--

	Valve Steam Leakoff from			
--	--------------------------	--	--	--

	RB valves			
--	-----------	--	--	--

	Rx Vessel Head O Ring Seal			
--	----------------------------	--	--	--

AP/1/A/5500/10	NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS Case II - Enclosure 3 Possible NC System Leakage Paths to Containment Sumps	PAGE NO. 1 OF 1
----------------	--	--------------------

## VALVE CHECKLIST

VALVE NUMBER	NOMENCLATURE	VALVE LOCATION	POSITION	INITIAL
1NM-67	PZR Sample Hdr Cont Pent Relief	755', 120°		
1NM-68	NC Hot Leg Sample Header Cont Pent Relief			
1NM-69	NI Accumulators Sample Hdr Cont Pent Relief	730', 115°		
1NV-102	Excess Letdown Hx #1 Tube Drain	Pipechase 115° 6' up	Closed	
1NV-108	Regenerative Hx #1 Overflow	Pipechase 105° 5' up	Closed	
1NV-110	Regenerative Hx #1 Drain	Pipechase 105° 5' up	Closed	
1NI-336	UHI Check Valve Test Line Safety Relief	RB 750' 236°		

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case II - Enclosure 4  
Possible NV System Leakage Paths in Auxiliary Building

PAGE NO.

1 OF 6

VALVE NUMBER	NOMENCLATURE	VALVE LOCATION	POSITION	INITIAL
--------------	--------------	----------------	----------	---------

NOTE This Enclosure is to be used as a guide. Consideration should be given to any recent change in NV System alignment.

Check Seal Leakoff on following valves:

ND & NS ROOMS SUMP

1NV-95B	NC Pumps Seal Ret C/I	744' Midget Hole		
	OTSD			

1NV-127A	L/D Hx Outlet 3-Way Temp	NC FILTER ROOM		
	Cntrl			

1NV-137A	NC Filters OTLT 3 Way	Outside VCT Rm. So. Wall		
	Cntrl			

1NV-141A	VCT Outlet Isolation	OTSD S Wall of VCT		
		under grating		

1NV-142B	VCT Outlet Isol	OTSD SE Wall of VCT		
		under grating		

1NV-803	PD Pump Outlet Isol	722' S. of PD Pump		
---------	---------------------	--------------------	--	--

1NV-219	PD Pump Disch Isol			
---------	--------------------	--	--	--

1NV-240	Regen Hx Tube Inlet Cntrl	722 HH-59 & JJ-60		
	Isol			

1NV-241	Seal Inj Flow Control	Above BW Pumps		
---------	-----------------------	----------------	--	--

1NV-242	Regen Hx Tube Side Inlt	Above BW Pumps		
	Cntrl Isol			

1NV-243	Regen Hx Tube Side Inlt	Above BW Pumps		
	Cntrl Bypass			

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case II - Enclosure 4  
Possible NV System Leakage Paths in Auxiliary Building

PAGE NO.

2 OF 6

VALVE NUMBER	NOMENCLATURE	VALVE LOCATION	POSITION	INITIAL
INV-244A	Charging Line Cont Isol	Above BW Pumps		
	OTSD			
INV-245B	Charging Line Cont Isol	West of BW Pumps		
	OTSD			
INV-431	Seal Water Inj Filters	A Seal Inj Rm		
	Bypass			
INV-230	Cent Charging Pump B Suct		726' SE of 1B CCP 12'	
		Off floor		
INV-224	Cent Charging Pump A Suct	726' HH-57 & JJ-58 W of		
		1B CCP 12' Off Floor		
INV-804	Cent Charging Pump B	Right of 1B CCP		
	Outlet Isol			
INV-232	Cent Charging Pump B	724' NW of 1B CCP		
	Disch			
INV-226	Cent Charging Pump A	726' NE of 1B CCP		
	Disch			
INV-802	Cent Charging Pump A	NE 5' Above 1A CCP		
	Outlet Isol			
INV-235	Cent Charging Pump B To	NW of 1B CCP		
	Seal Inj Filter			
INV-236	Cent Charging Pump A To	NE of 1A CCP		
	Seal Inj Filter			
INV-237	Cent Charging Pumps Disch	N of PD Pump		
	To Control Isol			
INV-238	Charging Line Flow	N of PD Pump		
	Control			
INV-239	Cent Charging Pumps Disch			

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case II - Enclosure 4  
Possible NV System Leakage Paths in Auxiliary Building

PAGE NO.

3 OF 6

VALVE NUMBER	NOMENCLATURE	VALVE LOCATION	POSITION	INITIAL
--------------	--------------	----------------	----------	---------

## Control Isol

1NV-347	NR System Flow Control	Seal Inj Filter Room		
---------	------------------------	----------------------	--	--

1NV-121	ND Letdown Control			
---------	--------------------	--	--	--

1NV-221A	NV Pumps Suct From FWST	20' N of BW Pump		
----------	-------------------------	------------------	--	--

1NV-222B	NV Pumps Suct From FWST	20' N of BW Pump		
----------	-------------------------	------------------	--	--

## RECYCLE HOLDUP TANK

1NV-7B	Letdown Cont Isol Outside			
--------	---------------------------	--	--	--

1NV-8	L/D Reheat Hx Tubeside	SE of L/D Hx		
-------	------------------------	--------------	--	--

## Back pressure Cntrl Isol

1NV-9	L/D Reheat Hx Tubeside	W of L/D Hx		
-------	------------------------	-------------	--	--

## Back pressure Cntrl Isol

1NV-10	L/D Reheat Hx Tubeside	W of L/D Hx		
--------	------------------------	-------------	--	--

## Back Pressure Cntrl Isol

1NV-11	L/D Reheat Hx Tubeside	SW of L/D Hx		
--------	------------------------	--------------	--	--

## Back Pressure Cntrl Isol

1NV-476	LP Letdown Control Inlet	S of L/D Hx		
---------	--------------------------	-------------	--	--

## Isol

1NV-124	Letdown Press Control	L/D Hx Rm		
---------	-----------------------	-----------	--	--

1NV-477	LP Letdown Control	L/D Hx Rm		
---------	--------------------	-----------	--	--

## Outlet Isol

Check vent and drain boundary valves closed:

## WASTE DRAIN TANK

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case II - Enclosure 4  
Possible NV System Leakage Paths in Auxiliary Building

PAGE NO.

4 OF 6

VALVE NUMBER	NOMENCLATURE	VALVE LOCATION	POSITION	INITIAL
1NV-184	Letdown Hx Tube Drain To WDT	L/D Hx Rm	CLOSED	
1NV-205	Seal Water Filter Drain To WDT	Seal Ret Filter Rm	CLOSED	
1NV-272	PD Pump Drain To WDT	Otsd PD Pump Rm	CLOSED	
1NV-310	Seal Water Inj Filters Drain To WDT	B Seal Inj Rm	CLOSED	
1NV-299	Charging Pump B Drain To WDT	E of 1B CCP	CLOSED	
1NV-330	NC Filter Drain To WDT	E of B NC Filters	CLOSED	
1NV-356	Mixed And Cation Bed Demin Outlet Line Drain To WDT	A Mixed Bed Rm	CLOSED	
<u>WASTE EVAPORATOR FEED TANK</u>				
1NV-181	Letdown Hx Tube Overflow	L/D Hx Rm	CLOSED	
1NV-185	Letdown Hx Tube Drain To WEFT	LD Hx Rm	CLOSED	
1NV-145	VCT Outlet Drain	Below VCT	CLOSED	
1NV-210	Seal Water Hx Tube Overflow		CLOSED	
1NV-204	Seal Water Filter Drain To WEFT		CLOSED	
1NV-215	Seal Water Hx Tube Drain To WEFT	Seal Water Hx Rm	CLOSED	
1NV-309	Seal Water Inj Filters	B Seal Inj Filter Rm	CLOSED	

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case II - Enclosure 4  
Possible NV System Leakage Paths in Auxiliary Building

PAGE NO.

5 OF 6

VALVE NUMBER	NOMENCLATURE	VALVE LOCATION	POSITION	INITIAL
--------------	--------------	----------------	----------	---------

Drain To WEFT

1NV-329	NC Filters Drain To WEFT	B NC Filter Rm	CLOSED	
---------	--------------------------	----------------	--------	--

1NV-335	Mixed Bed Demin A Backflush			
---------	-----------------------------	--	--	--

Drain

1NV-333	Mixed Bed Demin A Backflush		CLOSED	
---------	-----------------------------	--	--------	--

Outlet Isol

1NV-340	Mixed Bed Demin B	B Mixed Bed Rm	CLOSED	
---------	-------------------	----------------	--------	--

Backflush Outlet Isol

1NV-373	Mixed Bed Demin B	B Mixed Bed Rm	CLOSED	
---------	-------------------	----------------	--------	--

Outlet Line Drain

1NV-365	Cation Bed Demin	733 Pipechase between NR &	CLOSED	
---------	------------------	----------------------------	--------	--

Sluicing Resin Isol NV DIM

1NV-354	Mixed Bed Demin A Outlet	A Mixed Bed Rm	CLOSED	
---------	--------------------------	----------------	--------	--

Line Drain

1NV-366	Cation Bed Demin Outlet	Cation Bed Rm	CLOSED	
---------	-------------------------	---------------	--------	--

Line Drain

1NV-357	Mixed & Cation Bed	A Mixed Bed Rm	CLOSED	
---------	--------------------	----------------	--------	--

Demins Outlet Line Drain

To WEFT

## WASTE EVAPORATOR FEED TANK SUMP A

1NV-296	Charging Pump B Overflow		CLOSED	
---------	--------------------------	--	--------	--

1NV-300	Charging Pump B Drain To		CLOSED	
---------	--------------------------	--	--------	--

WEFT Sump A

1NV-285	Charging Pump A Overflow		CLOSED	
---------	--------------------------	--	--------	--

1NV-289	Charging Pump A Drain To		CLOSED	
---------	--------------------------	--	--------	--

WEFT Sump A

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
Case II - Enclosure 4  
Possible NV System Leakage Paths in Auxiliary Building

PAGE NO.

6 OF 6

VALVE NUMBER	NOMENCLATURE	VALVE LOCATION	POSITION	INITIAL
--------------	--------------	----------------	----------	---------

SPENT RESIN TANK

1NV-349	Mixed Bed Demin A Sluicing		CLOSED	
---------	----------------------------	--	--------	--

Resin Isol

1NV-350	Mixed Bed Demin A Sluicing		CLOSED	
---------	----------------------------	--	--------	--

Resin Isol

AP/1/A/5500/10

NC SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
CASE II - Enclosure 5  
Possible ND System Leakage Paths in Auxiliary Building

PAGE NO.  
1 OF 2

VALVE NUMBER	NOMENCLATURE	VALVE LOCATION	POSITION	INITIAL
--------------	--------------	----------------	----------	---------

ND & NS ROOMS SUMP Check seal leakoff on following valves

1ND-4B	B ND Pmp Suct From FWST	Aux 695'	FF-59 & GG-60	
--------	-------------------------	----------	---------------	--

Or NC

1ND-19A	A ND Pmp Suct From FWST	Aux 695'	GG-59 & HH-60	
---------	-------------------------	----------	---------------	--

Or NC

1ND-9	ND Pump B Disch	N of Pump	12' up	
-------	-----------------	-----------	--------	--

1ND-24	ND Pump A Disch	W of Pump	12' up	
--------	-----------------	-----------	--------	--

1ND-26	ND Hx A Inlet	E of Hx	6' up	
--------	---------------	---------	-------	--

1ND-14	B ND Hx Outlet	Aux 733'	LL-61	
--------	----------------	----------	-------	--

1ND-29	A ND Hx Outlet	Aux 733'	LL-60 & MM-61	
--------	----------------	----------	---------------	--

1ND-30A	Train 1A ND To Hot Leg	Aux 733'	LL-60 & MM-61	
---------	------------------------	----------	---------------	--

Isol

1ND-58A	Train 1A ND To NV & NI	Aux 733'	LL-60 & JJ-61	
---------	------------------------	----------	---------------	--

Pumps

1ND-15B	Train 1B ND To Hot Leg	Aux 733'	KK-60 & LL-61	
---------	------------------------	----------	---------------	--

Isol

1ND-35	ND To FWST Isol	15' E of KK-59,	12' up	
--------	-----------------	-----------------	--------	--

1ND-34	A & B ND Hx Bypass	Aux 733	KK-60 & LL-61	
--------	--------------------	---------	---------------	--

1ND-33	A ND Hx Bypass	Aux 733	LL-60 & MM-61	
--------	----------------	---------	---------------	--

1ND-18	B ND Hx Bypass	Aux 733	KK-60 & LL-61	
--------	----------------	---------	---------------	--

1ND-11	ND Hx B Inlet	W of Hx	4' up	
--------	---------------	---------	-------	--

1NI-173A	Train 1A ND To A & B CL	Aux 733'	FF-59 & GG-60	
----------	-------------------------	----------	---------------	--

1NI-178B	Train 1B ND To C&D CL	Aux 733'	HH-60 & JJ-61	
----------	-----------------------	----------	---------------	--

1NI-184B	RB Sump To Train 1B ND	Aux 716'	EE-58 & FF-59	
----------	------------------------	----------	---------------	--

& NS

AP/1/A/5500/10

ND SYSTEM LEAKAGE WITHIN CAPACITY OF BOTH NV PUMPS  
CASE II - Enclosure 5  
Possible ND System Leakage Paths in Auxiliary Building

PAGE NO.  
2 OF 2

VALVE NUMBER	NOMENCLATURE	VALVE LOCATION	POSITION	INITIAL
--------------	--------------	----------------	----------	---------

1NI-185A	RB Sump To Train 1A ND & NS	Aux 716' FF-59 & GG-60		
----------	--------------------------------	------------------------	--	--

WASTE EVAPORATOR FEED TANK Check Drain Boundary Valves Closed

1ND-52	ND HX A Drain Hdr	S of Hx	Closed	
--------	-------------------	---------	--------	--

1ND-46	ND Hx B Drain Hdr	S of Hx	Closed	
--------	-------------------	---------	--------	--

ND & NS ROOMS SUMP

1ND-51	ND Pump A Drain Hdr	SW of Pump	Closed	
--------	---------------------	------------	--------	--

1ND-45	ND Pump B Drain Hdr	S of Pump	Closed	
--------	---------------------	-----------	--------	--

1ND-69	ND & NS System Drain	RB 860' Rx Dome	Closed	
--------	----------------------	-----------------	--------	--

# MASTER FILE

## Duke Power Company PROCEDURE PROCESS RECORD

(1) ID No. UP/1/A/6100/02  
Change(s) 0 to 67 Incorporated

**SUPERCEDED**

### PREPARATION

(2) Station McGuire Nuclear Station  
(3) Procedure Title Controlling Procedure for Unit Shutdown

(4) Prepared By Verida Bellamy Date 1/20/89  
(5) Reviewed By [Signature] Date 1/20/89  
Cross-Disciplinary Review By \_\_\_\_\_ N/R \_\_\_\_\_

(6) Temporary Approval (if necessary)  
By \_\_\_\_\_ (SRO) Date \_\_\_\_\_

By [Signature] Date \_\_\_\_\_  
(7) Approved By Bruce Travis Date 2/1/89

(8) Miscellaneous  
Reviewed/Approved By [Signature] Date 1-20-89  
Reviewed/Approved By ETQS Date 1/20/89

(9) Comments (For procedure reissue indicate whether additional changes, other than previously approved changes, are included. Attach additional pages, if necessary.)  
Additional Changes Included. ☒ Yes  
☐ No

(10) Compared with Control Copy \_\_\_\_\_ Date \_\_\_\_\_

(11) Requires change to FSAR not identified in 10CFR50.59 evaluation? ☐ Yes  
If "yes", attach detailed explanation. ☒ No

### Completion

(12) Date(s) Performed \_\_\_\_\_

(13) Procedure Completion Verification

- ☐ Yes ☐ N/A Check lists and/or blanks properly initialed, signed, dated or filed in N/A or N/R, as appropriate?
- ☐ Yes ☐ N/A Listed enclosures attached?
- ☐ Yes ☐ N/A Data sheets attached, completed, dated and signed?
- ☐ Yes ☐ N/A Charts, graphs, etc. attached and properly dated, identified and marked?
- ☐ Yes ☐ N/A Procedure requirements met?

Verified By \_\_\_\_\_ Date \_\_\_\_\_

(14) Procedure Completion Approved \_\_\_\_\_ Date \_\_\_\_\_

(15) Remarks (attach additional pages, if necessary)

2.15.1.1 Ensure the "Operation Selector" for all 6 detectors is in the "Off" position.

2.15.1.2 Open and tag the 120 VAC main power breaker on the panel.

\_\_\_\_\_ 2.16 Determine required boron concentration to establish greater than or equal to 1.3% Delta k/k shutdown margin at desired temperature per Table 6.5 of OP/1/A/6100/22 (Unit 1 Data Book). If cooldown below 200°F is anticipated, ensure greater than or equal to 1% Delta k/k shutdown margin at 68°F prior to reduction below 200°F.

CAUTION The following step must be completed and NC System boron concentration verified prior to initiating NC System cooldown.

\_\_\_\_\_ 2.17 Borate the NC System per OP/1/A/6150/09 (Boron Concentration Control) or OP/1/A/6200/02 (BTRS) to establish the appropriate shutdown margin.

2.18 Have IAE do the following:

\_\_\_\_\_ 2.18.1 When the neutron level decays to the normal shutdown counts, verify "High Flux At Shutdown" alarm bistable is set at one-half decade above normal shutdown source counts, and reinstate "High Flux At Shutdown" alarm.

\_\_\_\_\_ 2.19 After the "High Flux At Shutdown" alarm has been reinstated, insert the Shutdown Banks per OP/1/A/6150/08 (Rod Control).

\_\_\_\_\_ 2.20 Remove both MG sets from service per OP/1/A/6150/08 (Rod Control).

\_\_\_\_\_ 2.21 As soon as access to lower containment is possible, close INC-24 (Reactor Vessel Head Gasket Leakoff Drain Manual Block) to prevent NCDT H<sub>2</sub> from escaping to containment during cooldown.