



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

VIRGINIA ELECTRIC AND POWER COMPANY

OLD DOMINION ELECTRIC COOPERATIVE

DOCKET NO. 50-338

NORTH ANNA POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 122
License No. NPF-4

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Virginia Electric and Power Company et al., (the licensee) dated March 28, 1989, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.D.(2) of Facility Operating License No. NPF-4 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 122, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Herbert N. Berkow, Director
Project Directorate II-2
Division of Reactor Projects-I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 2, 1989

ATTACHMENT TO LICENSE AMENDMENT NO. 122

TO FACILITY OPERATING LICENSE NO. NPF-4

DOCKET NO. 50-338

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page as indicated. The revised page is identified by amendment number and contains vertical lines indicating the area of change. The corresponding overleaf page is also provided to maintain document completeness.

Page

3/4 3-37

TABLE 3.3-6 (Continued)

TABLE NOTATION

- ACTION 19 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, perform area surveys of the monitored area with portable monitoring instrumentation at least once per 24 hours.
- ACTION 20 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, comply with the ACTION requirements of Specification 3.4.6.1.
- ACTION 21 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, comply with the ACTION requirements of Specification 3.9.12.
- ACTION 22 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, comply with the ACTION requirements of Specification 3.9.9.
- ACTION 35 - With the number of OPERABLE channels less than required by the Minimum Channels OPERABLE requirement, initiate the preplanned alternate method of monitoring the appropriate parameter(s), within 72 hours, and:
1. Either restore the inoperable channel(s) to OPERABLE status within 7 days of the event, or
 2. Prepare and submit a Special Report to the Commission pursuant to Specification 6.9.2 within 14 days following the event outlining the action taken, the cause of the inoperability and the plans and schedule for restoring the system to OPERABLE status.

TABLE 4.3-3

RADIATION MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

INSTRUMENT	CHANNEL CHECK	CHANNEL CALIBRATION	CHANNEL FUNCTIONAL TEST	MODES IN WHICH SURVEILLANCE REQUIRED
1. AREA MONITORS				
a. Fuel Storage Pool Area				
i. Criticality Monitor #	S	R	M	*
b. Containment				
i. Purge & Exhaust Isolation	S	R	M	6
ii. High Range Area	S	R	M	1, 2, 3, & 4
2. PROCESS MONITORS				
a. Ventilation Vent #				
i. Gaseous Gross Activity	S	R	M	**
ii. Particulate Gross Activity	S	R	M	**
b. Containment				
i. Gaseous Activity				
a) Purge & Exhaust Isolation	S	R	M	6
b) RCS Leakage Detection	S	R	M	1, 2, 3, & 4
ii. Particulate Activity				
a) Purge & Exhaust Isolation	S	R	M	6
b) RCS Leakage Detection	S	R	M	1, 2, 3, & 4

*With fuel in the storage pool or building

**With irradiated fuel in the storage pool

#Common to Unit 1 and Unit 2



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

VIRGINIA ELECTRIC AND POWER COMPANY

OLD DOMINION ELECTRIC COOPERATIVE

DOCKET NO. 50-339

NORTH ANNA POWER STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 106
License No. NPF-7

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Virginia Electric and Power Company, et al., (the licensee) dated March 28, 1989, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-7 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 106, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Herbert N. Berkow, Director
Project Directorate II-2
Division of Reactor Projects-I/II
Office of Nuclear Reactor Regulation

Attachment.
Changes to the Technical
Specifications

Date of Issuance: August 2, 1989

ATTACHMENT TO LICENSE AMENDMENT NO.106

TO FACILITY OPERATING LICENSE NO. NPF-7

DOCKET NO. 50-339

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page as indicated. The revised page is identified by amendment number and contains vertical lines indicating the area of change. The corresponding overleaf page is also provided to maintain document completeness.

Page

3/4 3-40

TABLE 3.3-6 (Continued)

TABLE NOTATION

- ACTION 22 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, perform area surveys of the monitored area with portable monitoring instrumentation at least once per 24 hours.
- ACTION 23 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, comply with the ACTION requirements of Specification 3.4.6.1.
- ACTION 24 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, comply with the ACTION requirements of Specification 3.9.12.
- ACTION 25 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, comply with the ACTION requirements of Specification 3.9.9.
- ACTION 35 - With the number of OPERABLE channels less than required by the Minimum Channels OPERABLE requirement, initiate the preplanned alternate method of monitoring the appropriate parameter(s), within 72 hours, and:
1. Either restore the inoperable channel(s) to OPERABLE status within 7 days of the event, or
 2. Prepare and submit a Special Report to the Commission pursuant to Specification 6.9.2 within 14 days following the event outlining the action taken, the cause of the inoperability and the plans and schedule for restoring the system to OPERABLE status.