

NOTICE OF VIOLATION

Northern States Power Company

Docket Nos. 50-282; 50-306

As a result of the inspection conducted on April 16 through May 26, 1989, and in accordance with the "General Policy and Procedures for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1988), the following violations were identified:

1. Technical Specification 4.6.A.1.C requires the licensee to verify that, at least once each month, for each diesel generator a sample of diesel fuel from the fuel storage tank is within the acceptable limits specified in Table 1 of ASTM D975-68 when checked for viscosity, water and sediment.

Contrary to the above, the licensee has not sampled the fuel storage tanks on a monthly basis.

This is a Severity Level IV violation (Supplement 1).

2. Technical Specification 3.6.A.8 requires, in part, that during maintenance and testing activities, containment integrity is considered intact if the auxiliary building special vent zone (ABSVZ) boundary is opened intermittently, provided such openings are under direct administrative control and can be reduced to less than 10 square feet within 6 minutes following an accident. Operations Procedure D54, Control of Openings in the Auxiliary Building Special Vent Zone Boundary, Rev. 3., requires that a log be kept in the control room which specifies the size and location of all openings in the ABSVZ. The log shall include the time and date openings are made and when they are closed.

Contrary to the above, from approximately 0800 hours on April 13, 1989, to 1402 hours on April 20, 1989, an opening in the ABSVZ boundary was not under direct administrative control or logged.

This is a Severity Level IV violation (Supplement 1).

Pursuant to the provisions of 10 CFR 2.201, you are required to submit to this office within thirty days of the date of this Notice a written statement or explanation in reply, including for each violation: (1) the corrective actions that have been taken and the results achieved; (2) the corrective actions that will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

JUN 20 1989

Dated \_\_\_\_\_

*William L. Stoney*  
for W. L. Axelson, Chief  
Projects Branch 2

B906280043 B90620  
PDR ADOCK 05000282  
Q PNU