

JUN 16 1989

Docket No. 50-317  
50-318

Baltimore Gas and Electric Company  
ATTN: Mr. George C. Creel  
Vice President  
Nuclear Energy  
Calvert Cliffs Nuclear Power Plant  
MD Rts 2 & 4, P.O. Box 1535  
Lusby, Maryland 20657

Gentlemen:

Subject: NRC Inspection No. 50-317/89-12 and 50-318/89-12

This letter refers to the routine safety inspection conducted by Mr. R. K. Mathew of this office on May 1-5, 1989, at the Calvert Cliffs Units 1 and 2, Lusby, Maryland of activities authorized by NRC License Nos. DPR-53 and DPR-69 and to the discussions of our findings held by Mr. Mathew with Mr. L. Russell at the conclusion of the inspection.

Areas examined during this inspection are described in the NRC Region I Inspection Report which is enclosed with this letter. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspector.

Based on the results of this inspection, it appears that certain of your activities were not conducted in full compliance with NRC requirements, as set forth in the Notice of Violation, enclosed herewith as Appendix A. These violations have been categorized by severity level in accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions, "10 CFR Part 2, Appendix C (Enforcement Policy)." You are required to respond to this letter and in preparing your response, you should follow the instructions in Appendix A.

In addition, it is important that proper management attention be given to the MOV maintenance program deficiencies identified in this report. We understand that you are in the process of implementing a new program to address current deficiencies. During the inspection, your staff agreed to provide the NRC a written description of plans to upgrade the MOV maintenance programs.

OFFICIAL RECORD COPY

CIR CC 89-12 - 0001.0.0  
06/16/89

8906220070 890616  
PDR ADCK 05000317  
Q PDC

IE:OI 1/1

JUN 16 1989

Baltimore Gas and Electric Company 2

Your cooperation with us in this matter is appreciated.

Sincerely,

Original Signed By:  
Jack R. Strosnider

Jacque P. Durr, Chief  
Engineering Branch  
Division of Reactor Safety

Enclosures:

1. Appendix A, Notice of Violation
2. Combined NRC Region I Inspection Report Number 50-317/89-12 and 50-318/89-12

cc w/encl:

W. J. Lippold, General Supervisor, Technical Services Engineering  
T. Magette, Administrator, Nuclear Evaluations  
Public Document Room (PDR)  
Local Public Document Room (LPDR)  
Nuclear Safety Information Center (NSIC)  
NRC Resident Inspector  
State of Maryland (2)

bcc w/encl:

Region I Docket Room (with concurrences)  
Management Assistant, DRMA (w/o encl)  
J. Wiggins, DRP  
L. Tripp, DRP  
D. Limroth, DRP  
P. Wilson, DRP  
R. Bores, DRSS  
S. McNeil, NRR  
PAO (14) SALP Reports Only

*cja for*  
RI:DRS  
Mathew/gcb/rw

6/16/89

*cja*  
RI:DRS  
Anderson

6/16/89

*JPD*  
RI:DRS  
Durr  
*for*

6/16/89

OFFICIAL RECORD COPY

CIR CC 89-12 - 0001.1.0  
06/16/89