

ENCLOSURE 5

BRUNSWICK STEAM ELECTRIC PLANT, UNITS 1 AND 2
NRC DOCKETS 50-325 & 50-324
OPERATING LICENSES DPR-71 & DPR-62
REQUEST FOR LICENSE AMENDMENT
INTEGRATED LEAK RATE TEST METHODS

TECHNICAL SPECIFICATION PAGES - UNIT 1

890501
8905040234 890501
PDR ADOCK 05000324
P FDC

CONTAINMENT SYSTEMS

LIMITING CONDITION FOR OPERATION (Continued)

ACTION (Continued)

- c. The leakage rate to less than or equal to 11.5 scf per hour for any one main steam line isolation valve,
prior to increasing reactor coolant system temperature above 212°F.

SURVEILLANCE REQUIREMENTS

4.6.1.2 The primary containment leakage rates shall be demonstrated at the following schedule and shall be determined in conformance with the criteria specified in Appendix J of 10 CFR 50:

- a. Three Type A Overall Integrated Containment Leakage Rate tests shall be conducted at 40 + 10 month intervals during shutdown at P_a , 49 psig, or P_t , 25 psig, during each 10-year service period. The third test of each set shall be conducted during the shutdown for the 10-year plant inservice inspection.
- b. If any periodic Type A test fails to meet either $0.75 L_a$ or $0.75 L_t$, the test schedule for subsequent Type A tests shall be reviewed and approved by the Commission. If two consecutive Type A tests fail to meet $0.75 L_a$ or $0.75 L_t$, a Type A test shall be performed at each plant shutdown for refueling or every 18 months, whichever occurs first, until two consecutive Type A tests meet $0.75 L_a$ or $0.75 L_t$, at which time the above test schedule may be resumed.
- c. The accuracy of each Type A test shall be verified by a supplemental test which:
1. Confirms the accuracy of the test by verifying that the difference between the supplemental data and the Type A test data is within $0.25 L_a$ or $0.25 L_t$.
 2. Has duration sufficient to establish accurately the change in leakage rate between the Type A test and the supplemental test.
 3. Requires the quantity of gas injected into the containment or bled from the containment during the supplemental test to be equivalent to at least 25 percent of the total measured leakage rate at P_a , 49 psig, or P_t , 25 psig.

*Exemption from Appendix J of 10CFR50.

3/4.6 CONTAINMENT SYSTEMS

BASES

3/4.6.1 PRIMARY CONTAINMENT

3/4.6.1.1 PRIMARY CONTAINMENT INTEGRITY

Primary CONTAINMENT INTEGRITY ensures that the release of radioactive materials from the containment atmosphere will be restricted to those leakage paths and associated leak rates assumed in the accident analyses. This restriction, in conjunction with the leakage rate limitation, will limit the site boundary radiation doses to within the limits of 10 CFR Part 100 during accident conditions.

3/4.6.1.2 PRIMARY CONTAINMENT LEAKAGE

The limitations on primary containment leakage rates ensure that the total containment leakage volume will not exceed the value assumed in the accident analyses at the peak accident pressure of 49 psig, P_a . As an added conservatism, the measured overall integrated leakage rate is further limited to less than or equal to $0.75 L_a$ or $0.75 L_t$, as applicable, during performance of the periodic tests to account for possible degradation of the containment leakage barriers between leakage tests.

Operating experience with the main steam line isolation valves has indicated that degradation has occasionally occurred in the leak tightness of the valves; therefore, the special requirement for testing these valves.

Exemptions from the requirements of 10 CFR Part 50 have been granted for main steam isolation valve leak testing, testing of airlocks after each opening, and leakage calculation methods.

Appendix J, paragraph III.A.3 requires that all Type A (Containment Integrated Leak Rate) tests be conducted in accordance with American National Standard (ANSI) N45.4-1972, "Leakage Rate Testing of Containment Structures for Nuclear Reactors," March 16, 1972. In addition to the Total Time and Point-to-Point methods described in that standard, the Mass Point method, when used with a test duration of at least 24 hours, is an acceptable method to use to calculate leakage rates. A typical description of the Mass Point method can be found in ANSI/ANS 56.8-1987, "Containment System Leakage Testing Requirements," January 20, 1987. Reduced duration Type A tests may be performed using the criteria and Total Time method specified in Bechtel Topical Report BN-TOP-1, Revision 1, November 1, 1972 (References 1 and 2).

References:

1. CP&L Letter to Mr. D. B. Vassallo, "Integrated Leak Rate Test," October 20, 1983.
2. NRC Letter from Mr. D. B. Vassallo to Mr. E. E. Utley, December 9, 1983.

CONTAINMENT SYSTEMS

BASES

3/4.6.1.3 PRIMARY CONTAINMENT AIR LOCKS

The limitations on closure and leak rate for the containment air locks are required to meet the restrictions on PRIMARY CONTAINMENT INTEGRITY and leak rate given in Specifications 3.6.1.1 and 3.6.1.2. The specification makes allowances for the fact that there may be long periods of time when the air locks will be in a closed and secured position during reactor operation.

3/4.6.1.4 PRIMARY CONTAINMENT STRUCTURAL INTEGRITY

This limitation ensures that the structural integrity of the primary containment steel vessel will be maintained comparable to the original design standards for the life of the facility. Structural integrity is required to ensure that the vessel will withstand the maximum pressure of 49 psig in the event of a LOCA. A visual inspection in conjunction with Type A leakage tests is sufficient to demonstrate this capability.

3/4.6.1.5 PRIMARY CONTAINMENT INTERNAL PRESSURE

The limitations of primary containment internal pressure ensure that the containment peak pressure of 49 psig does not exceed the design pressure of 62 psig during LOCA conditions. The limit of 1.75 psig for initial positive containment pressure will limit the total pressure to 49 psig, which is less than the design pressure and is consistent with the accident analyses.

3/4.6.1.6 PRIMARY CONTAINMENT AVERAGE AIR TEMPERATURE

The limitation in containment average air temperature ensures that the containment peak air temperature does not exceed the design temperature of 300°F during LOCA conditions and is consistent with the accident analyses.

ENCLOSURE 6

BRUNSWICK STEAM ELECTRIC PLANT, UNITS 1 AND 2
NRC DOCKETS 50-325 & 50-324
OPERATING LICENSES DPR-71 & DPR-62
REQUEST FOR LICENSE AMENDMENT
INTEGRATED LEAK RATE TEST METHODS

TECHNICAL SPECIFICATION PAGES - UNIT 2

CONTAINMENT SYSTEMS

LIMITING CONDITION FOR OPERATION (Continued)

ACTION (Continued)

- c. The leakage rate to less than or equal to 11.5 scf per hour for any one main steam line isolation valve,

prior to increasing reactor coolant system temperature above 212°F.

SURVEILLANCE REQUIREMENTS

4.6.1.2 The primary containment leakage rates shall be demonstrated at the following schedule and shall be determined in conformance with the criteria specified in Appendix J of 10CFR50:

- a. Three Type A Overall Integrated Containment Leakage Rate tests shall be conducted at 40 ± 10 month intervals during shutdown at P_a , 49 psig, or P_t , 25 psig, during each 10-year service period. The third test of each set shall be conducted during the shutdown for the 10-year plant inservice inspection.
- b. If any periodic Type A test fails to meet either $0.75 L_a$ or $0.75 L_t$, the test schedule for subsequent Type A tests shall be reviewed and approved by the Commission. If two consecutive Type A tests fail to meet $0.75 L_a$ or $0.75 L_t$, a Type A test shall be performed at each plant shutdown for refueling or every 18 months, whichever occurs first, until two consecutive Type A tests meet $0.75 L_a$ or $0.75 L_t$, at which time the above test schedule may be resumed.
- c. The accuracy of each Type A test shall be verified by a supplemental test which:
 1. Confirms the accuracy of the test by verifying that the difference between the supplemental data and the Type A test data is within $0.25 L_a$ or $0.25 L_t$.
 2. Has duration sufficient to establish accurately the change in leakage rate between the Type A test and the supplemental test.
 3. Requires the quantity of gas injected into the containment or bled from the containment during the supplemental test to be equivalent to at least 25 percent of the total measured leakage at P_a , 49 psig or P_t , 25 psig.

*Exemption from Appendix J of 10CFR50.

3/4.6 CONTAINMENT SYSTEMS

BASES

3/4.6.1 PRIMARY CONTAINMENT

3/4.6.1.1 PRIMARY CONTAINMENT INTEGRITY

Primary CONTAINMENT INTEGRITY ensures that the release of radioactive materials from the containment atmosphere will be restricted to those leakage paths and associated leak rates assumed in the accident analyses. This restriction, in conjunction with the leakage rate limitation, will limit the site boundary radiation doses to within the limits of 10 CFR Part 100 during accident conditions.

3/4.6.1.2 PRIMARY CONTAINMENT LEAKAGE

The limitations on primary containment leakage rates ensure that the total containment leakage volume will not exceed the value assumed in the accident analyses at the peak accident pressure of 49 psig, P_a . As an added conservatism, the measured overall integrated leakage rate is further limited to less than or equal to $0.75 L_a$ or $0.75 L_t$, as applicable, during performance of the periodic tests to account for possible degradation of the containment leakage barriers between leakage tests.

Operating experience with the main steam line isolation valves has indicated that degradation has occasionally occurred in the leak tightness of the valves; therefore, the special requirement for testing these valves.

Exemptions from the requirements of 10 CFR Part 50 have been granted for main steam isolation valve leak testing, testing of airlocks after each opening, and leakage calculation methods.

Appendix J, paragraph III.A.3 requires that all Type A (Containment Integrated Leak Rate) tests be conducted in accordance with American National Standard (ANSI) N45.4-1972, "Leakage Rate Testing of Containment Structures for Nuclear Reactors," March 16, 1972. In addition to the Total Time and Point-to-Point methods described in that standard, the Mass Point method, when used with a test duration of at least 24 hours, is an acceptable method to use to calculate leakage rates. A typical description of the Mass Point method can be found in ANSI/ANS 56.8-1987, "Containment System Leakage Testing Requirements," January 20, 1987. Reduced duration Type A tests may be performed using the criteria and Total Time method specified in Bechtel Topical Report BN-TOP-1, Revision 1, November 1, 1972 (References 1 and 2).

References:

1. CP&L Letter to Mr. D. B. Vassallo, "Integrated Leak Rate Test," October 20, 1983.
2. NRC Letter from Mr. D. B. Vassallo to Mr. E. E. Utley, December 9, 1983.

CONTAINMENT SYSTEMS

BASES

3/4.6.1.3 PRIMARY CONTAINMENT AIR LOCKS

The limitations on closure and leak rate for the containment air locks are required to meet the restrictions on PRIMARY CONTAINMENT INTEGRITY and leak rate given in Specifications 3.6.1.1 and 3.6.1.2. The specification makes allowances for the fact that there may be long periods of time when the air locks will be in a closed and secured position during reactor operation.

3/4.6.1.4 PRIMARY CONTAINMENT STRUCTURAL INTEGRITY

This limitation ensures that the structural integrity of the primary containment steel vessel will be maintained comparable to the original design standards for the life of the facility. Structural integrity is required to ensure that the vessel will withstand the maximum pressure of 49 psig in the event of a LOCA. A visual inspection in conjunction with Type A leakage tests is sufficient to demonstrate this capability.

3/4.6.1.5 PRIMARY CONTAINMENT INTERNAL PRESSURE

The limitations of primary containment internal pressure ensure that the containment peak pressure of 49 psig does not exceed the design pressure of 62 psig during LOCA conditions. The limit of 1.75 psig, for initial positive containment pressure will limit the total pressure to 49 psig, which is less than the design pressure and is consistent with the accident analyses.

3/4.6.1.6 PRIMARY CONTAINMENT AVERAGE AIR TEMPERATURE

The limitation in containment average air temperature ensures that the containment peak air temperature does not exceed the design temperature of 300°F during LOCA conditions and is consistent with the accident analyses.