



Log # TXX-89432
File # 10110
908.3
Ref. # 10CFR50.55(e)

June 29, 1989

William J. Cahill, Jr.
Executive Vice President

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
ELECTRICAL PENETRATION OVERLOAD PROTECTION
SDAR: CP-88-09 (SUPPLEMENTAL REPORT)

Gentlemen:

On January 11, 1988, TU Electric letter logged TXX-88068 notified the NRC of a reportable deficiency involving the overloading of and the absence of backup protection devices for Class 1E and non-Class 1E electrical penetrations. The purpose of this supplemental report is to revise the corrective action implementation schedule.

The most recent letter on this issue, TXX-88729 of October 20, 1988, provided a completion date of May 1, 1989, for Unit 1 corrective action. This schedule was not met. The new completion date for Unit 1 corrective actions is prior to fuel load for Unit 1. Unit 2 activities will be completed prior to Unit 2 fuel load.

Sincerely,

William J. Cahill, Jr.

WJH/ddm

c - Mr. R. D. Martin, Region IV
Resident Inspectors, CPSES (3)

8907060089 890629
PDR ADCK 05000445
S PNU

JE27
10