



Log # TXX-89620
File # 10110
907.0
Ref. # 10CFR50.55(e)

August 18, 1989

William J. Cahill, Jr.
Executive Vice President

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
LIMITORQUE MOV SPRING PACKS
SDAR: CP-89-021 (INTERIM REPORT)

Gentlemen:

On July 20, 1989, TU Electric verbally notified the NRC of a potential deficiency involving spring packs for motor operated valves (MOV's) supplied by Limtorque which may adversely affect torque switch setpoints and render the MOV's inoperable. This is an interim report of a potentially reportable item under the provisions of 10CFR50.55(e).

The evaluation of the safety impact of this issue on plant operations is continuing. The next report will be issued by Unit 1 fuel load.

Sincerely,

William J. Cahill, Jr.

William J. Cahill, Jr.

By: *Roger D. Walker*
Roger D. Walker
Manager, Nuclear Licensing

FAM/smp

c - Mr. R. D. Martin, Region IV
Resident Inspectors, CPSES (3)

8908220356 890818
PDR ADOCK 05000445
S FDC

*IE27
1/0*