

July 5, 1989

Docket No. 50-346

Mr. Donald C. Shelton
Vice President - Nuclear
Toledo Edison Company
Edison Plaza - Stop 712
300 Madison Avenue
Toledo, Ohio 43652

Distribution

Docket File

NRC & Local PDRs
PDIII-3 r/f
MVirgilio
JHannon
PKreutzer
SBajwa

TWambach
OGC
EJordan
BGrimes
ACRS(10)
Gray File
TMarsh

Dear Mr. Shelton:

SUBJECT: DAVIS-BESSE NUCLEAR POWER STATION - PERFORMANCE TESTING OF
RELIEF AND SAFETY VALVES - NUREG-0737, ITEM II.D.1
(TAC NO. 44572)

The NRC staff and its contractor EG&G, Idaho have completed the review of your submittals identified in the enclosed Technical Evaluation Report (TER) regarding the subject item. Based on the review, the NRC staff has found your responses acceptable and this issue is closed.

Although in Section 3 of the TER there is a statement that you have not evaluated the response of the overpressure protection system during feed and bleed decay heat removal, we acknowledge that, in fact, you have performed the evaluation as described in your letter dated August 8, 1988 (Serial Number 1526). We also understand that you have implemented the inspection and maintenance procedures for the Crosby Safety Valves to be used in the event a water discharge occurs through these valves.

Sincerely,

151

Thomas V. Wambach, Sr. Project Manager
Project Directorate III-3
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

Office: LA/PDIII-3
Surname: PKreutzer
Date: 6/22/89

DW
LPM/PDIV
DWigginton
6/22/89

TW
PM/PDIII-3 EMEB PD/PDIII-3
TWambach/mr TMarsh JHannon
6/22/89 6/30/89 5/89

DF01
11

Mr. Donald C. Shelton
Toledo Edison Company

Davis-Besse Nuclear Power Station
Unit No. 1

cc:

David E. Burke, Esq.
The Cleveland Electric
Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Radiological Health Program
Ohio Department of Health
1224 Kinnear Road
Columbus, Ohio 43212

Mr. Robert W. Schrauder
Manager, Nuclear Licensing
Toledo Edison Company
Edison Plaza
300 Madison Avenue
Toledo, Ohio 43652

Attorney General
Department of Attorney
General
30 East Broad Street
Columbus, Ohio 43215

Gerald Charnoff, Esq.
Shaw, Pittman, Potts
and Trowbridge
2300 N Street N.W.
Washington, D.C. 20037

Mr. James W. Harris, Director
(Addressee Only)
Division of Power Generation
Ohio Department of Industrial Relations
2323 West 5th Avenue
P. O. Box 825
Columbus, Ohio 43216

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois

Ohio Environmental Protection Agency
361 East Broad Street
Columbus, Ohio 43266-0558

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 525, 1700 Rockville Pike
Rockville, Maryland 20852

President, Board of
County Commissioners of
Ottawa County
Port Clinton, Ohio 43452

Resident Inspector
U.S. Nuclear Regulatory Commission
5503 N. State Route 2
Oak Harbor, Ohio 43449

State of Ohio
Public Utilities Commission
180 East Broad Street
Columbus, Ohio 43266-0573