

ADMINISTRATIVE CONTROLS

SEMIANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT (Continued)

The Semiannual Radioactive Effluent Release Reports shall include a list and description of unplanned releases from the site to UNRESTRICTED AREAS of radioactive materials in gaseous and liquid effluents made during the reporting period.

The Semiannual Radioactive Effluent Release Reports shall include any changes made during the reporting period to the PROCESS CONTROL PROGRAM (PCP) and to the OFFSITE DOSE CALCULATION MANUAL (ODCM), pursuant to Specifications 6.13 and 6.14, respectively, as well as any major changes to liquid, gaseous, or Solid Radwaste Treatment Systems pursuant to Specification 6.15. It will also include a listing of new locations for dose calculations and/or environmental monitoring identified by the land use census pursuant to Specification 3.12.2.

MONTHLY OPERATING REPORTS

6.9.1.8 Routine reports of operating statistics and shutdown experience, including documentation of all challenges to the main steam system safety/relief valves, shall be submitted on a monthly basis to the Document Control Desk, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, with a copy to the Regional Administrator of the Regional Office of the NRC, no later than the 15th of each month following the calendar month covered by the report.

Insert

SPECIAL REPORTS

6.9.2 Special reports shall be submitted to the Regional Administrator of the Regional Office of the NRC within the time period specified for each report.

6.10 RECORD RETENTION

6.10.1 In addition to the applicable record retention requirements of Title 10, Code of Federal Regulations, the following records shall be retained for at least the minimum period indicated.

6.10.2 The following records shall be retained for at least 5 years:

- a. Records and logs of unit operation covering time interval at each power level.
- b. Records and logs of principal maintenance activities, inspections, repair, and replacement of principal items of equipment related to nuclear safety.
- c. ALL REPORTABLE EVENTS.
- d. Records of surveillance activities, inspections, and calibrations required by these Technical Specifications and the Fire Protection Program.

8908250272 890817
FDR ADCK 05000461
P FDC

Insert for Page 6-21

CORE OPERATING LIMITS REPORT

6.9.1.9 Core operating limits shall be established and documented in the CORE OPERATING LIMITS REPORT before each reload cycle or any remaining part of a reload cycle. The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC in General Electric Standard Application for Reactor Fuel (GESTAR), NEDE-24011-P-A-8, as amended (latest approved version) and Maximum Extended Operating Domain and Feedwater Heater Out-of-Service Analysis for Clinton Power Station, NEDC-31546P, August 1988. The core operating limits shall be determined so that all application limits (e.g., fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as SHUTDOWN MARGIN, and transient and accident analysis limits) of the safety analysis are met. The CORE OPERATING LIMITS REPORT, including any mid-cycle revisions or supplements thereto, for each reload cycle, shall be submitted upon issuance to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector.