

SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

2.2 LIMITING SAFETY SYSTEM SETTINGS

REACTOR TRIP SETPOINTS

2.2.1 The reactor protective instrumentation setpoints shall be set consistent with the Trip Setpoint values shown in Table 2.2-1.

APPLICABILITY: AS SHOWN FOR EACH CHANNEL IN TABLE 3.3-1.

ACTION:

With a reactor protective instrumentation setpoint less conservative than the value shown in the Allowable Values column of Table 2.2-1, declare the channel inoperable and apply the applicable ACTION statement requirement of Specification 3.3.1.1 until the channel is restored to OPERABLE status with its trip setpoint adjusted consistent with the Trip Setpoint value.

TABLE 2.2-1

REACTOR PROTECTIVE INSTRUMENTATION TRIP SETPOINT LIMITS

FUNCTIONAL UNIT	TRIP SETPOINT	ALLOWABLE VALUES
1. Manual Reactor Trip	Not Applicable	Not Applicable
2. Power Level-High	Not Applicable	Not Applicable
Four Reactor Coolant Pumps Operating	$\leq 9.6\%$ above THERMAL POWER, with a minimum setpoint of $\leq 14.6\%$ of RATED THERMAL POWER.	$\leq 9.7\%$ Above THERMAL POWER, with a minimum of $\leq 14.7\%$ of RATED THERMAL POWER, and a maximum of $\leq 106.7\%$ of RATED THERMAL POWER.
3. Reactor Coolant Flow - Low (1)	$\geq 91.7\%$ of reactor coolant flow with 4 pumps operating*.	$\geq 90.1\%$ of reactor coolant with 4 pumps operating.
4. Reactor Coolant Pump Speed - Low	≥ 830 rpm	≥ 823 rpm
5. Pressurizer Pressure - High	≤ 2400 psia	≤ 2408 psia
6. Containment Pressure - High	≤ 4.75 psig	≤ 5.24 psig
7. Steam Generator Pressure - Low (2) (5)	≥ 680 psia	≥ 672 psia
8. Steam Generator Water Level - Low (5)	$\geq 36.0\%$ Water Level - each steam generator	$\geq 35.2\%$ Water Level - each steam generator
9. Local Power Density - High (3)	Trip setpoint adjusted to not exceed the limit lines of Figures 2.2-1 and 2.2-2 (4).	Trip setpoint adjusted to not exceed the limit lines of Figures 2.2-1 and 2.2-2 (4).

*Design Reactor Coolant flow with 4 pumps operating is the lesser of either:

- The reactor coolant flow rate measured per specification 4.2.6.1, or
- 340,000 gpm

THIS PAGE LEFT BLANK INTENTIONALLY

THIS PAGE LEFT BLANK INTENTIONALLY

MILLSTONE - UNIT 2

3/4 2-8(a)

Amendment No. ~~36, 52, 75, 90, 91, 92, 113, 122~~
139