

George S. Thomas Vice President-Nuclear Production

NYN- 89057

May 8, 1989

United States Nuclear Regulatory Commission Washington, DC 20555

Attention: Document Control Desk

References: a) Facility Operating License NPF-56, Docket No. 50-443

b) PSNH Letter, NYN-87136 dated November 23, 1987. "NUREG-0737, Task II.D.1, Performance Testing of Relief and Safety Valves," G. S. Thomas to USNRC

Subject: NRC Request for Additional Information Regarding NUREG-0737. Item II.D.1

Gentlemen:

In Reference (b), New Hampshire Yankee (NHY) responded to several NRC questions regarding the applicability of performance testing of safety and relief valves by the Electric Power Research Institute (EPRI) and the analyses performed on the Seabrook Station safety and relief valve piping systems.

The NRC Staff has recently requested further additional information from NHY regarding safety and relief valve load combinations, inlet water conditions and pressure settings. Responses to these additional information requests are contained in the Enclosure.

Should you have further questions concerning this response, please contact Mr. Robert E. Sweeney in our Bethesda Office at (301) 656-6100.

Very truly yours,

George S. Thomas

Enclosure

8905120191 890508 PDR ADOCK 05000443 PDC

New Hampshire Yankee Division of Public Service Company of New Hampshire P.O. Box 300 · Seabrook, NH 03874 · Telephone (603) 474-9521

United States Nuclear Regulatory Commission Attention: Document Control Desk May 8, 1989 Page 2

cc: Mr. William T. Russell Regional Administrator United States Nuclear Regulatory Commission Region I 475 Allendale Road King of Prussia, PA 19406

> Mr. Victor Nerses, Project Manager Project Directorate I-3 United States Nuclear Regulatory Commission Division of Reactor Projects Washington, DC 20555

Mr. David G. Ruscitto NRC Senior Resident Inspector P.O. Box 1149 Seabrook Station, NH 03874

Question 1

- a. Confirm that the safety value and relief value discharge loads were combined with earthquake loads.
- b. At what service limit were they combined?
- c. How does Seabrook's loading combinations compare to those in Electric Power Research Institute (EPRI) Report, "PWR Safety and Relief Valve Test Program Guide for Application of Valve Test Program Results to Plant-Specific Evaluation" Interim Report, July 1982, Tables 2A and 2B.

Response

- a. As delineated in Attachment 1 hereto, the safety valve and relief valve discharge loads (TR) were combined with the earthquake loads (OBE and SSE). As discussed in NHY letter NYN-87136 [Reference (b)] in response to RAI 11.E, stresses from individual load cases were, in general, conservatively combined using absolute summation. Justification was also provided to allow the use of Square Root Sum of the Squares (SRSS) method of combination as an option for dynamic loads. (Sge NOTE 6 of Attachment 2 hereto.)
- b. Attachment 2 hereto (Table 2A) has been annotated (shown in parentheses) to delineate the service limits used by NHY. It can be seen that NHY utilized more conservative service limits than required by Table 2A.
- c. All the piping downstream of the pressurizer safety and relief valves is seismically designed and supported: therefore, a comparison of load combinations is made in Attachment 2 hereto with Table 2A only.

Attachment 2 hereto (Table 2A) has been annotated (shown in parentheses) to delineate the corresponding load combinations used by NHY in the design of the discharge system piping downstream of the valves. The applicable service limits used by NHY are also shown (in parentheses) Note, the load combinations, presented in Attachment 1 hereto and Attachment 2 hereto, do not differentiate between the relief valve and safety valve transient loadings. The term TR is used generically to represent transient loading for the piping system under review.

Question 2

.

In demonstrating safety relief valve operability in relatively cooler regimes (i.e., $569^{\circ}F$ to $584^{\circ}F$), how does Seabrook consider effects of its inlet liquid water conditions? Are these inlet conditions still valid? Does WCAP-11677 provide details that show considerations of inlet liquid water conditions at these temperatures and their effects? Please provide WCAP-11677 or relative portions, if possible.

Response

The inlet water conditions used to determine operability of safety relief valves at Seabrook Station are identified in WCAP-11677. The site specific conditions in this report are still valid. A copy of WCAP-11677 is attached hereto as Attachment 3.

Question 3

Reaffirm that Seabrook's safety valve settings were the factory settings used in EPRI test.

Response

The pressure settings were not changed from factory settings of 2,500 psia. These settings were tested by the EPRI test, and the applicability of the test to the Seabrook safety valves was discussed in detail in NHY letter SBN-969 dated March 17, 1986.

Attachment 1 plof 1 0 # 6592 ENGINEERING AND DESIGN PROCEDURES Street Philadelphia Pa 18101 COMPANY PRIVATE DATE OF REVISION PROC NO DATE ORMINAL ISSUE REVISION NO PAGE 62 OF 74 8/20/80 6/10/83 DEDP-2607 2 TABLE 7 2. ANSI B31.1 - NNS-1 SEISMICALLY DESIGNED PIPING SYSTEMS " LOAD COMBINATIONS '6 STRESS LIMITS" STRESS STRESS LOAD SYSTEM COMBINATION LIMITS CATEGORY COMBINATION CONDITION Sh . Pr EQ(3) to EQ(5) DESIGN P S_h P+D Pm + Ph EQ(8) SERVICE SA (A) EQ(10) Pe T OF NORMAL $P_{ii} + P_{ij} + P_{e} = S_{h} + S_{A} (A) = EQ(11)$ P + D + T1.2 Sh (B) EC (9) Pmax + D + TR P. + F. OCCASIONAL (EMERGENCY) Fmay +D+TR+OBE+SAD OBE Pr + Ft 1.8 Sh (c) EQ(9) (UBET) OCCASIONAL AND 11 1.8 Sm(C) EC(9) P +I+TR+SSE+SAD(SSE) F + F. (FAULTED) P- DESIGN PRESSURE OBE - OBE INFRITA D - DEAD WEIGHT SSE - SSE INERTIA T - DESIGN TEMPERATURE SAD (OBE) - SEISMIC ANCHOR DISPLACEMENT (OBE) - PMAX - PEAK PRESSURE SAD(SSE) - SEISMIC ANCHOR TR - VALVE DISCHARGE TRANSIENT DISPLACEMENT (SSE) (SAFETY OR RELIEF) A Barthan Laman

			•	9+	taci	hme	int	2	p10	f 2	
	IN PORTION	Service Stress Limit	A (A)	B (B)	R +08E C (C)	(B) c (B)	AX+D D (C)	(a (conduction	ed in Tables 1-3. conjunction with able 3; or they may	t of downstream non- stegory I portion fro acceptable valve	
A FOR PRESSURIZER SAFE	NLLY DESIGNED DOWNSTREA	Combination	(P+D+T)	SOTU (P+D+TR)	OBE + SOTU (PMAX+D+T +SADIN	SOTE (P+D+TR	MS/FWPB OF DBPB CPM	LOCA & SSE & SOTP + S	pposed criteria contain ginal design basis in c sient definitions in Ta n Tables 1-3.	ically designed portion ssary to isolate the Ca esponse, and to assure	ther load abbreviations
TERE	SMICA	Load	N	+ N	+ N	+ N	+ 2 + 2	+ N	r orig trans	neces neces	to put
OAD COMBINATIONS AND ACCEPTANCE CR	EF VALVE PIPING AND SUPPORTS - SEI	Plant/System Operating Condition	Normal	Upset	Upset	Emergency	Faulted	Faulted	Plants without an PSAR may use the Plants with an FSAR may use their the appropriate system operating use the proposed criteria contain	This table is applicable to the s Category I piping (and supports) the non-selsmically designed pipi loading on the discharge nozzle.	See Table 3 for SOT definitions a
A	RELT	tion							1.1	2.1	3.)
	AND	Combina	1	2	5	*	ŝ	9	NOTES:		

The bounding number of valves (and discharge sequence if setpoints are significantly different) for the applicable system operating transient defined in Table 3 should 8.3

3.)

Verification of functional carrility is not required, but allowable loads and accelerations for the safety/: ...ief valves must be met. be used. 2.1

Use SRSS for combining dynamic load responses. 6.1

WAY, 05 '89' 14:37 BETHESDA LICENSING OFFICE

20'0

TABLE 2A

Attachment 2 p2 of 2

Revision 1

620	1.66	- 10-1		agen,	- 40
-	· 20.	- 164	T.,	9C -	
	1		100	About .	
-	_	_			_

DEFINITIONS OF LOAD ABBREVIATIONS

N	98	Sustained Loads During Normal Plant Operation
SOT	-	System Operating Transient
soru		Relief Valve Discharge Transient (1)
SOTE		Safety Valve Discharge Transient (1)
SOTF		Max (SOTU: SOTE); or Transition Flow
OBE	500	Operating Basis Earthquake
SSE	-	Safe Shutdown Earthquake
MS/FWPB		Main Steam or Feedwater Pipe Break
DBPB		Design Basis Pipe Break
LOCA		Loss of Coolant Accident

- (1) May also include transition flow, if determined that required operating procedures could lead to this condition.
- (2) Although certain transients (for example loss of load) which are classified as a service level B conditions may actuate the safety valves, the extremely low probability of actual safety valve actuation may be used to justify this as a service level C condition with the limitation that the plant will be shut down for examination after an appropriate number of actuations (to be determined on a plant specific basis).
- NOTE: Plants without an FSAR may use the proposed criteria contained in Tables 1-3. Plants with an FSAR may use their original design basis in conjunction with the appropriate system operating transient definitions in Table 3; or they may use the proposed criteria contained in Tables 1-3.