STP FSAR

ATTACHMENT 3 ST-HL-AE-3157 PAGE 7 OF 10

- The reactor is assumed to be at hot zero power. This assumption is more 3. conservative than that of a lower initial system temperature. The higher initial system temperature yields a larger fuel-water heat transfer coefficient, larger specific heats, and a less negative (smaller absolute magnitude) Doppler coefficient, all of which tend to reduce the Doppler feedback effect thereby increasing the neutron flux peak. The initial effective multiplication factor is assumed to be 1.0 since this results in the worst nuclear power transient.
- Two reactor coolant pumps are assumed to be in operation. This lowest 4. 57 initial flow minimizes the initial margin to DNB.
- Reactor trip is assumed to be initiated by power range high neutron flux 5. (low setting). The most adverse combination of instrument and setpoint errors, as well as delays for trip signal actuation and RCCA release, is taken into account. A 10 percent increase is assumed for the power range flux trip setpoint raising it from the nominal value of 25 percent to 35 percent. Since the rise in the neutron flux is so rapid, the effect of errors in the trip setpoint on the actual time at which the rods are released is negligible. In addition, the reactor trip insertion characteristic is based on the assumption that the highest worth RCCA is stuck in its fully withdrawn position. The RCCA insertion time to dashpot 2.8 entry of (2.2) seconds is assumed. * (This is a conservative insertion time) Under the reduced flow conditions that exist when only two reactor coolant pumps are assumed to be in operation. See Section 15.0.5 for additional RCCA insertion characteristics. DISCUSSEDL

DELETE

Q211.6

57

The maximum positive reactivity insertion rate assumed is greater than that for the simultaneous withdrawal of the combination of the two sequential control banks having the greatest combined worth at maximum speed (45 in/min). Control rod drive mechanism (CRDM) design is discussed in Section 4.6.

- 7. The most limiting axial and radial power shapes, associated with having the two highest combined worth banks in their high worth position, are assumed in the departure from nucleate boiling (DNB) analysis.
- The initial power level was assumed to be below the power level expected for any shutdown condition (10° of nominal power). The combination of 8. highest reactivity insertion rate and lowest initial power produces the highest peak heat flux.

A block diagram summarizing various protection sequences for safety actions required to mitigate the consequences of this event is provided in Figure 15.0-15.

Plant systems and equipment which are available to mitigate the effects of the accident are discussed in Section 15.0.8 and listed in Table 15.0-6. No single active failure in any of these systems or equipment will adversely affect the consequences of the accident.

Results

8907130318 890707 PDR ADOCK 05000498

ADD

XAS

5.0.

Figures 15.4-1 through 15.4-3 show the transient behavior for the uncontrolled RCCA bank withdrawal, with the accident terminated by reactor trip at 35 percent of nominal power. The reactivity insertion rate used is greater than that calculated for the two highest worth sequential control banks, both assumed to be in their highest incremental worth region.

Amendment 60

ATTACHMENT ST-HL-AE-3157 STP FSAR PAGE OF 10 NUCLEAR BOWER DELETE Figure 15.4-1 shows the neutron flux transient. The neutron flux does not

overshoot the nominal full power value manna

The energy release and the fuel temperature increases are relatively small. The thermal flux response, of interest for DNB considerations, is shown on Figure 15.4-2. The beneficial effect of the inherent thermal lag in the fuel is evidenced by a heat flux much less than the full power nominal value. There is a large margin to DNB during the transient since the rod surface heat flux remains below the design value, and there is a high degree of subcooling at all times in the core. Figure 15.6-3 shows the response of the hot spot fuel and cladding temperature. The hot spot fuel average temperature increas-es to a value below the nominal full power hot spot value. The minimum DNBR at all times remains above [1.30] - DELETE ADD. 18 THE SAFETY ANALYSIS LIMIT VALUE

The calculated sequence of events for this accident is shown in Table 15.4-1. With the reactor tripped, the plant returns to a stable condition. The plant may subsequently be cooled down further by following normal plant shutdown procedures.

15.4.1.3 Rediological Consequences. There are no radiological conseguences associated with an uncontrolled RCCA bank withdrawal from a subcritical or low power startup condition event since radioactivity is contained within the fuel rods and RCS within design limits.

15.4.1.4 Conclusions. In the event of a RCCA withdrawal accident from the subcritical condition, the core and the RCS are not adversely affected, since the combination of thermal power and the coolant temperature result in a DNBR which is well above the (limiting value of 1.30) Thus, the DNB design besis as described in Section / 4 is met 118

ADD SAFETY ANALYSIS LIMIT VALUE) Uncontrolled Rod Cluster Control Assembly Bank Withdrewal at Power 15.4.2

15.4.2.1 Identification of Causes and Accident Description. Uncontrolled RCCA bank withdrawal at power results in an increase in the core heat flux. Since the heat extraction from the steam generators lags behind the core power generation until the steam generator pressure reaches the relief or safety valve setpoint, there is a net increase in the reactor coolant temperature. Unless terminated by manual or automatic action, the power mismatch and resultant coolant temperature rise could eventually result in DNB. Therefore, in order to evert damage to the fuel clad, the Reactor Trip System (RTS) is designed to terminate any such transient before the DNBR falls below 1.30. 43

This event is classified as an ANS Condition II incident (an incident of moderate frequency) as defined in Section 15.0.1.

The automatic features of the RTS which prevent core damage following the postulated accident include the following:

- Power range neutron flux instrumentation actuates a reactor trip if two 1. out of four channels axceed an overpower setpoint.
- 2. Reactor trip is actuated if any two out of four AT channels exceed an overtemperature AT setpoint. This setpoint is automatically varied with axial power imbalance, coolant temperature and pressure to protect against DNB.

Amendment 57

43

1.44

STP FSAR



Table 15.4-1

TIME SEQUENCE OF EVENTS FOR INCIDENTS WHICH CAUSE REACTIVITY AND POWER DISTRIBUTION ANOMALIES

Accident

Event

Time (sec.)

Uncontrolled Rod Cluster Control Assembly Bank	Initiation of uncontrolled rod withdrawal from 10	0.0	
Withdrawal from a Subcritical or low	mainer power	REPLACE WITH	
Power Startup Condition		NEW	V ALUES
	Power range high neutron flux low setpoint reached	£13.7 }	10.4
	Peak nuclear power occurs	13.8	10.5
	Rods begin to fall into core	14.2	10.9
	Minimum DNBR occurs	15.6	13. D
Mare	Peak average clad temperature occurs	{ 15.6 }	13.4
	eesk heat flux occurs	{15.6	13.0)
	Peak average fuel temperature occurs	15.8	13.6

Uncontrolled RCCA Bank Withdrawal at Power

1. Case A

Initiation of uncontrolled RCCA withdrawal at a high reactivity insertion rate (70 pcm/sec)	0	
Power range high neutron flux high trip point reached	1.7	
Rods begin to fall into core	2.2	
Minimum DNBR occurs	3.0	

*

Amendment 57

57



12.106-66



. . . .

*

(



12



Γ	ATTACHMENT	3		
	ST-HL-AE-31	57		
1	PAGE 6	OF	10	

12.106-67





1



JUN 23 '89 15:04 WEC-EAST 405A

ATTACHMENT 3 ST-HL-AE-3157 PAGE 7 OF 10



23 ·	'89 15:05 WEC-EAST 405A		P.6
		ATTAUMMENT 3 ST-HL-AE-3157 PAGE 9 OF 10	
1	1		
1			
		•	
	STARTUP FROM SUBCRITICAL FOR TOX/THX FUEL AVERAGE TEMPERATURE VS TIME		
2002	NOT NON, 1		
1800.	\bigwedge		
1622		13.4-3	A
E 1400.			
1000			
E 800.			•
600.			
400. 0. E.	10. 15. 20. 25. 80. Time (SEC)	÷	
*	06/2	3/89	

