

July 6, 1989

Project No. 675

APPLICANT: Combustion Engineering Inc.

FACILITY: CESSAR-DC System 80+

SUBJECT: SUMMARY OF MEETING TO DISCUSS STAFF COMMENTS ON THE SYSTEM 80  
BASELINE PRA IN SUPPORT OF THE SYSTEM 80+

On June 6-7, 1989, representatives of the NRC, Brookhaven National Lab (BNL) and Combustion Engineering met in Windsor, Connecticut to discuss concerns resulting from the staff's and BNL's review of the System 80 baseline PRA. The System 80 baseline PRA will be modified to reflect system design enhancements proposed for the System 80+ standard design such as improvements in the electrical distribution system and in the component cooling water system. Enclosure 1 is a list of meeting attendees. Enclosure 2 is the agenda followed during the meeting and the slides presented.

The first part of the meeting was a presentation by CE on the System 80+ standard design. A presentation was then given on the status of the System 80+ PRA and responses to NRC comments on the baseline PRA. CE has made design enhancements in the System 80+ standard design in response to previous comments by the NRC staff. Enclosure 3 provides a summary of the staff's and BNL's comments.

CE indicated they would respond to the staff's concerns discussed during this meeting and forwarded to them by letters dated December 15, 1988 and March 14, 1989. CE indicated that the final PRA for the System 80+ will be made in three submittals starting with the Fall of 1989 and ending in 1990.

In summary, the baseline PRA was generated from a generic BOP because the applicant didn't have sufficient detailed information during its development. Since the scope of the System 80+ has been expanded to include the BOP portions of the plant, CE will upgrade the System 80+ PRA to reflect the final design details of the plant using fault tree analysis methodology. CE indicated that the PRA now reflects changes made in the electrical distribution system and in the component cooling water systems. Other upgrades will be made as the design progresses.

B907140157 890706  
PDR ADDCK 05000470  
A PNU

/s/  
Thomas J. Kenyon, Project Manager  
Standardization and Non-Power  
Reactor Project Directorate  
Division of Reactor Projects - III, IV,  
V and Special Projects

Enclosures:  
As stated

CONTACT:  
T. Kenyon, NRR/PDSNP  
492-1120

DISTRIBUTION:

Central File	OGC	EHylyton
NRC PDR	EJovan	TKenyon
JSniezek	BGrimes	
PDSNP Reading	NRC Participants	
JMonniger	ACRS (10)	

PM:PDSNP  
JMonniger  
07/5/89

PM:PDSNP  
TKenyon:cw  
07/11/89

cm  
D:PDSNP  
CMiller  
07/6/89

QFB

11



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

July 6, 1989

Project No. 675

APPLICANT: Combustion Engineering Inc.

FACILITY: CESSAR-DC System 80+

SUBJECT: SUMMARY OF MEETING TO DISCUSS STAFF COMMENTS ON THE SYSTEM 80  
BASELINE PRA IN SUPPORT OF THE SYSTEM 80+

On June 6-7, 1989, representatives of the NRC, Brookhaven National Lab (BNL) and Combustion Engineering met in Windsor, Connecticut to discuss concerns resulting from the staff's and BNL's review of the System 80 baseline PRA. The System 80 baseline PRA will be modified to reflect system design enhancements proposed for the System 80+ standard design such as improvements in the electrical distribution system and in the component cooling water system. Enclosure 1 is a list of meeting attendees. Enclosure 2 is the agenda followed during the meeting and the slides presented.

The first part of the meeting was a presentation by CE on the System 80+ standard design. A presentation was then given on the status of the System 80+ PRA and responses to NRC comments on the baseline PRA. CE has made design enhancements in the System 80+ standard design in response to previous comments by the NRC staff. Enclosure 2 provides a summary of the staff's and BNL's comments.

CE indicated they would respond to the staff's concerns discussed during this meeting and forwarded to them by letters dated December 15, 1988 and March 14, 1989. CE indicated that the final PRA for the System 80+ will be made in three submittals starting with the Fall of 1989 and ending in 1990.

In summary, the baseline PRA was generated from a generic BOP because the applicant didn't have sufficient detailed information during its development. Since the scope of the System 80+ has been expanded to include the BOP portions of the plant, CE will upgrade the System 80+ PRA to reflect the final design details of the plant using fault tree analysis methodology. CE indicated that the PRA now reflects changes made in the electrical distribution system and in the component cooling water systems. Other upgrades will be made as the design progresses.

A handwritten signature in black ink, appearing to read "T. Kenyon".  
Thomas J. Kenyon, Project Manager  
Standardization and Non-Power  
Reactor Project Directorate  
Division of Reactor Projects - III, IV,  
V and Special Projects

Enclosures:  
As stated

CONTACT:  
T. Kenyon, NRR/PDSNP  
492-1120

ATTENDEES  
PRA MEETING  
CESSAR- DC SYSTEM 80±  
June 6-7, 1989

Name	Organization
T. Kenyon	NRC/NRR/DRSP
S. Ritterbusch	CE Licensing
J. Monninger	NRC/NRR/DRSP
E. Kennedy	CE Licensing
G. Davis	CE Project Manager
C. Bagual	CE ALWR Project Office
D. Finnicum	CE PRA
B. Jaquita	CE PRA
R. Turk	CE ALWR Engineering Manager
R. Matzie	CE ALWR Director
T.L. Chu	BNL
B. Fitzpatrick	BNL
E. Chelliah	NRC/RES

AGENDAMEETING WITH NRC STAFF ON S-80+ PRAJUNE 6 - 7, 1989TUESDAY

9:30	INTRODUCTIONS	S. RITTERBUSCH
9:45	OVERVIEW OF THE SYSTEM 80+ DESIGN	R. MATZIE
10:45	STATUS OF PRA AND RESPONSES TO NRC COMMENTS	D. FINNICUM R. JAQUITH
12:00	LUNCH	
1:00	PRA . . .	
3:00	SUMMARY OF SIR DESIGN	R. TURK

WEDNESDAY

9:00	PRA . . .	
12:00	LUNCH	
1:00	MEETING SUMMARY AND REVIEW OF ACTION ITEMS	S. RITTERBUSCH

MEETING WITH NRC STAFF ON  
SYSTEM 80+ PRA

JUNE 6-7, 1989


OVERVIEW OF THE SYSTEM 80+ DESIGN

R. A. MATZIE  
ALWR PROJECT OFFICE DIRECTOR

## PROGRAM OUTLINE


- 3 START WITH SYSTEM 80 STANDARD DESIGN (DESCRIBED IN CESSAR-F)
- 0 IMPLEMENT CHANGES TO REFLECT:
  - 0 EPRI ALWR REQUIREMENTS DOCUMENT
  - 0 C-E/DUKE DESIRED IMPROVEMENTS
  - 0 NRC SEVERE ACCIDENT POLICY & STANDARDIZATION RULE
- 0 MODIFIED DESIGN SUBMITTED TO NRC, IN STAGES, FOR CERTIFICATION REVIEW
- 0 REVISED DESIGN CALLED SYSTEM 80 PLUS
- 0 REVISED LICENSING DOCUMENT CALLED CESSAR-DC

## C-E ALWR Program



**CERTIFIED SYSTEMS<sup>TM</sup> S0+ DESIGN**

SYSTEMS<sup>TM</sup>



THE SYSTEM 80+ DESIGN PROCESS

SYSTEM 80+

## **SYSTEM 80 ATTRIBUTES**

- 0 PROVEN, STANDARDIZED DESIGN
- 0 ENGINEERED WITH FIVE DIFFERENT BALANCE-OF-PLANT DESIGNS
- 0 IN OPERATION AND SETTING WORLD RECORDS AT PALO VERDE
- 0 FINAL DESIGN APPROVAL FROM NRC
- 0 100% DESIGN DETAIL
- 0 OPERATIONAL FEEDBACK INCORPORATED

**SYSTEM 80**

**DESIGN CERTIFICATION PROGRAM**


**EXPANDED SCOPE**

0 CURRENT SYSTEM 80 DESIGN INCLUDES NUCLEAR STEAM SUPPLY  
SYSTEM (NSSS)

- 0 SYSTEM 80+ DESIGN INCLUDES THE ENTIRE PLANT
- NSSS
  - EMERGENCY FEEDWATER SYSTEM
  - CONTAINMENT
  - ADVANCED CONTROL COMPLEX (NUPLEX 80+)
  - BALANCE OF PLANT

**SENTRY 80+**

SYSTEM 80 PLUS STANDARDIZED PLANT



SYSTEM 80<sup>+</sup>

## WHAT IS NOT IN SYSTEM 80+ SCOPE?

10 CFR 52 STATES:

AN "ESSENTIALLY COMPLETE NUCLEAR PLANT" DESIGN IS ONE THAT INCLUDES "ALL STRUCTURES, SYSTEMS, AND COMPONENTS WHICH CAN AFFECT SAFE OPERATION OF THE PLANT EXCEPT FOR SITE-SPECIFIC ELEMENTS SUCH AS THE SERVICE WATER INTAKE STRUCTURE AND THE ULTIMATE HEAT SINK. THEREFORE, THOSE PORTIONS OF THE DESIGN THAT ARE EITHER SITE SPECIFIC (SUCH AS THE SERVICE WATER INTAKE STRUCTURE OR THE ULTIMATE HEAT SINK) OR INCLUDE STRUCTURES, SYSTEMS, AND COMPONENTS WHICH DO NOT AFFECT THE SAFE OPERATION OF THE FACILITY (SUCH AS WAREHOUSES AND SEWAGE TREATMENT FACILITIES) MAY BE EXCLUDED FROM THE SCOPE OF DESIGN."

NOT INCLUDED IN SYSTEM 80+: (IF SAFETY-RELATED, INTERFACE REQUIREMENTS ARE PROVIDED)

- 0 SERVICE WATER INTAKE STRUCTURE
- 0 ULTIMATE HEAT SINK
- 0 WAREHOUSES
- 0 SEWAGE TREATMENT FACILITIES
- 0 POTABLE AND SANITARY WATER
- 0 SWITCHYARD
- 0 TRAINING FACILITIES
- 0 OFFICE SPACE OUTSIDE THE CONTROL COMPLEX
- 0 EMERGENCY OPERATIONS FACILITY


MAJOR DESIGN FEATURES

OF  
SYSTEM 80 PLUS

- O MORE FORGIVING REACTOR COOLANT SYSTEM
- O ADVANCED CONTROL ROOM DESIGN
- O HIGHLY RELIABLE SAFEGUARDS SYSTEMS
- O LARGE, DRY SPHERICAL CONTAINMENT
- O INTEGRATED DESIGN APPROACH


SYSTEM 80 PLUS REACTOR COOLANT SYSTEM

SYSTEM 80<sup>TM</sup> +



MORE FORGIVING REACTOR COOLANT SYSTEM

1. INCREASED OVERPOWER MARGIN
2. MANEUVERING CONTROL WITHOUT SOLUBLE BORON
3. RING FORGED REACTOR VESSEL
4. LONG LIFE CONTROL RODS
5. LARGER PRESSURIZER
6. 10% STEAM GENERATOR (SG) TUBE PLUGGING MARGIN
7. INCREASED SECONDARY INVENTORY
8. CORROSION RESISTANT SG TUBES
9. SG DESIGNED FOR EASE OF MAINTENANCE
10. REDUCED HOT LEG TEMPERATURE ( $T_H$ )



DESIGN CHANGES TO INCREASE THERMAL MARGIN

CHANGE	APPROX. CHANGE
LOWER COOLANT TEMPERATURE (6F)	3%
HIGHER CORE FLOW RATE (2X)	2%
COLSS/CPC IMPROVEMENTS	4%
ADVANCED INTEGRAL B.P. (OPTIONAL)	2%
	<hr/>
	9 - 11%


NET THERMAL MARGIN FOR SYSTEM 80+ (TYPICAL)

INITIAL CORE  
RELOAD CORES

18 - 20%  
15 - 17%

SHENZHEN 0045

CONTROL ELEMENT ASSEMBLY PATTERN



12 ELEMENT FULL STRENGTH CEA

4 ELEMENT FULL STRENGTH CEA





4 ELEMENT PART STRENGTH CEA

DENOTES SPARE CEA LOCATIONS  
FOR OPEN MARKET PLUTONIUM  
RECYCLE

SHEET 60 +







# 1

## IMAGE EVALUATION TEST TARGET (MT-3)






# 1

## IMAGE EVALUATION TEST TARGET (MT-3)




# 1

## IMAGE EVALUATION TEST TARGET (MT-3)



# 1


## IMAGE EVALUATION TEST TARGET (MT-3)



CONTROL ELEMENT ASSEMBLY DESIGN CHANGE COMPARISON

CEA TYPE	SYSTEM 80		SYSTEM 80+	
	NUMBER	ABSORBER	NUMBER	ABSORBER
FULL STRENGTH (12-FINGER)	43	B <sub>4</sub> C	48	B <sub>4</sub> C
FULL STRENGTH (4-FINGER)	28	B <sub>4</sub> C	20	AG-IW-CU
PART LENGTH (4-FINGER)	13	B <sub>4</sub> C	--	--
PART-STRENGTH (4-FINGER)	--	--	25	INCOMET
TOTAL	89	10-YEAR LIFE	93	20-YEAR LIFE


SWEET BUD +



SYSTEM 80+ REACTOR VESSEL

SYSTEM 80+

SYSTEM 80 REACTOR VESSEL COMPARISON



SYSTEM 80<sup>++</sup>

PRESSURIZER SIZE  
(2400 FT<sup>3</sup>)


- 0 MAJOR DESIGN BASES FOR INCREASING VOLUME
  - PREVENT DRAINING PRESSURIZER FOLLOWING A REACTOR TRIP
  - MAINTAIN PRESSURIZER WATER LEVEL BELOW SAFETY VALVE NOZZLES FROM FEEDWATER LINE BREAK
  - MAINTAIN PRESSURIZER WATER LEVEL ABOVE HEATERS FOR TURBINE TRIP
  - MINIMIZE PRESSURIZER FLUCTUATIONS DURING TRANSIENTS

STANLEY J. COOPER

**COMPARATIVE PRESSURIZER SIZING**

PLANT	NORMALIZED PRESSURIZER VOLUME (FT <sup>3</sup> /MM <sup>3</sup> )	PRESSURIZER VOLUME TO RCS VOLUME
PALISADES	0.682	16.0%
AN0-2	0.425	13.7%
SONGS 2 & 3	0.440	14.6%
PALO VERDE	0.472	14.7%
YGN 384	0.637	15.5%
SYSTEM 80+	0.629	19.4%

**SYSTEM 80+**



SYSTEM 80+ STEAM GENERATOR ENHANCEMENTS

SYSTEM 80+

## STEAM GENERATOR ENHANCEMENTS

- INCREASED DOWNCOMER VOLUME ..... INCREASES "BOIL-DRY" TIME, AND REDUCES LEVEL FLUCTUATIONS DURING TRANSIENTS; 20% INCREASE IN SECONDARY INVENTORY
- IMPROVED TUBE INTEGRITY ..... INCONEL 690 TT AND RECIRCULATION SYSTEM
- LOWER Head ..... 615F INCREASES THERMAL MARGIN, REDUCES LOCAL WATERSIDE CORROSION, AND INCREASES TUBE CORROSION RESISTANCE
- INCREASED HEAT TRANSFER AREA ..... PROVIDES 10% TUBE PLUGGING MARGIN
- IMPROVED ACCESS FOR MAINTENANCE ..... LARGER (21") REPOSITIONED MANWAYS; INCREASED SPACE BETWEEN DRIERS AND SEPARATORS
- IMPROVED DRYERS ..... 99.9% QUALITY STEAM
- REPOSITIONED DOWNCOMER DISTRIBUTION RING ..... AVOID WATERHAMMER


STANLEY 100+

ADVANCED CONTROL ROOM DESIGN


- 0 HUMAN FACTORS ENGINEERED
- 0 LARGE IPSO DISPLAY SCREEN
- 0 TOUCH-SENSITIVE CRTS & PLASMA DISPLAYS
- 0 MICROPROCESSORS TO REDUCE OPERATOR BURDEN
- 0 HIERARCHY OF INFORMATION
- 0 PRIORITIZED AND MODE DEPENDENT ALARMS
- 0 VALIDATED SIGNALS
- 0 MULTIPLEXING
- 0 OFF-THE-SHELF EQUIPMENT
- 0 SELF-TESTING FEATURES

## ADVANCED CONTROL COMPLEX


### DATA PROCESSING SYSTEM



### CONTROL CENTER PANEL



### PLANT WIDE INTEGRATION




PLANT PROTECTION SYSTEM AND ALARM SYSTEM      COMPONENT CONTROL SYSTEM


## MULTEX 80+

## MULTEX 80+<sup>+</sup>

NUPLEX 80+ CONTROL ROOM

NUPLEX  
80+






©1989 Combustion Engineering, Inc.

## SYSTEM 80 PLUS CONTROL ROOM

SYSTEM 80 +



©1989 Combustion Engineering, Inc.

## INTEGRATED PROCESS STATUS OVERVIEW DISPLAY

SYSTEM 80+





FIGURE 10.7.1-1  
INTEGRATED INFORMATION PRESENTATION

PRESSURIZER PRESSURE



©1989 Combustion Engineering, Inc.

CRT DISPLAY FOR PRESSURIZER INFORMATION

SYSTEM 80 +

NUPLEX 80+ DESIGN BASIS  
FOR  
DISPLAY AND ALARM

1. REDUCE THE QUANTITY OF DATA THAT MUST BE MENTALLY PROCESSED BY AN OPERATOR, TO MINIMIZE "INFORMATION OVERLOAD":
  - o SIGNAL VALIDATION PRIOR TO DISPLAY
  - o REDUCE DATA THROUGH PARAMETER CORRELATION PRIOR - TO DISPLAY
2. DISPLAY INFORMATION USING HIERARCHICAL PRESENTATION:
  - o PLANT LEVEL OVERVIEW INFORMATION ON IPSO
  - o KEY SYSTEM PARAMETERS ON DISCRETE INDICATORS
  - o THREE-LEVEL CRT DISPLAY PAGE HIERARCHY

3. REDUCE THE NUMBER OF ALARMS GENERATED TO MINIMIZE OPERATOR "INFORMATION OVERLOAD":
  - o CROSS-CHANNEL SIGNAL VALIDATION PRIOR TO ALARM GENERATION
  - o ALARM LOGIC AND SETPOINTS CONTINGENT ON APPLICABLE PLANT MODE
4. DISPLAY ALARM WITH DISTINCT VISUAL CUEING IN ACCORDANCE WITH PRIORITY OF OPERATOR RESPONSE:
  - o PRIORITY 1 - IMMEDIATE ACTION
  - o PRIORITY 2 - PROMPT ACTION
  - o PRIORITY 3 - CAUTION
  - o OPERATOR AID - STATUS INFORMATION


5. ALLOW AN OPERATOR TO USE THE DISPLAYS DURING ACCIDENTS THAT HE USES DURING NORMAL OPERATION.
  - o SEISMICALLY QUALIFIED INDICATORS CORRELATE NORMALLY USED SENSORS TO PAMI SENSORS
  - o SPDS IS INTEGRATED IN NORMAL CRT DISPLAY SYSTEMS
6. PROVIDE REDUNDANCY AND DIVERSITY IN INFORMATION PROCESSING AND DISPLAY.
  - o INFORMATION REQUIRED FOR OPERATION FOR 24 HOURS WITHOUT DPS IS ALSO PROCESSED AND DISPLAYED BY DIAS
  - o TWO SYSTEM REDUNDANCY IS INVISIBLE TO OPERATORS THROUGH CONTINUOUS CROSS-CHECKING AND INTEGRATED OPERATOR INTERFACES
  - o PRIORITY 1 AND 2 ALARMS ARE PROCESSED AND DISPLAYED BY TWO INDEPENDENT SYSTEMS

80000

## DISCRETE INDICATOR

NuTecX 80+

PZR PRESS




DISCRETE INDICATOR SHOWN AND NORMALLY BRACKETED  
VALUES FOR PRESSURE AND LEVEL

## DISCRETE INDICATOR VALIDATION APPLICATION

PRESSURIZED SENSORS	PRESSURE RANGE	CONVENTIONAL CONTROL ROOM INDICATION
P-103	0 - 1600 psia	RECORDER
P-104	"	"
P-105	"	"
P-106	"	"
P-101A	1600 - 2500 psia	INDICATOR
B	"	"
C	"	"
D	"	"
P-100X	1500 - 2500	INDICATOR
Y	"	"
P-190A	0 - 4000	RECORDER
Z	"	"

PLEX 80+

PLEX 80+




80+


HIGHLY RELIABLE SAFEGUARDS SYSTEMS

- 0 4 TRAIN EMERGENCY CORE COOLING SYSTEM
- 0 IN-CONTAINMENT REFUELING WATER TANK
- 0 SAFETY DEPRESSURIZATION SYSTEM
- 0 4 TRAIN EMERGENCY FEEDWATER SYSTEM
- 0 HIGHER PRESSURE SHUTDOWN COOLING SYSTEM
- 0 ALTERNATE EMERGENCY POWER SUPPLY

ENGINEERED SAFETY FEATURES SYSTEM  
(Safety Injection System)




SYSTEM 80+



SAFETY DEPRESSURIZATION AND VENT SYSTEM


SYSTEM 80+



**SYSTEM 80<sup>+</sup>**

EMERGENCY FEEDWATER SYSTEM

**ENGINEERED SAFETY FEATURES SYSTEM**  
(Shutdown Cooling & Containment Spray System)



**SYSTEM 80+**<sup>TM</sup>

**SYSTEM 80+**

**AUXILIARY SYSTEMS**

**NON-SAFETY CHEMICAL AND VOLUME CONTROL SYSTEM**

**CENTRIFUGAL CHARGING PUMPS**

**IMPROVED LETDOWN**


**SYSTEM 80+**

**ENHANCEMENT FEATURES**

LARGE STEEL SPHERICAL CONTAINMENT

- o DUAL CONTAINMENT
- o 200 FT. DIAMETER
- o INCREASED SPACE FOR MAINTENANCE & ACCESS
- o DESIGNED TO MITIGATE SEVERE CORE DAMAGE
- o SHADOW AREA HOUSES SAFEGUARDS SYSTEMS


SYSTEM 80+



©1989 Combustion Engineering, Inc.

CONTAINMENT BUILDING - ELEVATION VIEW

SYSTEM 80+



©1989 Combustion Engineering, Inc.

CONTAINMENT BUILDING - PLAN VIEW

SYSTEM 80+

CESSAR-DC SUBMITTAL SCHEDULE

0	GROUP A	-	NOVEMBER 1987
0	GROUP B	-	APRIL 1988
0	GROUP C	-	JUNE 1988
0	GROUP D	-	SEPTEMBER 1988
0	GROUP E	-	MARCH 1989 (END OF DESIGN PHASE)
0	GROUP F	-	SEPTEMBER 1989
0	GROUP G	-	JUNE 1990
0	GROUP H	-	SEPTEMBER 1990 (END OF ANALYSIS)

## CESSAR-DC SUBMITTAL GROUP CONTENTS

- A. GENERAL DESCRIPTIONS AND REQUIREMENTS, POWER CONVERSION SYSTEM, QUALITY ASSURANCE
- B. REACTOR CORE, REACTOR COOLANT SYSTEM, CHEMICAL AND VOLUME CONTROL SYSTEM, PROCESS SAMPLING SYSTEM
- C. SHUTDOWN COOLING SYSTEM, SAFETY INJECTION SYSTEM, EMERGENCY FEEDWATER SYSTEM
- D. SITE ENVELOPE, SAFETY DEPRESSURIZATION SYSTEM, INSTRUMENTATION AND CONTROL SYSTEMS, HUMAN FACTORS ENGINEERING
- E. CONTAINMENT SYSTEMS, LEAK-BEFORE-BREAK EVALUATION, REACTOR PROTECTIVE SYSTEM, ELECTRIC POWER, FUEL HANDLING SYSTEMS, RAD. WASTE SYSTEM, SABOTAGE PROTECTION, NUPLEX 80+ EVALUATION
- F.\* USI/GI RESOLUTION
- G.\* CONTAINMENT DESIGN AND SEISMIC ANALYSES, PROBABILISTIC RISK ASSESSMENT, DEGRADED CORE PERFORMANCE
- H. SAFETY ANALYSES, TECHNICAL SPECIFICATIONS

---

\* INCLUDING RESULTS OF THE CESSAR-DC INTEGRATED REVIEW FOR NSSS AND BOP SYSTEMS.

SYSTEM 80+

## SYSTEM 80+ CERTIFICATION SCHEDULE

	1987	1988	1989	1990	1991	1992	
CESSAR DC SUBMITTALS							SAR PREPARATION
GENERAL DESCRIPTION							NRC REVIEW
REACTOR COOLANT SYSTEM							
SAFETY SYSTEMS							
ARRANGEMENTS, I&C							
AUXILIARY SYSTEMS							
SAFETY ANALYSES							FDA
INTEGRATED NRC REVIEW							
RULE MAKING							
CERTIFICATION							

**SYSTEM 80+**

SYSTEM 80+ PRA  
STATUS

JUNE 6 - 7, 1989

COMBUSTION ENGINEERING  
AND

BROOKHAVEN NATIONAL LABORATORY

SYSTEM 80+

**TASK 3**

**PERFORM PROBABILISTIC RISK ASSESSMENT**

**TASK OBJECTIVE**

- o COMPLY WITH SEVERE ACCIDENT POLICY STATEMENT REQUIREMENT FOR PRA BY PROVIDING A LEVEL III PRA FOR ADVANCED SYSTEM 80 DESIGN
- o DEMONSTRATE COMPLIANCE WITH EPRI ALMR MEAN CORE DAMAGE FREQUENCY GOAL OF  $10^{-5}$ /YR.
- o DEMONSTRATE COMPLIANCE WITH LARGE RELEASE GOAL OF  $10^{-6}$ /YR.
- o SUPPORT EVALUATION OF DESIGN CHANGES

*System 80+*

## SYSTEM 80+ PRA

### PROBABILISTIC RISK ASSESSMENT

#### APPROACH

- o ESTABLISH BASELINE PRA FOR SYSTEM 80
- o USE PRA AS EVALUATION TOOL FOR ASSESSMENT OF DESIGN CHANGES
- o PREPARE LEVEL III PRA FOR SYSTEM 80+

SYSTEM 80+  
+

SYSTEM 80+ PRA

DESIGN ISSUES ADDRESSED  
IN FIRST HALF OF FISCAL 1989

- o COOLING WATER SYSTEM DESIGNS
- o ELECTRICAL DISTRIBUTION SYSTEM

SIZE-**80+**

## SYSTEM 80+ PRA

### COOLING WATER SYSTEM DESIGN

- o BASELINE PRA USED STANDS~~Y~~ SYSTEM FOR COOLING SAFETY RELATED LOADS
  - 2 TRAINS, 1 Pump/TRAIN
  - SEPARATE SYSTEM SUPPLIED NON-SAFETY LOADS
- o SYSTEM 80+ USES A COMBINED SYSTEM TO SUPPLY SAFETY AND NON-SAFETY LOADS
  - 2 DIVISIONS, 2 Pumps/DIVISION, 1 Pump/DIVISION NORMALLY OPERATING
  - NON-SAFETY LOADS SHED ON SAFEGUARDS ACTUATION
  - SELECTED BASED ON SENSITIVITY ANALYSES BY DUKE AND AKSAP
  - CONSISTENT WITH EPRI REQUIREMENTS
- o IMPACT OF SELECTED COOLING WATER SYSTEM DESIGN ON PRA
  - SYSTEM MORE RELIABLE SOURCE OF COOLING FOR SAFETY LOADS,
  - NEW INITIATING EVENT TO BE ADDRESSED, OPERATING FAILURE CAN CAUSE TRIP AND IMPAIR SAFEGUARDS SYSTEMS

→ SYSTEM 80+

**SYSTEM 80+ PRA**

**ELECTRICAL DISTRIBUTION SYSTEM**

- o NEW ELECTRICAL DISTRIBUTION SYSTEM DESIGN SELECTED
  - COMPATIBLE WITH EPRI REQUIREMENTS
  - SLIGHT MODIFICATIONS SUGGESTED DUKE AND C-E
- o DIFFERS FROM SYSTEM DESIGN ASSUMED FOR BASELINE PRA
  - 1 LESS GRID SUPPLY LINE
  - 13.8 KV LEVEL IN SUPPLY TO ESF BUSSES ELIMINATED
  - NUMBER OF 480V LOAD CENTERS REDUCED
  - 6 CLASS 1E 125 VDC BUSSES INSTEAD OF 4
  - EACH DG HAS DEDICATED BATTERY FOR START & CONTROL
  - 2 125 VDC CONTROL POWER SOURCES FOR EACH ESF COMPONENT

*ESF 80+*

**SYSTEM 80+ PRA**

**ELECTRICAL DISTRIBUTION SYSTEM DESIGN CHANGE IMPACT ON PRA**

- o USE OF THE ALTERNATE AC SOURCE WILL BE TREATED AS RECOVERY ACTION
  - FACTOR OF .1 FOR LOSS OF POWER CUTSETS
- o RE DO ALL ELECTRICAL SUPPLY SYSTEM MODELS
  - FRONT LINE SYSTEM MODELS AND EVENT SEQUENCES NOT REQUANTIFIED YET
- o ANTICIPATE SLIGHT IMPROVEMENT IN SYSTEM RELIABILITIES

**SIZE 80+**

SYSTEM 80+ PRA  
PRELIMINARY CORE DAMAGE FREQUENCY  
BY  
INITIATING EVENT

<u>INITIATING EVENT</u>	CORE DAMAGE FREQUENCY <u>(WITH RECOVERY)</u>
LARGE LOCA	2.52E-7
MEDIUM LOCA	2.88E-7
SMALL LOCA	4.33E-8
LOSS OF FEEDWATER	3.48E-8
LOSS OF CONDENSER VACUUM	6.71E-9
OTHER TRANSIENTS	1.10E-7
STEAMLINE BREAKS	1.04E-9
S.G. TUBE RUPTURE	1.68E-7
LOSS OF OFFSITE POWER	4.42E-7
ATWS	2.14E-7**
LOSS OF CCW/SW	3.98E-8
LOSS OF 125 VDC Bus	5.00E-8**
INTERFACING SYSTEM LOCA	1.00E-7**
TOTAL	1.75E-6

\* NO RECOVERY

\*\* ESTIMATED

SYSTEM 80+ PRA

OVERALL CORE DAMAGE FREQUENCY

INTERNAL EVENTS	1.75E-6
SEISMIC	7.9E-6
TORNADO STRIKE	3.1E-7
TOTAL	9.96E-6

CORE DAMAGE FREQUENCY (PER  $10^6$  YEARS)



ALWR WITHOUT CSS & SDCS INTERCONNECTIONS

ALWR WITHOUT SIS IMPROVEMENTS

ALWR WITH RWST OUTSIDE CONTAINMENT

ALWR WITHOUT SDS

ALWR WITH ALL EXCLUSIONS

connection

CORE DAMAGE FREQUENCY  
(WITH ESTIMATED RECOVERY)

	ALWR	ALWR W/O SDS	ALWR W/O HPSI IMP.	ALWR W/RWST OUTSIDE CTMT	ALWR W/O CSS & RHR INTERCON.
LARGE LOCA	2.52E-7	2.48E-7	2.52E-7	7.01E-7	2.48E-7
MEDIUM LOCA	2.88E-7	2.88E-7	3.94E-7	7.62E-7	2.88E-7
SMALL LOCA	4.13E-8	4.34E-8	1.27E-7	3.90E-7	7.02E-8
STGR	1.68E-7	4.45E-7	5.10E-7	5.10E-7	2.72E-7
LOSS OF OFF-SITE POWER	4.42E-7	3.91E-7	6.71E-7	7.38E-7	4.38E-7
LOSS OF CLG WATER	3.98E-8	2.63E-5	7.55E-8	7.84E-8	1.48E-7
ATWS	2.16E-7	2.12E-7	2.37E-7	2.38E-7	2.29E-7
LOSS OF FEED-WATER	3.48E-8	1.26E-6	5.55E-8	5.70E-8	9.75E-8
OTHER TRAN-SIENTS	1.17E-7	2.78E-7	1.46E-7	1.51E-7	1.38E-7
LARGE SEC. SIDE BREAK	1.04E-9	7.42E-8	1.42E-9	3.66E-9	2.30E-9
TOTAL	1.60E-6	2.95E-5	2.47E-6	3.63E-6	1.93E-6

congestion)

**IMPACT OF SUPPORT SYSTEMS  
ON CORE MELT FREQUENCY**

<u>INITIATING EVENT</u>	<u>Core Melt frequency</u>	<u>SYSTEM 80</u>	<u>SYSTEM 80+</u>	<u>SYSTEM 80+</u>	<u>SYSTEM 80+</u>
		<u>BASELINE</u>	<u>OLD COOLING</u>	<u>NEW COOLING</u>	<u>NEW ELECTRICAL</u>
Large LOCA	$1.57 \times 10^{-6}$ /year	$6.83 \times 10^{-7}$ /year		$2.52 \times 10^{-7}$ /year	$1.31 \times 10^{-7}$ /year
Medium LOCA	$3.59 \times 10^{-6}$ /year	$7.43 \times 10^{-7}$ /year		$2.88 \times 10^{-7}$ /year	
Small LOCA	$9.40 \times 10^{-6}$ /year	$1.22 \times 10^{-7}$ /year		$4.33 \times 10^{-8}$ /year	$6.10 \times 10^{-9}$ /year
Steam Generator Tube Rupture	$1.05 \times 10^{-5}$ /year	$2.66 \times 10^{-7}$ /year		$1.68 \times 10^{-7}$ /year	
Loss of Offsite Power	$3.78 \times 10^{-5}$ /year	$5.10 \times 10^{-7}$ /year		$4.42 \times 10^{-7}$ /year	
Transients	$1.17 \times 10^{-5}$ /year	$1.85 \times 10^{-7}$ /year		$1.52 \times 10^{-7}$ /year	$2.91 \times 10^{-8}$ /year
Loss of Cooling Water	N/A	N/A		$3.98 \times 10^{-7}$ /year	
Large Secondary Side Breaks	$9.04 \times 10^{-7}$ /year		$4.81 \times 10^{-9}$ /year		$1.04 \times 10^{-9}$ /year
ATWS	$4.79 \times 10^{-6}$ /year		$2.14 \times 10^{-7}$ /year	$2.14 \times 10^{-7}$ /year	$2.14 \times 10^{-7}$ /year
<b>TOTAL</b>		$8.02 \times 10^{-5}$ /year	$2.73 \times 10^{-6}$ /year		$1.60 \times 10^{-6}$ /year

**SYSTEM 80+ PRA**  
**ARSAP SUPPORT**

- o EXTERNAL EVENT EVALUATION
  - QUALITATIVE EVALUATION ELIMINATED ALL BUT SEISMIC AND TORNADO STRIKE
  - PRELIMINARY QUANTIFICATION
    - . TORNADO STRIKE                     $3.1E-7/\text{YR}$
    - . SEISMIC                               $7.9E-6/\text{YR}$
- o PROVIDING ASSISTANCE IN LEVEL II ANALYSES

**SYSTEM 80+<sup>+</sup>**

**SYSTEM 80+ PRA**

**LEVEL III ANALYSES**

- o PROCESS DEFINE
- o PLANT DAMAGE STATE PARAMETERS DEFINED
- o DRAFT SET OF PLANT DAMAGE STATES DEFINED
  - THIRD PASS
  - IN REVIEW BY DUKE AND ARSAP
  - 216 PRELIMINARY DAMAGE STATES
- o PRELIMINARY DRAFT OF CONTAINMENT EVENT TREE PROVIDED BY DUKE

*Version 004*

**SYSTEM 80+ PRA**

**PLANT DAMAGE STATE PARAMETERS**

- 0    IN-VESSEL PRESSURE AT CORE MELT
- 0    RCS LEAK RATE
- 0    POINT OF RELEASE (OF RCS INVENTORY)
- 0    SECONDARY SIDE HEAT REMOVAL STATUS
- 0    CONTAINMENT SCRUBBING
- 0    CONTAINMENT HEAT REMOVAL
- 0    CAVITY CONDITION
- 0    CONTAINMENT ISOLATION

**SYSTEM 80+**

## BNL REVIEW CONCERNS

- o INITIATING EVENTS
  - INTERFACING SYSTEMS LOCA (ITEM 2.A)
  - LOSS OF SECONDARY COOLING (ITEM 2.B, TABLE 1)
  - PLANT OPERATIONAL STATES (ITEM 2.C)
  - LOSS OF OFF-SITE POWER/SBO (ITEM 2.D)
- o METHODOLOGY
  - CONDITIONAL SYSTEM FAILURE PROBABILITIES VERSUS FAULT TREE LINKING (ITEM 3)
- o SYSTEM ANALYSIS AND ACCIDENT SEQUENCE ANALYSIS
  - AC POWER AVAILABILITY AND RECOVERY (ITEM 4.A)
  - ALTERNATE SECONDARY HEAT REMOVAL (ITEMS 4.A, 4.B)
  - AGGRESSIVE SECONDARY SIDE COOLDOWN (ITEM 4.B)
  - COPIES OF FAULT TREES (ITEM 4.C)
  - WHERE ARE HUMAN ACTIONS ADDRESSED IN MODELS (ITEM 4.D)
  - DOCUMENTATION OF SUCCESS CRITERION AND MISSION TIME (ITEM 4.E)
  - IMPACT OF SUPPORT SYSTEMS ON DOMINANT CORE DAMAGE SEQUENCES (ITEM 4.F)
  - CONDITIONAL UNAVAILABILITY OF ESFAS SIGNALS (ITEM 4.G)
  - TREATMENT OF SGTR (ITEM 4.H)

EMERGENCY  
00+

BNL REVIEW CONCERNs  
INITIATING EVENTS

- o INTERFACING SYSTEMS LOCA
  - METHODOLOGY BEING REVIEWED
  - NEW ANALYSIS FOR SYSTEM 80+
- o LOSS OF SECONDARY COOLING
  - NOT APPROPRIATE FOR SYSTEM 80 BASELINE (STANDBY SAFETY SYSTEM)
  - INCLUDED FOR SYSTEM 80+ BECAUSE OF DESIGN CHANGE
- o LOSS OF OFF-SITE POWER/SBO
  - LOSS OF OFF-SITE POWER AND SBO SEQUENCES COMBINED
    - BETTER TREATMENT OF DIESEL GENERATOR CONFIGURATION
    - EASIER RECOVERY ANALYSIS
  - POST-TRIP LOOP/SBO LIKE SEQUENCES COVERED IN ALL OTHER EVENT SEQUENCES

SYSTEM 80+

BNL REVIEW CONCERNS  
INITIATING EVENTS (CONT'D)

- o SPECIAL INITIATORS
  - GROUND RULES A) CAUSE TRANSIENT  
                  B) DISABLE SAFETY SYSTEMS
  - "LOSS OF 125VDC BUS", "LOSS OF 4.16 KV BUS" INCLUDED
  - "LOSS OF INSTRUMENT AIR", "LOSS OF 480 VAC BUS" NOT INCLUDED
- o PLANT OPERATIONAL STATES
  - ONLY POWER OPERATION COVERED

SYSTEM 60+

BNL REVIEW CONCERNs  
METHODOLOGY

o CONDITIONAL SYSTEM FAILURE PROBABILITY APPROACH

- USE FOR SYSTEM 80 BASELINE
- PROVIDES ESTIMATE OF CORE DAMAGE FREQUENCY AND DOMINANT CONTRIBUTORS
- CONSISTENT WITH LEVEL OF DETAIL FOR GENERIC BOP USED FOR SYSTEM 80 BASELINE

o FAULT TREE LINKING

- USED FOR SYSTEM 80+
- PROVIDES CORE DAMAGE CUTSETS  
    NEEDED FOR EXTENSION TO LEVEL 2 ANALYSES
- EASIER RECOVERY ANALYSIS
- BETTER EVALUATION OF IMPACT OF SUPPORT SYSTEMS
- REQUIRES MORE DETAIL

SYSTEM 80+

BNL REVIEW CONCERNS  
SYSTEM ANALYSIS AND ACCIDENT SEQUENCE ANALYSIS

- o AC POWER AVAILABILITY AND RECOVERY
  - ELECTRICAL POWER EXPLICITLY MODELED FOR ALL SYSTEMS
  - LOOP AND SBO SEQUENCES COMBINED
  - FAULT TREE LINKING USED
  - RECOVERY AT CUTSET LEVEL
  - SEQUENCE DEPENDENT RESTORATION TIMES USED
  - RESTORATION PROBABILITIES FROM EPRI KEY ASSUMPTIONS AND GROUND RULES DOCUMENT
- o ALTERNATE SECONDARY HEAT REMOVAL
  - NOT POSSIBLE FOR SYSTEM 80+
  - STARTUP FEEDWATER PUMP EXPLICITLY MODELED

BNL REVIEW CONCERNS  
SYSTEM ANALYSIS AND ACCIDENT SEQUENCE ANALYSIS (CONT'D)

O DOCUMENTATION RELATED

- 3 TIERS FOR SYSTEM 80+ PRA
  - A) CESSAR-DC SUMMARY
  - B) PRA REPORT
  - C) SUPPORTING FILES
- SYSTEM 80+ PRA REPORT WILL CONTAIN ALL FAULT TREE MODELS AND SEQUENCES
- DOMINANT CUTSET FOR TOP FAULT TREES AND SEQUENCES WILL BE INCLUDED
- MISSION TIMES/SUCCESS CRITERIA SPECIFIED IN REPORT, DOCUMENTED BY REFERENCE

SYSTEM 80+

NRC STAFF AND BNL COMMENTS  
TO CE

- 1) When using the IRRAS II code for PRA, concern was expressed over whether IRRAS II was capable of handling large fault trees.
- 2) CE was asked to submit two selected fault trees for one sequence for auditing purposes.
- 3) The baseline PRA was generated from a generic BOP and didn't have sufficient detailed information. CE indicated that the System 80+ PRA would include design details of the plant including the BOP.
- 4) What are the special features that allow CE to meet the proposed safety goal of 25 rem beyond a one-half mile radius following a large release of radiation due to core melt?
- 5) CE should ensure that all potential problems and event sequences caused by the addition of new features have been addressed to ensure that new problem have not been introduced by such features.
- 6) CE should justify the use of the IRRAS II code and address the potential for non-conservative results.
- 7) How did CE model the common mode failures? Please provide additional documentation.
- 8) CE should include maintenance unavailability estimates. The PRA should provide some unavailability estimates for the most adverse train.
- 9) Since the Technical Specifications for the System 80+ are to be based on reliability assumptions, CE should ensure the assumptions used for developing the PRA and the Technical Specifications are the same.
- 10) Provide documentation on how each initiating event affects plant systems and response.
- 11) The frequency of the loss of offsite power seems low. CE should make use of site parameters.
- 12) Discuss any dependency of the actuation signals in the reactor protection system.
- 13) Discuss the impacts of single steam generator tube rupture verse multiple steam generator tube ruptures.
- 14) In the steam generator tube rupture event tree, CE should modify this event tree to account for ATWS sequence.
- 15) The NRC staff indicated that CE could request a copy of the risk codes currently used by the staff.
- 16) CE should provide an electrical power system distribution list including various electrical loads connected to the 125V and 4180V buses.