

AUG 22 1989

Docket No. 50-317
50-318

Baltimore Gas and Electric Company
ATTN: Mr. George C. Creel
Vice President
Nuclear Energy
Calvert Cliffs Nuclear Power Plant
MD Rts 2 & 4, P.O. Box 1535
Lusby, Maryland 20657

Gentlemen:

Subject: NRC Inspection No. 50-317/89-17 and 50-318/89-18

This letter refers to the routine safety inspection conducted by Mr. J. F. Lara of this office on July 17-21, 1989 at the Calvert Cliffs Units 1 and 2, Lusby, Maryland of activities authorized by NRC License Nos. DPR-53 and DPR-69 and to the discussions of our findings held by Mr. Lara with Mr. L. Russell at the conclusion of the inspection.

Areas examined during this inspection are described in the NRC Region I Inspection Report which is enclosed with this letter. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspectors.

Within the scope of this inspection, no items of noncompliance were observed. However, one activity appears to be a deviation from the Calvert Cliffs FSAR regarding the sampling and testing of emergency diesel generator fuel oil. This deviation is set forth in the Notice of Deviation, enclosed herewith as Appendix A. You are requested to respond to this letter and in preparing your response, you should follow the instructions in Appendix A.

Our inspector also noted that one of the corrective actions being considered for this deviation was to delete the diesel generator fuel oil sampling commitments in the FSAR. As stated in Section 4.4 of the enclosed report, we consider this particular corrective action to be a step in a non-conservative direction.

Your cooperation with us in this matter is appreciated.

Sincerely,

Original Signed By:
P. K. Eapen

Jacque P. Durr, Chief
Engineering Branch
Division of Reactor Safety

OFFICIAL RECORD COPY CIR CC 89-17/18 - 0001.0.0
08/22/89

R908310227 890822
PDR ADOCK 05000317
Q FDC

IE:01

AUG 22 1989

Baltimore Gas and Electric Company

2

cc w/encls:

W. J. Lippold, General Supervisor, Technical Services Engineering
T. Magette, Administrator, Nuclear Evaluations
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
State of Maryland (2)

bcc w/encl:

Region I Docket Room (with concurrences)
Management Assistant, DRMA (w/o encl)
J. Wiggins, DRP
L. Tripp, DRP
D. Limroth, DRP
S. McNeil, NRR
PAO (14) SALP Reports Only
J. Dyer, EDO

JL
RI:DRSS
Lara/gcb

08/10/89

RI:DRSS
Anderson *for*

08/16/89

RI:DRSS
Durr *for*

08/22/89

OFFICIAL RECORD COPY

CIR CC 89-17/18 - 0001.1.0
08/10/89