APPENDIX A

NOTICE OF VIOLATION

Northeast Nuclear Energy Company
Millstone Unit 2

Docket No. 50-336
License No. DPR-65

During a routine safety inspection from June 16 to July 26, 1989, the following violation was identified in accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C.

Plant Surveillance Technical Specification 4.3.2.1.1, Amendment 53 dated April 9, 1981, requires implementation of a channel functional test for each engineered safety feature actuation system instrument per Table 4.3-2. Table 4.3-2 item 2c requires a monthly channel functional test of the automatic actuation logic, including the automatic test feature, which is to be verified operable every 31 days.

Contrary to the above, the automatic test function of the engineered safety feature automatic actuation logic was not verified operable pursuant to Technical Specification 4.3.2.1.1 between April 9, 1981 and July 26, 1989.

This is a Severity Level IV Violation (Supplement I).

Pursuant to 10 CFR 2.201, Northeast Nuclear Energy Company is hereby required to submit to this office, within thirty days of the date of the letter which transmits this Notice, a written statement or explanation in reply including: (1) the corrective actions taken and results achieved; (2) corrective steps to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending this response time.

8908310282 890821
PDR ADOCK 05000336
Q PDC