DCS No: 50320890710 Date: July 10, 1989

PRECIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-I-89-56

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The mation is as initially received without verification or evaluation, and is bas y all that is known by the Region I staff on this date.

Facility: GPU Nuclear Corporation Three Mile Island, Unit 2 Docket Number 50-320	Licensee Emergency Classification: Notification of Unusual Event Alert Site Area Emergency General Emergency X Not Applicable
DOCKET Hamber DO DEO	General Emerg

Subject: DISCOVERY OF REACTOR VESSEL LOWER HEAD CRACKS

The licensee recently completed defueling a major portion of the lower head region. Visual examination of several incore guide tubes revealed lower head cracks that propagated from two of the guide tube to vessel welds. The two guide tubes, E-7 and G-6, were substantially damaged by the flow of molten fuel during the accident. At present, approximately 1" of the original 12" tubes remains. The crack at location E-7 is the more visible and is approximately 4-5 inches long and approximately 1/4" to 1/2" wide. Crack depth is unknown at this time. The licensee is presently investigating methods of determining the actual size of these cracks, along with additional cleanup of the area. The resident inspectors are following the licensee's investigation.

The Commonwealth of Pennsylvania has been informed.

PAO hos cupy

Media interest is expected. This PN is issued for information only and is current as of $1:00\ p.m.$, July 10, 1989.

CONTACT:	F. Young (717) 948	-1167	C. Cowgill (215) 337-5128	Roll For	
DISTRIBUT OWFN Chairman Comm. Rob Comm. Rog Comm. Cur	Carr erts ers	MNBB AEOD ARM OGC	H-St. ACRS PDR	NL RES	Mail: ADM:DMB DOT:Trans only NRC Ops Ctr
SECY N CA N OGC O GPA O	MSS RR IA I LITP	Regional Office 8907170146 PDR 18E PNO-I-89-056		INPO NSAC RI Reside Licensee:	nt Office(Reactor Licensees)
Region I (Rev. Apr		PNO-1-39-05	5 PDC		
	EM) m	0		0

7/10

6\ Z=3