

EFFLUENT AND WASTE DISPOSAL SEMI ANNUAL REPORT
January 1, 1989 to June 30, 1989

SUPPLEMENTAL INFORMATION

FACILITY TMI Unit 2 (Including Epicor-II) LICENSEE DPR-73-320

1. Regulatory Limits

- a. Fission and activation gases:
- b. Iodines:
- c. Particulates, half-lives > 8 days: Environmental Tech Spec,
- d. Liquid Effluents: Article 2.3

2. Maximum Permissible Concentrations

Provide the MPCs used in determining allowable release rates or concentrations.

- a. Fission and activation gases:
- b. Iodines: 10 CFR, Part 20, Appendix B
- c. Particulates, half-lives 8 days:
- d. Liquid effluents:

3. Average Energy

Provide the average energy (E) of the radionuclide mixture in releases of fission and activation gases, if applicable - N/A

4. Measurements and Approximations of Total Radioactivity

Provide the methods used to measure or approximate the total radioactivity in effluents and the methods used to determine radionuclide composition.

- a. Fission and activation gases: Ge (Li) Spectrometry, Liquid Scintillation
- b. Iodines: Ge (Li) Spectrometry,
- c. Particulates: Ge (Li) Spectrometry, Gas Flow Proportional,
Beta Spectrometry
- d. Liquid effluents: Ge (Li) Spectrometry, Liquid Scintillation

5. Batch Releases

Provide the following information relating to batch releases of radioactive materials in liquid and gaseous effluents.

A. Liquid	1989	1989
	<u>1st Quarter</u>	<u>2nd Quarter</u>
1. Number of batch releases:	45	39
2. Total time period for batch release:	N/A	N/A
3. Maximum time period for a batch release:	N/A	N/A
4. Average time period for batch releases:	N/A	N/A
5. Minimum time period for a batch releases:	N/A	N/A
6. Average stream flow during periods of release of effluent into flowing stream:	N/A	N/A

N/A = not applicable

5. Batch Releases (cont.)

B. Gaseous	1989 <u>1st Quarter</u>	1989 <u>2nd Quarter</u>
1. Number of batch releases:	0	0
2. Total time period for batch releases:	N/A	N/A
3. Maximum time period for a batch release:	N/A	N/A
4. Average time period for batch release:	N/A	N/A
5. Minimum time period for a batch release:	N/A	N/A

6. Abnormal Releases

A. Liquid

1. Number of releases:	None	None
2. Total activity released:	N/A	N/A

B. Gaseous

1. Number of releases:	None	None
2. Total activity released:	N/A	N/A

TMI-2 SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT
FIRST AND SECOND QUARTERS 1989

ATTACHMENT 5
4410-89-L-0096
Page 3 of 10

TABLE 1A
EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT
GASEOUS EFFLUENTS-SUMMATION OF ALL RELEASES

	UNITS	1989 1ST QUARTER	1989 2ND QUARTER	EST. TOTAL ERROR %
	=====	=====	=====	=====
A. FISSION AND ACTIVATION GASES				
1. TOTAL RELEASE	Ci	<LLD	<LLD	+/- 60%
2. AVERAGE RELEASE RATE FOR PERIOD	uCi/sec	N/A	N/A	
3. PERCENT OF TECH SPEC LIMIT	%	N/A	N/A	TECH SPEC LIMIT = 7.2 E+3 uCi/sec FOR KR-85
B. IODINES				
1. TOTAL IODINE-131	Ci	<LLD	<LLD	+/- 60%
2. AVERAGE RELEASE RATE FOR PERIOD	uCi/sec	N/A	N/A	
3. PERCENT OF TECH SPEC LIMIT	%	N/A	N/A	TECH SPEC LIMIT = 2.4 E-2 uCi/sec
C. PARTICULATES				
1. PARTICULATES WITH HALF-LIVES >8 DAYS	Ci	7.13E-08	2.03E-07	+/- 60%
2. AVERAGE RELEASE RATE FOR PERIOD	uCi/sec	9.17E-09	2.58E-08	
3. PERCENT OF TECH SPEC LIMIT	%	0.00%	0.00%	TECH SPEC LIMIT =
4. GROSS ALPHA RADIOACTIVITY	Ci	1.76E-07	<LLD	2.4 E-2 uCi/sec
D. TRITIUM				
1. TOTAL RELEASE	Ci	2.55E+00	4.27E+00	+/- 60%
2. AVERAGE RELEASE RATE FOR PERIOD	uCi/sec	3.28E-01	5.43E-01	
3. PERCENT OF TECH SPEC LIMIT	%	0.01%	0.01%	TECH SPEC LIMIT = 4.8 E+3 uCi/sec FOR H-3

TMI-2 SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT
FIRST AND SECOND QUARTERS 1989

ATTACHMENT 5
4410-89-L-0096
Page 4 of 10

TABLE 1B

EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT

GASEOUS EFFLUENTS-GROUND LEVEL RELEASES

		CONTINUOUS MODE		BATCH MODE	
NUCLIDES RELEASED =====	UNIT =====	1989 1ST QUARTER =====	1989 2ND QUARTER =====	1989 1ST QUARTER =====	1989 2ND QUARTER =====
1. FISSION GASES					
KRYPTON-85	Ci	<LLD	<LLD	<LLD	<LLD
KRYPTON-85M	Ci	<LLD	<LLD	<LLD	<LLD
KRYPTON-87	Ci	<LLD	<LLD	<LLD	<LLD
KRYPTON-88	Ci	<LLD	<LLD	<LLD	<LLD
XENON-133	Ci	<LLD	<LLD	<LLD	<LLD
XENON-135	Ci	<LLD	<LLD	<LLD	<LLD
XENON-135M	Ci	<LLD	<LLD	<LLD	<LLD
XENON-138	Ci	<LLD	<LLD	<LLD	<LLD
OTHERS (SPECIFY)	Ci	<LLD	<LLD	<LLD	<LLD
	Ci				
	Ci				
	Ci				
	Ci				
UNIDENTIFIED	Ci	<LLD	<LLD	<LLD	<LLD
TOTAL FOR PERIOD	Ci	N/A	N/A	N/A	N/A
2. IODINES					
IODINE-131	Ci	<LLD	<LLD	N/A	N/A
IODINE-133	Ci	<LLD	<LLD	N/A	N/A
IODINE-135	Ci	<LLD	<LLD	N/A	N/A
TOTAL FOR PERIOD	Ci	N/A	N/A	N/A	N/A
3. PARTICULATES					
STRONTIUM-89	Ci	<LLD	<LLD	N/A	N/A
STRONTIUM-90	Ci	7.13E-08	1.02E-07	N/A	N/A
CESIUM-134	Ci	<LLD	<LLD	N/A	N/A
CESIUM-137	Ci	<LLD	<LLD	N/A	N/A
BARIUM-LANTHANUM-140	Ci	<LLD	<LLD	N/A	N/A
OTHERS (SPECIFY)					
UNIDENTIFIED	Ci	<LLD	<LLD	N/A	N/A

TMI-2 SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT
FIRST AND SECOND QUARTERS 1989

ATTACHMENT 5
4410-89-L-0096
Page 5 of 10

TABLE 2A
EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT
LIQUID EFFLUENTS-SUMMATION OF ALL RELEASES

	UNITS =====	1989 1ST QUARTER =====	1989 2ND QUARTER =====	EST. TOTAL ERROR % =====
A. FISSION AND ACTIVATION PRODUCTS				
1. TOTAL RELEASES (NOT INCLUDING TRITIUM, GASES, ALPHA)	Ci	5.76E-05	1.29E-04	+/- 60% BASED ON 2E-5 uCi/ml (Cs-137)
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/ml	4.33E-12	1.22E-11	
3. PERCENT OF APPLICABLE LIMIT	%	0%	0%	
B. TRITIUM				
1. TOTAL RELEASE	Ci	1.45E-06	1.26E-04	+/- 60% BASED ON 3E-3 uCi/ml (H-3)
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/ml	1.09E-13	1.19E-11	
3. PERCENT OF APPLICABLE LIMIT	%	0%	0%	
C. DISSOLVED AND ENTRAINED GASES				
1. TOTAL RELEASE	Ci	<LLD	<LLD	+/- 60%
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/ml	N/A	N/A	
3. PERCENT OF APPLICABLE LIMIT	%	N/A	N/A	
D. GROSS ALPHA ACTIVITY				
1. TOTAL RELEASE	Ci	<LLD	<LLD	+/- 25%
E. VOLUME OF WASTE RELEASED (PRIOR TO DILUTION)				
	liters	1.04E+05	1.03E+05	+/- 25%
F. VOLUME OF DILUTION WATER USED				
	liters	1.33E+10	1.06E+10	+/- 10%

TMI-2 SEMI-ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT
FIRST AND SECOND QUARTERS 1989

ATTACHMENT 5
4410-89-L-0096
Page 6 of 10

TABLE 2B

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

LIQUID EFFLUENTS

NUCLIDES RELEASED =====	UNIT =====	CONTINUOUS MODE		BATCH MODE	
		1989 1ST QUARTER =====	1989 2ND QUARTER =====	1989 1ST QUARTER =====	1989 2ND QUARTER =====
STRONTIUM-89	Ci			<LLD	<LLD
STRONTIUM-90	Ci			1.25E-05	3.63E-05
CESIUM-134	Ci			<LLD	<LLD
CESIUM-137	Ci			4.51E-05	9.28E-05
IODINE-131	Ci			<LLD	<LLD
COBALT-58	Ci			<LLD	<LLD
COBALT-60	Ci			<LLD	<LLD
IRON-59	Ci			<LLD	<LLD
ZINC-65	Ci			<LLD	<LLD
MANAGANESE-54	Ci			<LLD	<LLD
CHROMIUM-51	Ci			<LLD	<LLD
ZIRCONIUM-NIOBIUM-95	Ci			<LLD	<LLD
MOLYBDENUM-99	Ci			<LLD	<LLD
TECHNETIUM-99M	Ci			<LLD	<LLD
BARIUM-LANTHANUM-140	Ci			<LLD	<LLD
CERIUM-141	Ci			<LLD	<LLD
OTHER (SPECIFY)	Ci				
UNIDENTIFIED	Ci			<LLD	<LLD
TOTAL FOR PERIOD	Ci			5.76E-05	1.29E-04
XENON-133	Ci			<LLD	<LLD
XENON-135	Ci			<LLD	<LLD

TABLE 3A
EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT
SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

A. Solid waste shipped off-site for burial or disposal (not irradiated fuel)

1. Type of waste	UNIT	6 month period	EST. TOTAL ERROR %
a. Spent resins, filter sludges, evaporator bottoms, etc.	m ³ C1	35.46 10078.7	5%
b. Dry compressible waste, contaminated equipment, etc.	m ³ C1	692.9 10.94	5%
c. Irradiated components, control rods, etc.	m ³ C1		N/A
d. Other (describe)	m ³ C1		N/A

2. Estimate of major nuclide composition (by type of waste)		
a. Cs137	46.81%	
Sr90	42.99%	
Pm147	7.58%	
Cs134	.744%	
b. Sr90	53.32%	
Cs137	26.1%	
Pm147	8.63%	
Pu241	3.98%	
Sb125	1.97%	
c.	%	
	%	
	%	
	%	
	%	
d.	%	
	%	
	%	
	%	

3. Solid Waste Disposition		
Number of Shipments	Mode of Transportation	Destination
See Attached For This	Information	

B. Irradiated Fuel Shipments (Disposition)

Number of Shipments	Mode of Transportation	Destination
6 Shipments	Railcar - Cask (NuPac 125B)	INEL - Scoville, Idaho

TMI-2 EFFLUENT & WASTE DISPOSAL SEMI-ANNUAL REPORT

01/01/89 Through 06/30/89

Table A.3.a

<u>No. of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
7	Tractor-Cask (CNSI 8-120B)	Barnwell, SC
1	Tractor-Cask (HN-200)	Barnwell, SC
4	Tractor-Cask (HN-200)	Hanford-Richland, WA
2	Tractor-Cask (NuPac 14/190M)	Hanford-Richland, WA
1	Tractor-Cask (HN-142)	Hanford-Richland, WA

Table A.3.b

<u>No. of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
*9	Tractor-Flatbed	Scientific Ecology Group, Oak Ridge, TN
*1	Tractor-Closed Van	Scientific Ecology Group, Oak Ridge, TN
1	Tractor-Flatbed	Hanford-Richland, WA

WASTE SHIPPED AS FOLLOWS:

TABLE A.1.a:

- Four (4) - CNSI 8-120 Liners @ 125.2 Ft.³ Each
- *ive (5) - EA-50 High Integrity Containers @ 49.9 Ft.³ Each
- Two (2) - Steel Liners @ 170 Ft.³ Each
- **One (1) - EA-142 High Integrity Container @ 130.8 Ft.³ Each
- Three (3) - Medium Poly High Integrity Containers @ 36.5 Ft.³ Each

TABLE A.1.b:

- *Two Hundred Fifth-Nine (259) - Steel Boxes @ 92 Ft.³ Each
- *Twenty (20) - Steel Drums @ 7.5 Ft.³ Each
- *Four (4) - Steel Boxes @ 34.6 Ft.³ Each
- *Two (2) - Steel Boxes @ 57 Ft.³ Each
- One (1) - Steel Liner @ 161 Ft.³ Each

* Material Sent to Waste Processor for Volume Reduction

** SDS Vessel Overpacked with DAW in EA-142 High Integrity Container, Volume and Activity of SDS Vessel Assigned to Resin Category, Remaining Volume (78.3 Ft.³) and Activity Assigned to DAW Category.

TYPICAL GASEOUS EFFLUENT LLD (Lower Limit of Detection) VALUES

ASSUMPTIONS: Sample volume (Marinelli) 1640cc
Sample volume (Particulate & Charcoal Filters) 5.7E8cc
Sampling Rate 2 cfm or 5.66E4cc/min
Sampling Time 1 week or 1E4 min
Sample volume (tritium bubbled thru water) 7.56E5cc
Sampling Rate 75cc/min
Sampling Time 1E4 min
Sample Counting Time: α & H-3 = 20min; β = 10min; γ = 1000sec
Sample Counters: γ emitters 25% Ge(Li)
 α or β Proportional Counter
H-3 Liquid Scintillation Counter

ISOTOPE		μ Ci/cc LLD	NOTES
Gross Alpha	α	1E-15	Particulate Filter Paper
Gross Beta	β	1E-14	"
Tritium	H-3	1E-10	Air bubbled thru water by a fritted disc or Fisher Milligan gas washer
Krypton-85	Kr-85	5E-6	Marinelli
Krypton-85m	Kr-85m	2E-8	"
Krypton-87	Kr-87	6E-8	"
Krypton-88	Kr-88	5E-8	"
Xenon-133	Xe-133	4E-8	"
Xenon-133m	Xe-133m	1E-7	"
Xenon-135	Xe-135	2E-8	"
Xenon-135m	Xe-135m	3E-7	"
Xenon-138	Xe-138	3E-7	"
Iodine-131	I-131	2E-8	"
Iodine-133	I-133	3E-8	"
Iodine-135	I-135	2E-7	"
Iodine-131	I-131	3E-14	Charcoal Filter
Iodine-133	I-133	4E-14	"
Iodine-135	I-135	3E-13	"
Manganese-54	Mn-54	3E-14	Particulate filter Paper
Iron-59	Fe-59	8E-14	"
Cobalt-58	Co-58	3E-14	"
Cobalt-60	Co-60	5E-14	"
Zinc-65	Zn-65	9E-14	"
Strontium-89	Sr-89	2E-14	"
Strontium-90	Sr-90	2E-14	"
Molybdenum-99	Mo-99	2E-14	"
Ruthenium-103	Ru-103	2E-14	"
Silver-110m	Ag-110m	3E-14	"
Cesium-134	Cs-134	4E-14	"
Cesium-137	Cs-137	3E-14	"
Cerium-141	Ce-141	3E-14	"
Cerium-144	Ce-144	9E-14	"

TYPICAL LIQUID EFFLUENT LLD (Lower Limit of Detection) VALUES

ASSUMPTIONS: Sample volume = 1 liter = 1000 cc
Sample counting time = 1000 sec
Sample counted with a 25% Ge(Li) for Gamma Emitters

<u>ISOTOPE</u>		<u>μCi/cc LLD</u>	<u>NOTES</u>
Gross Alpha	α	4E-9	Counted with proportional counter
Gross Beta	β	7E-8	Counted with proportional counter
Tritium	H-3	4E-6	Counted with liquid scintillation counter
Krypton-85	Kr-85	1E-4	
Xenon-131m	Xe-131m	2E-5	
Xenon-133	Xe-133	1E-6	
Xenon-135	Xe-135	3E-7	
Chromium-51	Cr-51	3E-6	
Manganese-54	Mn-54	4E-7	
Cobalt-58	Co-58	4E-7	
Iron-59	Fe-59	9E-7	
Cobalt-60	Co-60	6E-7	
Zinc-65	Zn-65	1E-6	
Zirconium-95	Zr-95	7E-7	
Niobium-95	Nb-95	4E-7	
Molybdenum-99	Mo-99	3E-7	
Technetium-99m	Tc-99m	3E-7	
Silver-110m	Ag-110m	6E-7	
Antimony-125	Sb-125	9E-7	
Cesium-134	Cs-134	5E-7	
Cesium-136	Cs-136	4E-7	
Cesium-137	Cs-137	5E-7	
Barium-140	Ba-140	1E-6	
Lanthanum-140	La-140	7E-7	
Cerium-141	Ce-141	5E-7	
Cerium-144	Ce-144	3E-6	
Iodine-131	I-131	3E-7	
Iodine-133	I-133	4E-7	
Phosphorus-32	P-32	1E-6	These LLD values for liquid sample analyses of gross alpha, P-32, Fe-55, Sr-89, and Sr-90 are the same as Unit 1 which are offsite vendor LLD values.
Iron-55	Fe-55	5E-8	
Strontium-89	Sr-89	5E-8	
Strontium-90	Sr-90	5E-8	
Gross Alpha	α	1E-7	