HL-615 0201V

July 7, 1989

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D.C. 20555

> PLANT HATCH - UNITS 1, 2 NRC DOCKETS 50-321, 50-366 OPERATING LICENSES DPR-57, NPF-5 ATWS-ARI SYSTEM TESTIBILITY AT POWER

Gentlemen:

Atlanta, Georgia 30308 1866ph./ssi 404 526 319

This letter is written in response to your correspondence of December 14, 1988 noting the open item concerning ATWS-ARI System Testibility at power.

Georgia Power Company will implement a design change which will allow testing at power. The change will utilize test switches which block the actuation signal to the ARI solenoid valve during testing. This will allow the ARI Actuation Relays to be energized without causing the valves to change state. Also, an alarm will be provided to alert the operator that testing is in progress which conforms with the Regulatory Guide 1.47 regulatory position. These changes will be implemented according to our schedule for completing the additional ATWS modifications, that is; by the end of the refueling outages scheduled for 1990 and 1991 for Units 1 and 2, respectively.

Should you have any questions, please advise.

Sincerely,

W. G. Hairston, III

DLM/eb

c: (See next page.)

A055

8907170371 890707 PDR ADDCK 05000321 U.S. Nuclear Regulatory Commission July 7, 1989 Page Two

c: Georgia Power Company
Mr. H. C. Nix, General Manager - Nuclear Plant
Mr. J. D. Heidt, Manager Engineering and Licensing - Hatch
GO-NORMS

U.S. Nuclear Regulatory Commission, Washington, D.C. Mr. L. P. Crocker, Licensing Project Manager - Hatch

U.S. Nuclear Regulatory Commission, Region II
Mr. S. D. Ebneter, Regional Administrator
Mr. J. E. Menning, Senior Resident Inspector - Hatch