

000

AUG 15 1989

Docket No. 50-454
Docket No. 50-455

Commonwealth Edison Company
ATTN: Mr. Cordell Reed
Senior Vice President
Post Office Box 767
Chicago, IL 60690

Gentlemen:

We have reviewed your response regarding an allegation we forwarded to you by our letter dated June 27, 1989 (attached). In that correspondence we requested you to perform an independent verification of the histories of the Allen Nuclear Associates (ANA) employees involved in eddy current testing and make a comparison of the results achieved to the resumes they submitted. Also compare the results to the requirements of the job(s) they were assigned. We further requested you to conduct an overview inspection of a sample of ongoing eddy current testing and an independent inspection of a sample of completed eddy current testing to demonstrate that scheduled work on safety-related systems was in fact completed. Finally we requested you to provide the names of those employees of ANA assigned to the outage of 1987 and again during the May-June 1988 outage.

Your letter of July 26, 1989 (attached) describes the actions your staff took to resolve the above described issues. Based on the information provided related to the qualification requirements, in terms of formal education and actual training, coupled with the NDT analysis techniques employed and the multiple oversight of the data provided by the automated state of the art equipment, your response adequately addressed the issues. No violations of NRC requirements were identified. We consider this allegation (RIII-88-A-0112) closed.

Sincerely,

"Original signed by W.D. Shafer"

W. D. Shafer, Chief
Reactor Projects Branch 1

Attachments: As stated

See Attached Distribution

8909060344 890815
FDR ADOCK 05000454
FDC

RIII *yes*
Hand
Hinds/jp
08/15/89

RIII
Shafer

IF 54

Commonwealth Edison Company

2 AUG 15 1989

Distribution

cc w/attachments:

T. J. Maiman, Vice President,
PWR Operations

T. Kovach, Nuclear
Licensing Manager

R. Pleriewicz, Station Manager
DCD/DCB (RIDS)

Licensing Fee Management Branch

Resident Inspector, RIII Byron

Resident Inspector, RIII
Braidwood

D. W. Cassel, Jr., Esq.

Richard Hubbard

J. W. McCaffrey, Chief, Public
Utilities Division

Diane Chavez, DAARE/SAFE

L. Olshan, NRR LPM

H. S. Taylor, Quality Assurance
Division

C. Weil, RIII