

MAR 15 1989

Docket No. 50-266
Docket No. 50-301

Wisconsin Electric Power Company
ATTN: Mr. C. W. Fay
Vice President
Nuclear Power Department
231 West Michigan, Room 308
Milwaukee, WI 53201

Gentlemen:

This is to acknowledge receipt of your letter dated January 23, 1989, which transmitted Revisions 29 and 31 to the Point Beach Nuclear Plant Emergency Plan.

We have completed our review of revisions 19 and 31, dated January 19, 1989, and have determined that they remain consistent with the requirements of 10 CFR 50.54(q) and do not decrease the effectiveness of the emergency plan.

Be advised that 10 CFR 50.54(q) requires prior NRC approval of any changes to your plan which may decrease the effectiveness of the plan. However, if your safety review assures no decrease in emergency preparedness effectiveness, then changes to the plan may be made and implemented without prior NRC approval in accordance with 10 CFR 50.54(q). Also, any changes to the Emergency Plan Implementing Procedures should be made in accordance with the requirements of 10 CFR 50, Appendix E, Section V.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter will be placed in the NRC Public Document Room.

If you have any questions regarding this letter, please contact Ms. Marcia Smith of my staff at (312) 790-5298.

Sincerely,

L. Robert Greger, Chief
Reactor Programs Branch

See Attached Distribution

RIII. <i>mys</i> Smith/mnj	<i>yes</i> RIII WGS Snell 3/14/89	<i>yes</i> RIII <i>MAR for 3/14/89</i> DeFayette	RIII <i>[Signature]</i> Greger <i>Yes</i>
----------------------------------	---	---	--

IE35
1/0

MAR 15 1989

Distribution

cc: J. J. Zach, Plant Manager
DCD/DCB (RIDS)
Licensing Fee Management Branch
Resident Inspector, RIII
Virgil Kanable, Chief
Boiler Section
Charles Thompson, Chairperson
Wisconsin Public Service
Commission
R. I. Braund (SLO),
WI Div. of Emergency Government
Lawrence J. McDonnell, Chief
Radiation Protection Section
WI Department of Health and
Social Services, Division
of Health
Ruth L. LaFreniere, RIII