

TU ELECTRIC

Log # TXX-89248
File # 10110
906.2
906.5
Ref. # 10CFR50.55(e)

W. J. Cahill
Executive Vice President

May 8, 1989

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
CONTAINMENT SPRAY PUMP RECIRCULATION PIPING
SDAR: CP-87-055 (SUPPLEMENTAL REPORT)

Gentlemen:


On December 8, 1987, TU Electric notified the NRC via report logged TXX-7046 of a reportable item involving the containment spray pump recirculation piping. The latest report on this subject was logged TXX-88850, dated December 16, 1988. The purpose of this report is to revise the schedule for implementation of corrective action.

The replacement of the affected containment spray pump recirculation piping with ASME III Class 2 pipe and seismic Category 1 supports is continuing. These modifications will be completed prior to fuel load for Unit 1. The Unit 2 completion schedule remains unchanged.

Sincerely,

William J. Cahill, Jr.

8905190015 890508
PDR ADCK 05000445
S PNU

By: 
D. R. Woodlan
Docket Licensing Manager

CBC/vld

c - Mr. R. D. Martin, Region IV
Resident Inspectors, (CPSES) (3)

IE27
1/0