

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
)
Duquesne Light Company)
Beaver Valley Power Station)

UNIT NO. 2
Docket No. 50-412
License No. NPF-73

APPLICATION FOR AMENDMENT
TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the U. S. Nuclear Regulatory Commission, Duquesne Light Company hereby requests that the Technical Specifications set forth in Appendix A of the license be amended to revise the overtemperature ΔT and overpower ΔT reactor trip time response requirements from 4.0 to 5.5 seconds.

The proposed technical specification changes are set forth in Attachments A to this Application. A Safety Evaluation is set forth in Attachment B. A No Significant Hazard Evaluation is set forth in Attachment C. Based on the guidance provided by the Commission, the proposed changes have been determined to involve no significant hazards consideration in accordance with 10 CFR 50.92.


WHEREFORE, Applicant respectfully requests that Appendix A to the Operating License be amended in the form attached hereto as Attachment A.

Duquesne Light Company

By J. D. Sieber
J. D. Sieber
Vice President, Nuclear

Subscribed and sworn to before me
on this 4th day of May, 1989.

Sheila M. Fattore



Member, Pennsylvania Association of Notaries

8905190087 890504
PDR ADOCK 05000412
P PNU

ATTACHMENT A

Revise the Technical Specifications as follows:

Remove Page

3/4 3-8

Insert Page

3/4 3-8