

Duquesne Light Company

Beaver Valley Power Station
PO Box 4
Shippingport, PA 15077-0004

JOHN D. SIEBER
Vice President - Nuclear Group

(412) 643-6255

August 25, 1989

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Reference: Beaver Valley Power Station, Unit No. 2
Docket No. 50-412, License No. NPF-73
Proposed Operating License Change Request No. 27


Gentlemen:

Enclosed are:

1. An application for Amendment to the above operating license to revise the Reactor Trip System specification by deleting the trip function on Steam/Feedwater Flow Mismatch coupled with Low Steam Generator Water Level.
2. Documents designated Attachments A, B and C which set forth the change in the technical specifications, the safety analysis and the no significant hazards evaluation.

This change was reviewed by the OSC and ORC and determined to be safe and does not involve an unreviewed safety question.

Very truly yours,


J. D. Sieber
Vice President
Nuclear Group

cc: Mr. J. Beall, Sr. Resident Inspector
Mr. W. T. Russell, NRC Region I Administrator
Mr. P. Tam, Sr. Project Manager
Mr. T. M. Gerusky, Director BRP/DER
Mr. R. Janati, BRP/DER
Mr. R. Saunders, Director Safety Evaluation & Control (VEPCO)

8909080005 890825
PDR ADOCK 05000412
P PDC

A001
11