

Omaha Public Power District
1623 Harney Omaha, Nebraska 68102-2247
402/536-4000

August 31, 1989
LIC-89-815

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, DC 20555

References: 1. Docket No. 50-285
2. Letter from NRC (A. Bournia) to OPPD (K. J. Morris) dated
June 29, 1989

Gentlemen:


SUBJECT: Resolution of HED 93 Regarding Indicator Light Bulb Issue

HED 93 identified a concern that, "in general, indicator lights do not have a lamp test feature". Omaha Public Power District (OPPD) intends to resolve this issue using one of the four acceptable methods noted in Reference 2. This will involve replacing the normally off and non-testable, single indicating, safety-related lamps with "long-life" Light Emitting Diode (LED) cluster lamps.

Should the NRC accept OPPD's proposed resolution of this issue and respond by May of 1990, a modification will be issued and the work will be completed during the 1991 refueling outage.

If you should have any questions, please contact us.

Sincerely,


K. J. Morris
Division Manager
Nuclear Operations

KJM/pjc

c: LeBoeuf, Lamb, Leiby & MacRae
R. D. Martin, NRC Regional Administrator
A. Bournia, NRC Project Manager
P. H. Harrell, NRC Senior Resident Inspector

A001
1/2

8909080022 890831
PDR ADOCK 05060285
P FDC