



LOUISIANA
POWER & LIGHT

317 BARONNE STREET • P. O. BOX 60340
NEW ORLEANS, LOUISIANA 70160 • (504) 595-3100

W3P89-3088
A4.05
QA

July 17, 1989

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Subject: Waterford 3 SES
Docket No. 50-382
License No. NPF-38
Monthly Operating Report

Gentlemen:

Enclosed is the subject monthly report which covers the operating statistics for the month of June 1989. This report is submitted per Section 6.9.1.6 of the Waterford 3 Technical Specifications for Facility Operating License No. NPF-38.

Very truly yours,

R.F. Burski
Manager
Nuclear Safety & Regulatory Affairs

RFB/LWL/ssf

Enclosure

cc: Messrs. R.D. Martin, NRC Region IV
F.J. Hebdon, NRC-NRR
D.L. Wigginton, NRC-NRR
J.T. Wheelock (INPO Records Center)
E.L. Blake
W.M. Stevenson
NRC Resident Inspectors Office

8907200099 890630
PDR ADOCK 05000382
R PDC

"AN EQUAL OPPORTUNITY EMPLOYER"

NRC MONTHLY OPERATING REPORT

SUMMARY OF OPERATIONS

WATERFORD 3

JUNE 1989

The unit operated at an average reactor power of 98.0% and experienced no significant power reductions or shutdowns during the period.

PRESSURIZER SAFETY VALVE
FAILURES AND CHALLENGES
WATERFORD 3

During the month of June 1989, there were no pressurizer safety valve failures or challenges.

OPERATING DATA REPORT

UNIT NAME: WATERFORD 3
 CITY/STATE: KILLONA/LA
 DATE: July 1989

OPERATING STATUS

1. Docket: 50-382
2. Reporting Period: JUNE 1989
3. Utility Contact: PATRICK CENTOLANZI
 Phone Number: (504) 464-3360
4. Licensed Thermal Power (MWt): 3390
5. Nameplate Rating (Gross MWe): 1200
6. Design Electrical Rating (Net MWe): 1104
7. Maximum Dependable Capacity (Gross MWe): 1120
8. Maximum Dependable Capacity (Net MWe): 1075
9. If Changes Occur in Capacity Ratings (Items Number 4 Through 8) Since Last Report, Give Reasons: _____

10. Power Level To Which Restricted, if Any (Net MWe): NONE
11. Reasons For Restrictions, If Any: N/A

Notes

	This Month	Yr.-to-Date	Cumulative
12. Hours In Reporting Period	<u>720.0</u>	<u>4343.0</u>	<u>33024.0</u>
13. Number Of Hours Reactor Was Critical	<u>720.0</u>	<u>4284.3</u>	<u>27013.4</u>
14. Reactor Reserve Shutdown Hours	<u>-0-</u>	<u>-0-</u>	<u>-0-</u>
15. Hours Generator On-Line	<u>720.0</u>	<u>4280.6</u>	<u>26567.8</u>
16. Unit Reserve Shutdown Hours	<u>-0-</u>	<u>-0-</u>	<u>-0-</u>

OPERATING DATA REPORT
(Continued)

	This Month	Yr.-to-Date	Cumulative
17. Gross Thermal Energy Generated (MWH)	<u>2,390,707</u>	<u>14,272,904</u>	<u>86,296,500</u>
18. Gross Electrical Energy Generated (MWH)	<u>804,860</u>	<u>4,836,950</u>	<u>29,106,900</u>
19. Net Electrical Energy Generated (MWH)	<u>769,183</u>	<u>4,635,420</u>	<u>27,696,274</u>
20. Unit Service Factor	<u>100.0</u>	<u>98.6</u>	<u>80.4</u>
21. Unit Availability Factor	<u>100.0</u>	<u>98.6</u>	<u>80.4</u>
22. Unit Capacity Factor (Using MDC Net)	<u>99.4</u>	<u>99.3</u>	<u>78.0</u>
23. Unit Capacity Factor (Using DER Net)	<u>96.8</u>	<u>96.7</u>	<u>76.0</u>
24. Unit Forced Outage Rate	<u>0.0</u>	<u>1.4</u>	<u>5.6</u>
25. Unit Forced Outage Hours	<u>0.0</u>	<u>62.4</u>	<u>1589.1</u>

26. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

Refueling Outage #3, 9/22/89, 60 Days

27. If Shut Down At End of Report Period, Estimated Date Of Startup: _____

28. Units In Test Status (Prior to Commercial Operation):

	<u>Forecast</u>	<u>Achieved</u>
INITIAL CRITICALITY	_____	<u>3/4/85</u>
INITIAL ELECTRICITY	_____	<u>3/16/85</u>
COMMERCIAL OPERATION	_____	<u>9/24/85</u>

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-382

UNIT WATERFORD 3

DATE JULY 1989

COMPLETED BY PATRICK CENTOLANZI

TELEPHONE 504-464-3360

MONTH JUNE 1989

DAY AVERAGE DAILY POWER LEVEL
 (MWe-Net)

1	<u>1088</u>
2	<u>1088</u>
3	<u>1089</u>
4	<u>1090</u>
5	<u>1090</u>
6	<u>1081</u>
7	<u>1085</u>
8	<u>1088</u>
9	<u>1088</u>
10	<u>997</u>
11	<u>1089</u>
12	<u>1087</u>
13	<u>927</u>
14	<u>1084</u>
15	<u>1085</u>
16	<u>1086</u>

DAY AVERAGE DAILY POWER LEVEL
 (MWe-Net)

17	<u>943</u>
18	<u>949</u>
19	<u>1060</u>
20	<u>1089</u>
21	<u>1089</u>
22	<u>1089</u>
23	<u>1089</u>
24	<u>1087</u>
25	<u>1087</u>
26	<u>1087</u>
27	<u>1086</u>
28	<u>1085</u>
29	<u>1084</u>
30	<u>1085</u>
31	<u>NA</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS REPORT FOR JUNE 1989

DOCKET NO
UNIT NAME
DATE
COMPLETED BY
TELEPHONE

50-382
WATERFORD 3
JULY 1989
PATRICK CENTOLANZI
504-464-3360

Cause & Corrective
Action to
Prevent Recurrence

Component
Code⁵

System
Code⁴

Licensee
Event
Report #

Method of
Shutting
Down Reactor³

REASON²

Duration
(HOURS)

Type¹

No. Date

NONE

1

F: Forced
S: Scheduled

2

Reason:

A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training &
License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3

Method

1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Continuation
5-Load Reduction
9-Other

4

IEEE Std. 805-1984

5

IEEE Std. 803A-1983