



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

ARKANSAS POWER AND LIGHT COMPANY

DOCKET NO. 50-313

ARKANSAS NUCLEAR ONE, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 125
License No. DPR-51

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Arkansas Power and Light Company (the licensee) dated June 13, 1989, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. DPR-51 is hereby amended to read as follows:

2. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 125, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. The license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Frederick J. Hebdon
Frederick J. Hebdon, Director
Project Directorate IV
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 31, 1989

ATTACHMENT TO LICENSE AMENDMENT NO. 125

FACILITY OPERATING LICENSE NO. DPR-51

DOCKET NO. 50-313

Revise the following page of the Appendix "A" Technical Specifications with the attached page. The revised page is identified by Amendment number and contains a vertical line indicating the area of change.

REMOVE PAGE

40

INSERT PAGE

40

3.4 STEAM AND POWER CONVERSION SYSTEM

Applicability

Applies to the turbine cycle components for removal of reactor decay heat.

Objective

To specify minimum conditions of the turbine cycle equipment necessary to assure the capability to remove decay heat from the reactor core.

Specifications

3.4.1 The reactor shall not be heated above 280°F unless the following conditions are met:

1. Capability to remove decay heat by use of two steam generators.
- *2. Fourteen of the steam system safety valves are operable.
3. A minimum of 11.1 feet (107,000 gallons) of water is available in Tank T41B.
- **4. Both EFW pumps and their flow paths are operable.
5. Both main steam block valves and both main feedwater isolation valves are operable.

3.4.2 Initiate functions of the EFIC system which are bypassed at cold shutdown conditions shall have the following minimum operability conditions:

- a. "low steam generator pressure" initiate shall be operable when the main steam pressure exceeds 750 psig.
- b. "loss of 4 RC pumps" initiate shall be operable when neutron flux exceeds 10% power.
- c. "main feedwater pumps tripped" initiate shall be operable when neutron flux exceeds 10% power.

* Except that during hydrotests, with the reactor subcritical, fourteen of the steam system safety valves may be gagged and two (one on each header), may be reset for the duration of the test, to allow the required pressure for the test to be attained.

**Except that a test with available steam pressure of the steam driven EFW pump shall demonstrate its functionality until completion of surveillance testing at hot shutdown conditions as required by Surveillance Requirement 4.8.1.