

DCS

MAY 16 1989

Docket No. 50-344
License No. NPF-1
EA 89-16

Portland General Electric Company
ATTN: Mr. David W. Cockfield
Vice President, Nuclear
121 S. W. Salmon Street
Portland, Oregon 97204

Gentlemen:


This will acknowledge receipt of your letter dated April 28, 1989 and your check for \$75,000 in payment for the civil penalty proposed by NRC in a letter dated April 4, 1989.

Based on discussions held with your staff subsequent to the enforcement conference on January 26, 1989, we had expected that your response to the Notice of Violation would include a summary of the results to date of your review of past procurement practices, your intended actions to expand your review based on those results, and your schedule for replacement of parts, where warranted. In addition, your response indicates that approximately 1500 maintenance requests will not be dispositioned prior to restart because they do not involve EQ, seismic qualification, or ASME Section XI pressure retaining installations. We are concerned that active safety-related components such as pump bearings, pump shafts, and valve stems may not be reviewed prior to restart. We would expect you to disposition active safety-related components prior to restart or to provide a case-by-case justification for any delay in such dispositions.

In order that any open issues may be addressed during your 1989 refueling outage, which is presently in progress, please provide a written response to the above concerns addressed to the Regional Administrator, Region V, within 14 days of the date of this letter.

Your response and corrective actions to the violations will be examined during future inspections.

Sincerely,
Original signed by
Howard J. Wong



James Lieberman, Director
Office of Enforcement

cc: J. Martin, RV
S. Richards, RV
E. Baker, NRR

DISTRIBUTION:

JLieberman, OE
HWong, OE
AJohnson, RV
Day File
EA File
DCS

8905230380 890516
PDR ADOCK 05000344
Q PDC

HSW HSW
OE D:OE for
HWong JLieberman
5/14/89 5/16/89

TEIA
10