



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

CONSUMERS POWER COMPANY

PALISADES PLANT

DOCKET NO. 50-255

AMENDMENT TO PROVISIONAL OPERATING LICENSE

Amendment No. 121  
License No. DPR-20

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Consumers Power Company (the licensee) dated July 30, 1985 and supplemented by letter dated January 13, 1986, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public; and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 3.B. of Provisional Operating License No. DPR-20 is hereby amended to read as follows:


Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 121, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

8905240081 890512  
PDR ADOCK 05000255  
PDC

3. This license amendment is effective as of the date of its issuance and shall be implemented not later than June 25, 1989 .

FOR THE NUCLEAR REGULATORY COMMISSION



Lawrence Yandell, Acting Director  
Project Directorate III-1  
Division of Reactor Projects - III, IV, V  
& Special Projects  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: May 12, 1989

ATTACHMENT TO LICENSE AMENDMENT NO. 121

PROVISIONAL OPERATING LICENSE NO. DPR-20

DOCKET NO. 50-255

Revise Appendix A Technical Specifications by removing the page identified below and inserting the attached page. The revised page is identified by the captioned amendment number and contains marginal lines indicating the area of change.

REMOVE

3-81

INSERT

3-81



Table 3.17.4

Instrumentation Operating Requirements for  
Other Safety Feature Functions

<u>No.</u>	<u>Functional Unit</u>	<u>Minimum Operable Channels</u>	<u>Minimum Degree of Redundancy</u>	<u>Permissible Bypass Conditions</u>
1	SIRW Low-Level Switches	2 <sup>(b)</sup>	1	None
2	WT - Power Comparator	3 <sup>(c)</sup>	1	None
3	(Deleted)			/
4	Air Cooler Service Water Flow Instr.	1	None	None
5	Primary and Secondary Rod Insertion and Out- of-Sequence Monitors	1	None	NA
6	Fuel Pool Bldg Crane Interlocks	1	None	As Requested Under Administrative Control <sup>(a)</sup>
7	Start-Up Channels	2	1 <sup>(d)</sup>	Not Required Above 10 <sup>-4</sup> % of Rated Power

- (a) Crane shall not be used to move material past the fuel storage pool unless the interlocks are available.
- (b) One of the inoperable channels must be in the tripped condition.
- (c) If only 2 channels are operable, load shall be reduced to 70% or less of rated power.
- (d) Minimum operable channels shall be one (1) and minimum degree of redundancy is zero (0) if shutdown neutron power levels indicated on the log range channels are greater than 3 times the lowest decade in which neutron visibility can be confirmed. Neutron visibility will be confirmed through observation of reactivity changes on neutron power level (including a 1/M plot during reactor startup) and comparing the observed changes to the changes noted on previous similar startups. Instrumentation operability will also be verified by comparison among the three operable channels to ensure their individual responses are in agreement.

Amendment No. 121