



GPU Nuclear Corporation
 Post Office Box 388
 Route 9 South
 Forked River, New Jersey 08731-0388
 609 971-4000
 Writer's Direct Dial Number:

May 15, 1989

Director of Nuclear Reactor Regulation
 U.S. Nuclear Regulatory Commission
 ATTN: Document Control Desk
 Mail Station P1-137
 Washington, D.C. 20555

Gentlemen:

Subject: Oyster Creek Nuclear Generating Station
 Docket No. 50-219
 Generic Letter 83-28

Pursuant to your correspondence of April 11, 1989, GPUN will provide functional testing of the backup scram valves during each refueling outage. Modifications, if any, related to the testing will be accomplished in accordance with the Long Range Planning Program.

The April 11, 1989 correspondence requested a response by May 1, 1989 in order to meet the staff's scheduled completion date. As discussed with Mr. A. Dromerick, NRC Project Manager, on May 1, 1989, this submittal confirms GPUN's commitment to perform the testing described above. It was agreed GPUN would document this commitment by May 15, 1989.

Very truly yours,

E. E. Fitzpatrick
 Vice President and Director
 Oyster Creek

EEF/BDM:aa
 (0751A:01)

cc: Mr. William T. Russell, Administrator
 Region I
 U.S. Nuclear Regulatory Commission
 475 Allendale Road
 King of Prussia, PA 19406

Mr. Alexander W. Dromerick, Project Manager
 U.S. Nuclear Regulatory Commission
 Division of Reactor Projects I/II
 Washington, DC 20555

NRC Resident Inspector
 Oyster Creek Nuclear Generating Station

GPU Nuclear Corporation is a subsidiary of General Public Utilities Corporation

8905240159 890515
 PDR ADDCK 05000219
 PDC

A055
 1/0