

May 18, 1989

Docket No. 50-322

Mr. John D. Leonard, Jr.
Vice President-Nuclear Operations
Long Island Lighting Co.
Shoreham Nuclear Power Station
P.O. Box 618, North Country Road
Wading River, NY 11792

DISTRIBUTION

Docket File
NRC PDR
Local PDR
PDI-2 Reading
SVarga
BBoger
WButler
MO'Brien

SBrown
CShiraki
OGC
EJordan
BGrimes
ACRS (10)

Dear Mr. Leonard:

SUBJECT: GENERIC LETTER 88-14, "INSTRUMENT AIR SUPPLY SYSTEM PROBLEMS
AFFECTING SAFETY RELATED EQUIPMENT" (TAC NO. M 71720)

RE: SHOREHAM NUCLEAR POWER STATION, UNIT 1

Your letter of February 21, 1989, provided LILCO's response to the subject generic letter. In this response LILCO committed to:

- ° Complete its investigation of variances found from design condition and to take appropriate measures to correct those parameters found beyond specification limits.
- ° To evaluate several plant hardware modifications, to ensure that the Shoreham plant does not experience instrument air problems.
- ° To make changes in both the Shoreham's operating procedures and emergency operating procedures to assist operators in identifying and verifying the design responses of selected air operated components.
- ° To change the frequency of preventative maintenance surveillance of the air dryers from 24 to 12 months; and
- ° To enhance the training programs for licensed operation, non-licensed operators and I & C technicians to address instrument air system concern.

The staff has completed its review of your submittal and finds that LILCO is taking correct and positive measures towards ensuring that the Shoreham facility does not experience instrument air system problems.

Sincerely,

/s/

Stewart W. Brown, Project Manager
Project Directorate I-2
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

[LEONARD]

Previously concurred*

PDI-2/PM
SBrown:mr
5/18/89

SPLB/C*
JCraig
05/18/89

PDI-2/D
WButler
5/18/89

8905240389 890518
PDR ADOCK 05000322
P PDC

DFOL
1/0



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

May 18, 1989

Docket No. 50-322

Mr. John D. Leonard, Jr.
Vice President-Nuclear Operations
Long Island Lighting Co.
Shoreham Nuclear Power Station
P.O. Box 618, North Country Road
Wading River, NY 11792

Dear Mr. Leonard:

SUBJECT: GENERIC LETTER 88-14, "INSTRUMENT AIR SUPPLY SYSTEM PROBLEMS
AFFECTING SAFETY RELATED EQUIPMENT" (TAC NO. M 71720)

RE: SHOREHAM NUCLEAR POWER STATION, UNIT 1

Your letter of February 21, 1989, provided LILCO's response to the subject generic letter. In this response LILCO committed to:

- ° Complete its investigation of variances found from design condition and to take appropriate measures to correct those parameters found beyond specification limits.
- ° To evaluate several plant hardware modifications, to ensure that the Shoreham plant does not experience instrument air problems.
- ° To make changes in both the Shoreham's operating procedures and emergency operating procedures to assist operators in identifying and verifying the design responses of selected air operated components.
- ° To change the frequency of preventative maintenance surveillance of the air dryers from 24 to 12 months; and
- ° To enhance the training programs for licensed operation, non-licensed operators and I & C technicians to address instrument air system concern.

The staff has completed its review of your submittal and finds that LILCO is taking correct and positive measures towards ensuring that the Shoreham facility does not experience instrument air system problems.

Sincerely,

A handwritten signature in cursive script, reading "Stewart Brown".

Stewart W. Brown, Project Manager
Project Directorate I-2
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Mr. John D. Leonard, Jr.
Long Island Lighting Company

Shoreham Nuclear Power Station

cc:

Victor A. Staffieri, Esq.
General Counsel
Long Island Lighting Company
175 East Old County Road
Hicksville, New York 11801

W. Taylor Reveley, III, Esq.
Hunton & Williams
Post Office Box 1535
707 East Main Street
Richmond, Virginia 23212

Mr. Lawrence Britt
Shoreham Nuclear Power Station
Post Office Box 618
Wading River, New York 11792

Mr. John Scalice
Plant Manager
Shoreham Nuclear Power Station
Post Office Box 628
Wading River, New York 11792

Resident Inspector
Shoreham NPS
U.S. Nuclear Regulatory Commission
Post Office Box 8
Rocky Point, New York 11778

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Ms. Donna Ross
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223

Supervisor
Town of Brookhaven
205 S. Ocean Ave.
Patchogue, New York 11772

Town Attorney
Town of Brookhaven
3232, Route 112
Medford, NY 11763

MHR Technical Associates
1723 Hamilton Avenue
Suite K
San Jose, California 95125

Richard M. Kessel
Chairman & Executive Director
New York State Consumer Protection
Board
Room 1725
250 Broadway
New York, NY 10007

Jonathan D. Feinberg, Esq.
New York State Department
of Public Service
Three Empire State Plaza
Albany, New York 12223

Gerald C. Crotty, Esq.
Ben Wiles, Esq.
Counsel to the Governor
Executive Chamber
State Capitol
Albany, New York 12224

Herbert H. Brown, Esq.
Lawrence Coe Lanpher, Esq.
Karla J. Letsche, Esq.
Kirkpatrick & Lockhart
South Lobby - 9th Floor
1800 M Street, N.W.
Washington, D.C. 20036-5891

Long Island Lighting Company

- 2 -

Shoreham

cc:

Dr. Monroe Schneider
North Shore Committee
Post Office Box 231
Wading River, NY 11792

Fabian G. Palomino, Esq.
Special Counsel to the Governor
Executive Chamber - State Capitol
Albany, NY 12224

Martin Bradley Ashare, Esq.
Suffolk County Attorney
H. Lee Dennison Building
Veteran's Memorial Highway
Hauppauge, NY 11788

Robert Abrams, Esq.
Attorney General of the State
of New York
ATTN: John Corwin, Esq.
New York State Department of Law
Consumer Protection Bureau
120 Broadway
3rd Floor
New York, NY 10271

Honorable Peter Cohalan
Suffolk County Executive
County Executive/Legislative Building
Veteran's Memorial Highway
Hauppauge, NY 11788

Ms. Nora Bredes
Shoreham Opponents Coalition
195 East Main Street
Smithtown, New York 11787

Chris Nolin
New York State Assembly
Energy Committee
626 Legislative Office Building
Albany, New York 12248

Mr. Charlie Donaldson
Assistant Attorney General
NYS Department of Law
Room 3-118
120 Broadway
New York, NY 10271