



**Northeast  
Nuclear Energy**

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385-0128  
(860) 447-1791  
Fax (860) 444-4277

The Northeast Utilities System

May 8, 1998

Docket No. 50-423  
B17183

Re: 10 CFR 50.73(a)(2)(i)(B)

Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Millstone Nuclear Power Station Unit 3  
Licensee Event Report 98-022-00

"Failure to Provide Required Operable Reactor Coolant System Loops in Mode 4"

This letter forwards Licensee Event Report 98-022-00, documenting a condition that was determined reportable at Millstone Unit No. 3 on April 8, 1998. This LER is submitted pursuant to 10 CFR 50.73(a)(2)(i)(B). Northeast Nuclear Energy Company's (NNECO) commitments in response to this event are contained within Attachment 1 to this letter.

Should you have any questions regarding this submittal, please contact Mr. David A. Smith at (860) 437-5840.

Very truly yours,

NORTHEAST NUCLEAR ENERGY  
COMPANY



G. D. Hicks  
Unit Director, Millstone Unit No. 3

9805170356 980508  
PDR ADOCK 05000423  
S PDR

IE22 1/1

U.S. Nuclear Regulatory Commission  
B17183/Page 2

Attachment: 1) NNECO's commitments in response to LER 98-022-00  
2) LER 98-022-00

cc: H. J. Miller, Region I Administrator  
A. C. Cerne, Senior Resident Inspector, Millstone Unit No. 3  
J. W. Andersen, NRC Project Manager, Millstone Unit No. 3  
W. D. Travers, Ph.D., Director, Special Projects  
Corrective Action Group Files (CR M3-98-1863)

KAM:km

Docket No. 50-123  
B17.33

Attachment 1

Millstone Nuclear Power Station, Unit No. 3  
NNECO's Commitments  
In Response To  
**(LER 98-022-00)**

May 8, 1998



Attachment  
List of Regulatory Commitments

The following table identifies those actions committed to by NNECO in this document. Please notify the Manager - Regulatory Compliance at the Millstone Nuclear Power Station Unit No. 3 of any questions regarding this document or any associated regulatory commitments.

Number	Commitment	Due
B17183-01	The RCP Operability Check Surveillance Procedure acceptance criteria has been revised.	Complete
B17183-02	Training has been conducted for Operations crews on TS 3.4.1.3 requirements.	Complete
B17183-03	Operations personnel involved in the event have been counseled.	Complete
B17183-04	A briefing will be provided to Operations crews on expectations regarding verification of information and performance of electrical line ups, proper use and satisfaction of acceptance criteria, and need for surveillance validation.	May 30, 1998
B17183-05	A briefing will be provided to the Operations procedures group to provide management expectations of clarity and level of detail in surveillance acceptance criteria.	May 30, 1998

Docket No. 50-423

B17183

Attachment 2

Millstone Nuclear Power Station, Unit No. 3  
NNECO's Submittal of  
**(LER 98-022-00)**

May 8, 1998