

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

DUQUESNE LIGHT COMPANY

DHIO EDISON COMPANY

PENNSYLVANIA POWER COMPANY

DOCKET NO. 50-334

BEAVER VALLEY POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 143 License No. DPR-56

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Duquesne Light Company, et al. (the licensee) dated June 22, 1989 and supplement dated July 24, 1989, complies with the standards requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the riles and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8908030091 890727 PDR ADOCK 05000334 PDC PDC

- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-66 is hereby amended to read as follows:
 - (2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 143, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective on issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

(for Willie Butter Bruce A. Boger, Assistant Director For Region I Reactors

Division of Reactor Projects 1/11 Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: July 27, 1989

ATTACHMENT TO LICENSE AMENDMENT NO. 143

FACILITY OPERATING LICENSE NO. DPR-66

DOCKET NO. 50-334

Replace the following pages of the Appendix A (Technical Specifications) with the enclosed pages as indicated. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change.

Remove

Insert

3/4	1-15	3/4	1-15
3/4	1-16	3/4	1-16
3/4	1-17	3/4	1-17
3/4	3-228	3/6	3-228
3/4	3-27	3/4	3-27
3/4	6-2	3/4	6-2
3/4	6-3	3/4	6-3
3/4	6-5	3/4	6-5
3/4	6-5a	3/4	6-5a
3/4	6-6	3/4	6-6
3/4	6-7	3/4	6-7
3/4	6-8	3/4	6-8
3/4	6-11	3/4	6-11
3/4	6-13	3/4	6-13
3/4	7-14	3/4	7-14
B314	6-2	R3/1	1 5-2

REACTIVITY CONTROL SYSTEMS

BORATED WATER SOURCES - SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.1.2.7 As a minimum, one of the following borated water sources shall be OPERABLE:

- a. A boric acid storage system with:
 - 1. A minimum contained volume of 5000 gallons,
 - 2. Between 7000 and 7700 ppm of boron, and
 - 3. A minimum solution temperature of 65°F.
- b. The refueling water storage tank with:
 - 1. A minimum contained volume of 175,000 gallons,
 - 2. A minimum boron concentration of 2000 ppm, and
 - 3. A minimum solution temperature of 45°F.

APPLICABILITY: MODES 5 and 6.

ACTION:

With no borated water source OPERABLE, suspend all operations involving CORE ALTERATIONS or positive reactivity changes until at least one borated water source is restored to OPERABLE status.

SURVEILLANCE REQUIREMENTS

4.1.2.7 The above required borated water source shall be demonstrated OPERABLE:

- a. At least once per 7 days by:
 - 1. Verifying the boron concentration of the water,
 - 2. Verifying the water level of the tank, and
 - Verifying the boric acid storage tank solution temperature when it is the source of borated water.
- b. At least once per 24 hours by verifying the RWST temperature when it is the source of borated water and the outside ambient air temperature is <45°F.</p>

BEAVER	VALLEY	- UNIT	1 3	14	1-15	Amendmen	+ No	143
						ALT 1 Be 1 1 1 1 1 1 1 1 Be 1 1		

REACTIVITY CONTROL SYSTEMS

BORATED WATER SOURCES - OPERATING

LIMITING CONDITION FOR OPERATION

3.1.2.8 As a minimum, the following borated water source(s) shall be OPERABLE as required by Specification 3.1.2.2.

- a. A boric acid storage system with:
 - 1. A minimum contained volume of 11,336 gallons,
 - 2. Between 7000 and 7700 ppm of boron, and
 - 3. A minimum solution temperature of 65°F.
- b. The refueling water storage tank with:
 - A contained volume between 439,050 gallons and 441,100 gallons of borated water,
 - A boron concentration between 2000 and 2100 ppm, and
 - A solution temperature of ≥45°F and ≤55°F.

APPLICABILITY: MODES 1, 2, 3 & 4.

ACTION:

- a. With the boric acid storage system inoperable, restore the storage system to OPERABLE status within 72 hours or be in at least HOT STANDBY and borated to a SHUTDOWN MARGIN equivalent to at least 1% delta k/k at 200°F within the next 6 hours; restore the boric acid storage system to OPERABLE status within the next 7 days or be in COLD SHUTDOWN within the next 30 hours.
- b. With the refueling water storage tank inoperable, restore the tank to OPERABLE status within one hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.1.2.8 Each borated water source shall be demonstrated OPERABLE:

BEAVER VALLEY - UNIT 1 3/4 1-16

Amendment No. 35, 143

REACTIVITY CONTROL SYSTEMS

. .

SURVEILLANCE REQUIREMENTS (Continued)

- a. At least once per 7 days by:
 - 1. Verifying the boron concentration in each water source,
 - 2. Verifying the water level in each water source, and
 - 3. Verifying the boric acid storage system solution temperature.
- b. At least once per 24 hours by værifying the RWST temperature when the RWST ambient air temperature is <45°F or >55°F.

BEAVER VALLEY - UNIT 1 3/4 1-17

Amendment No. 143

TABLE 3.3-4 (Continued)

行.

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

ATION TRIP SETPOINTS	ALLOWABL& VALUES		Not Applicable	Not Applicable	218'2-1/2" and 519'2-1/2"	28'0" and 29'0"
BLE 3.3-4 (Continued) CTUATION SYSTEM INSTRUMENT	TRIP SETPOINT		Not Applicable	Not Applicable	18'8-1/2"	8*6"
TA ENGINEERED SAFETY FEATURE A	FUNCTIONAL UNIT	1.1 SAFETY INJECTION-TRANSFER FROM INJECTION TO THE RECIRCULATION MODE	a. Manual Initiation	b. Automatic Actuation Logic Coincident with Safety Injection Signal	c. Refueling Water Storage Tank Level-Low	d. Refueling Water Storage Tank Level - Auto QS Flow Reduction

TABLE 3.3-5 (Continued)

.

ENGINEERED SAFETY FEATURES RESPONSE TIMES

IN	ITIAT	INS SIGNAL AND FUNCTION	RESPONSE TIME IN SECONDS
4.	Ste	an Line Pressure-Low	
	۵.	Safety Injection (ECCS)	≤ 27.0#/37.0##
	b.	Reactor Trip (from SI)	\$ 3.0
	c.	Feedwater Isolation	≤ 75.0(1)
	d.	Containment Isolation-Phase "A"	≤ 22.0(3)/33.0(2)
	ε.	Auxiliary Feedwater Pumps	Not Applicable
	f.	Rx Plant River Water System	≤ 77.0(3)/110.0(2)
	g.	Steam Line Isolation	≤ 8.0
5.	Cont	ainment PressureHigh-High	
	a.	Containment Quench Spray	≤ 85.0(2)
	b.	Containment Isolation-Phase "B"	Not Applicable
	с.	Control Room Ventilation Isolation	$\leq 22.0(3)/77.0(2)$
б.	Stea	m Generator Water LevelHigh-High	
	۵.	Turbine Trip-Reactor Trip	≤ 2.5
	b.	(Above P-9) Feedwater Isolation	≤ 13.0(2)
7.	Cont	ainment Pressure Intermediate High	-High
	a.	Steam Line Isolation	< 8.0
8.	Stea	mline Pressure Rate High Negative	-
	a.	Steamline Isolation	< 8.0
9.	Loss	of Power	
	۵.	4.16kv Emergency Bus Undervoltage (Loss of Voltage)	≤ 1.3
	b.	4.16kv and 480v Emergency Bus Undervoltage (Degraded Voltage)	<u>≤</u> 95
BEAV	ER VI	ALLEY - UNIT 1 3/4 3-27	Amendment No. 42. 742, 72 738, 143

Correction-letter-dated 5/15/89

CONTAINMENT LEAKAGE

LIMITING CONDITION FOR OPERATION

- 3.6.1.2 Containment leakage rates shall be limited to:
 - a. An overall integrated leakage rate of:
 - 1. < La, 0.10 percent by weight of the containment air per 24 hours at Pa, (40.0 psig), or
 - b. A combined leakage rate of \leq 0.60 L_s for all penetrations and valves subject to Type B and C tests as identified in Table 3.6-1, when pressurized to Pa.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With either (a) the measured overall integrated containment leakage rate exceeding 0.75 La, or (b) with the measured combined leakage rate for all penetrations and valves subject to Types B and C tests exceeding 0.60 La, restore the leakage rate(s) to within the limit(s) prior to increasing the Reactor Coolant System temperature above 200°F.

SURVEILLANCE REQUIREMENTS

4.6.1.2 The containment leakage rates shall be demonstrated at the following test schedule and shall be determined in conformance with the criteria specified in Appendix J of 10 CFR 50* using the methods and provisions of ANSI N45.4-1972:

a. A Type-A test (Overall Integrated Containment Leakage Rate) shall be conducted at 40 ± 10-month intervals during shutdown at Pa (40.0 psig).

Exemption to Appendix J of 10 CFR 50, Section III.D.1(a), granted on December 5, 1984.

BEAVER VALLEY - UNIT 1 3/4 6-2 Amendment No. 82, 143

SURVEILLANCE REQUIREMENTS (Continued)

- b. If any periodic Type A test fails to meet .75 L_a, the test schedule for subsequent Type A tests shall be reviewed and approved by the Commission. If two consecutive Type A tests fail to meet .75 L_a, a Type A test shall be performed at least every 18 months until two consecutive Type A tests meet .75 L_a at which time the above test schedule may be resumed.
- c. The accuracy of each Type A test shall be verified by a supplemental test which:
 - Confirms the accuracy of the Type A test by verifying that the difference between supplemental and Type A test data is within 0.25 L_a.
 - Has a duration sufficient to accurately establish the change in leakage for between the Type A test and the supplemental test.
 - Requires the quantity of gas injected into the containment or bled from the containment during the supplemental test to be equivalent to at least 25 percent of the total measured leakage rate at F_a (40.0 psig).
- d. Type B and C tests shall be conducted with gas at $P_a*(40.0 \text{ psig})$ at intervals no greater than 24 months except for tests involving:
 - 1. Air locks,
 - Penetrations using continuous leakage monitoring systems, and
 - 3. Valves pressurized with fluid from a seal system.
- e. Air locks shall be tested and demonstrated OPERABLE per Surveillance Requirement 4.6.1.3.
- f. Leakage from isolation valves that are sealed with fluid from a seal system may be excluded, subject to the provisions of Appendix J, Section III.C.3, when determining the combined leakage rate provided the seal system and valves are pressurized to at least 1.10 Pa (44.0 psig) and the seal system capacity is adequate to maintain system pressure for at least 30 days.

* Applicable valves may be tested using water as the pressure fluid in accordance with the Inservice Testing Program.

BEAVER VALLEY - UNIT 1 3/4 6-3 Amendment No. %5, 143

CCRTAINMENT SYSTEMS

CONTAINMENT AIR LOCKS

LIMITING CONDITION FOR OPERATION

- 3.6.1.3 Each containment air lock shall be OPERABLE with:
 - Both doors closed except when the air lock is being 8. used for normal transit entry and exit through the containment, then at least one air lock door shall be closed, and
 - An overall air lock leakage rate of less than or equal b. to 0.05 La at Pa (40.0 psig).

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

- 8. With one containment air lock door inoperable:
 - Maintain the associated OPERABLE air lock door 1. closed and either restore the associated inoperable air lock door to OPERABLE status within 24 hours or lock the associated OPERABLE air lock door closed.
 - Operation may then continue until performance of 2. the next required overall air lock leakage test provided that the associated OPERABLE air lock door is verified to be locked closed at least once per 31 days.
 - Otherwise, be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the 3. following 30 hours.
 - The provisions of Specification 3.0.4 are not 4. applicable.
- With a containment air lock inoperable, except as the b. result of an inoperable air lock door, maintain at least one air lock door closed; restore the inoperable air lock to OPERABLE status within 24 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

BEAVER VALLEY - UNIT 1 3/4 6-5 Amendment No. 2, 82, 143

SURVEILLANCE REQUIREMENTS

4.6.1.3 Each containment air lock shall be demonstrated OPERABLE:

- a. Within 72 hours following each containment entry, except when the air lock is being used for multiple entries, then at least once per 72 hours, by verifying no detectable seal leakage when the gap between the door seals is pressurized for at least 2 minutes to:
 - 1. Personnel airlock > 40.0 psig
 - Emergency air lock ≥ 10.0 psig

or, by quantifying the total air lock leakage to insure the requirements of 3.6.1.3.b are met.

- b. By conducting overall air lock leakage tests, at not less than P_a (40.0 psig), and verifying the overall air lock leakage rate is within its limit:
 - i. At least once per 6 months, # and
 - Upon completion of maintenance which has been performed on the air lock that could affect the air lock sealing capability.*
- c. At least once per 18 months during shutdown by verifying:
 - Only one door in each air lock can be opened at a time, and
 - No detectable seal leakage when the volume between the emergency air lock shaft seals is pressurized to greater than or equal to 40.0 psig for at least 2 minutes.

The provisions of Specification 4.0.2 are not applicable.

* Exemption to Appendix J of 10 CFR 50, dated November 19, 1984.

BEAVER VALLEY - UNIT 1 3/4 5-5a

Amendment No. 8, 86, 143

INTERNAL PRESSURE

LIMITING CONDITION FOR OPERATION

3.6.1.4 Primary Containment internal air partial pressure shall be maintained \geq 8.9 PSIA and within the acceptable operation range (below and to the left of the applicable containment temperature limit line) shown on Figure 3.6-1 as a function of river water temperature.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With the containment internal air partial pressure < 8.9 PSIA or above the applicable containment temperature limit line shown on Figure 3.6-1, restore the internal pressure to within the limits within 1 hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.6.1.4 The primary containment internal pressure shall be determined to be within the limits at least once per 12 hours.

BEAVER VALLEY - UNIT 1 3/4 6-6

Amendment No. 143





MAXIMUM ALLOWABLE PRIMARY CONTAINMENT AIR PRESSURE VERSUS RIVER WATER TEMPERATURE

BEAVER VALLEY - UNIT 1 3/4 6-7

Amendment No. 37, 143

AIR TEMPERATURE

LIMITING CONDITION FOR OPERATION

3.6.1.5 Primary containment average air temperature shall be maintained:

- a. Greater than or equal to 75°F and less than or equal to 105°F, or
- b. Greater than or equal to 95°F and less than or equal to 105°F

in accordance with the requirements of Figure 3.6-1.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With the containment average air temperature > 105°F or less than the minimum containment temperature prescribed in Figure 3.6-1 (75°F or 95°F) restore the average air temperature to within the limit within 8 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.6.1.5 The primary containment average maximum and minimum air temperatures shall be the arithmetical average of the temperatures at the following locations and shall be determined at least once per 24 hours. The nearest alternate thermocouple may be used for temperature determination up to a maximum of one per location.

Location

- a. Reactor Head Storage Area Elev. 802
- b. Pressurizer Cubicle Elev. 740
- c. Annulus Elev. 777
- d. RHR Heat Exchanger Elev. 730
- e. Annulus Elev. 701

BEAVER VALLEY - UNIT 1 3/4 6-8

Amendment No. 52, 143

3/4.6.2 DEPRESSURIZATION AND COOLING SYSTEMS

CONTAINMENT QUENCH SPRAY SYSTEM

LIMITING CONDITION FOR OPERATION

3.6.2.1 Two separate and independent containment quench spray subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With one containment quench spray subsystem inoperable, restore the inoperable subsystem to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.6.3.1 Each containment guench spray subsystem shall be demonstrated OPERABLE;

- At least once per 31 days by: 8.
 - Verifying that each valve (manual, power-operated, 1. or automatic) in the flow path not locked, sealed, or otherwise secured in position, is in its correct position; and
 - Verifying the temperature of the borated water in 2. the refueling water storage tank is within the limits of Specification 3.1.2.8.b.3.
- At least once per 31 days on a STAGGERED TEST BASIS, by b. verifying, that on recirculation flow, each pump develops a differential pressure of greater than or equal to 142 psid at a flow of 2 1600 gpm when tested pursuant to Specification 4.0.5.

BEAVER VALLEY - UNIT 1 3/4 6-11 Amendment No. 26, 742, 143

CONTAINMENT RECIRCULATION SPRAY SYSTEM

LIMITING CONDITION FOR OPERATION

3.6.2.2 Four separate and independent containment recirculation spray subsystems, each composed of a spray pump, associated heat exchanger and flow path shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With one containment recirculation spray subsystem inoperable, restore the inoperable subsystem to CPERABLE status within 7 days or be in HOT STANDBY within the next 6 hours; restore the inoperable spray system to OPERABLE status within the next 48 hours or be in COLD SHUTDOWN within the next 30 hours.

SURVEILLANCE REQUIREMENTS

4.6.2.2 Each containment recirculation spray subsystem shall be demonstrated OPERABLE:

- a. At least once per 31 days by verifying that each accessible valve (manual, power-operated, or automatic) in the flow path not locked, sealed or otherwise secured in position, is in its correct position;
- b. When tested pursuant to Specification 4.0.5, manually start each recirculation spray pump and verify the pump shaft rotates;
- c. At least once per 18 months by verifying that on a Containment Pressure-High-High signal, the recirculation spray pumps start automatically as follows:

RS-P-1A and RS-P-2B 210 ± 5 second delayRS-P-2A and RS-P-1B 225 ± 5 second delay

d. At least once per 18 months during shutdown, verify that on recirculation flow, each pump develops the required differential pressure and flow rate as shown below when tested pursuant to Specification 4.0.5:

KS-P-1A	and	RS-P-1B	>	127	psid	=	>	2000	-
DC-D-DA	and	80.8.48	-		En en or se	GL 5-	-	2000	Shu
NO-L-CW	ang	KD-F-2B	>	132	Dsid	24	5	2000	27 87 54

BEAVER VALLEY - UNIT 1 3/4 6-13 Amendment No. 442, 143

PLANT SYSTEMS

3/4.7.5 ULTIMATE HEAT SINK - OHIO RIVER

LIMITING CONDITION FOR OPERATION

3.7.5.1 The ultimate heat sink shall be OPERABLE with:

- a. A minimum water level at or above elevation 654 Mean Sea Level, at the intake structure, and
- b. An average water temperature of <90°F.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With the requirements of the above specification not satisfied, be in at least HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVETLIANCE REQUIREMENTS

4.7.5.1 The ultimate heat sink shall be determined OPERABLE at least once per 24 hours by verifying the average water tomperature and water level to be within their limits.

BEAVER VALLEY - UNIT 1 3/4 7-14 Amendment No. 94, 147, 143

BASES

. .

3/4.6.1.4 and 3/4.6.1.5 INTERNAL PRESSURE AND AIR TEMPERATURE

The limitations on containment internal pressure and average air temperature as a function of river water temperature ensure that 1) the containment structure is prevented from exceeding its design negative pressure of 8.0 psia, 2) the containment peak pressure does not exceed the design pressure of 45 psig during LOCA conditions, and 3) the containment pressure is returned to subatmospheric conditions following a LOCA.

The containment internal pressure and temperature limits shown as a function of river water temperature describe the operational envelope that will 1) limit the containment peak pressure to less than its design value of 45 psig and 2) ensure the containment internal pressure returns subatmospheric within 60 minutes following a LOCA.

The limits on the parameters of Figure 3.6-1 are consistent with the assumptions of the accident analyses.

3/4.6.1.6 CONTAINMENT STRUCTURAL INTEGRITY

This limitation ensures that the structural integrity of the containment vessel will be maintained comparable to the original design standards for the life of the facility. Structural integrity is required to ensure that the vessel will withstand the maximum pressure of 40.0 psig in the event of a LOCA. The visual and Type & leakage tests are sufficient to demonstrate this capability.

3/4.6.2 DEPRESSURIZATION AND COOLING SYSTEMS

3/4.6.2 and 3/4.6.2.2 CONTAINMENT QUENCH AND RECIRCULATION SPRAY SYSTEMS

The OPERABILITY of the containment spray systems ensures that containment depressurization and subsequent return to subatmospheric pressure will occur in the event of a LOCA. The pressure reduction and resultant termination of containment leakage are consistent with the assumptions used in the accident analyses.

"nendment No. 113

-

1

1

1