

September 15, 1989

Docket Nos. 50-317
and 50-318

Mr. G. C. Creel
Vice President - Nuclear Energy
Baltimore Gas & Electric Company
Calvert Cliffs Nuclear Power Plant
MD Rts. 2 & 4
Post Office Box 1535
Lusby, Maryland 20657

DISTRIBUTION

~~Docket file~~

NRC & Local PDRs
PDI-1 r/f
SVarga
SMcNeil
AD/RI
CVogan
LTripp

OGC
EJordan
BGrimes
RCapra
Plant file
JWiggins
ACRS (10)
TChan

Dear Mr. Creel:

SUBJECT: GENERIC LETTER 89-08, "EROSION/CORROSION INDUCED PIPE WALL
THINNING" (TAC NOS. 73465 AND 73466)

On May 2, 1989, the NRC issued Generic Letter (GL) 89-08 which requested you to stipulate whether or not you have implemented, or intend to implement, a long term erosion/corrosion monitoring program to ensure the structural integrity of all single and two phase high-energy carbon steel systems at Calvert Cliffs Units 1 and 2.

Your response dated July 19, 1989, confirmed that you currently have such a program and that by December 31, 1989 a controlling procedure shall be in place establishing implementation and administrative requirements for this erosion/corrosion monitoring program. Consequently, your response to GL 89-08 is satisfactory and shall be considered complete contingent upon your implementation of the program controlling procedure.

To facilitate closure of this action, it is requested that you submit written notification to the NRC that the erosion/corrosion program controlling procedure is in place and that this program has been fully implemented.

Please provide the requested information within 60 days following the effective date of full erosion/corrosion program implementation at Calvert Cliffs.

This request for information affects fewer than 10 respondents; therefore, OMB clearance is not required under Public Law 95-511.

Sincerely,

Scott Alexander McNeil

Scott Alexander McNeil, Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

8909280141 890915
PDR ADDOCK 05000317
F PDC

cc: See next page

[SM LTR2 GCREEL 73465/6]

DFOI
1/1

PDI-1
CVogan
9/15/89

PDI-1 *Sam*
SMcNeil:dmj
9/15/89

PDI-1 *Sam*
RCapra *for*
9/15/89



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

September 15, 1989

Docket Nos. 50-317
and 50-318

Mr. G. C. Creel
Vice President - Nuclear Energy
Baltimore Gas & Electric Company
Calvert Cliffs Nuclear Power Plant
MD Rts. 2 & 4
P. O. Box 1535
Lusby, Maryland 20657

Dear Mr. Creel:

SUBJECT: GENERIC LETTER 89-08, "EROSION/CORROSION INDUCED PIPE WALL
THINNING" (TAC NOS. 73465 AND 73466)

On May 2, 1989, the NRC issued Generic Letter (GL) 89-08 which requested you to stipulate whether or not you have implemented, or intend to implement, a long term erosion/corrosion monitoring program to ensure the structural integrity of all single and two phase high-energy carbon steel systems at Calvert Cliffs Units 1 and 2.

Your response dated July 19, 1989, confirmed that you currently have such a program and that by December 31, 1989 a controlling procedure shall be in place establishing implementation and administrative requirements for this erosion/corrosion monitoring program. Consequently, your response to GL 89-08 is satisfactory and shall be considered complete contingent upon your implementation of the program controlling procedure.

To facilitate closure of this action, it is requested that you submit written notification to the NRC that the erosion/corrosion program controlling procedure is in place and that this program has been fully implemented.

Please provide the requested information within 60 days following the effective date of full erosion/corrosion program implementation at Calvert Cliffs.

This request for information affects fewer than 10 respondents; therefore, OMB clearance is not required under Public Law 95-511.

Sincerely,

A handwritten signature in cursive script, reading "Scott Alexander McNeil".

Scott Alexander McNeil, Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

cc: See next page

Mr. G. C. Creel
Baltimore Gas & Electric Company

Calvert Cliffs Nuclear Power Plant

cc:

Mr. William T. Bowen, President
Calvert County Board of
Commissioners
Prince Frederick, Maryland 20678

Mr. Joseph H. Walter
Engineering Division
Public Service Commission of Maryland
American Building
231 E. Baltimore Street
Baltimore, Maryland 21202-3486

D. A. Brune, Esq.
General Counsel
Baltimore Gas and Electric Company
P. O. Box 1475
Baltimore, Maryland 21203

Ms. Kirsten A. Burger, Esq.
Maryland People's Counsel
American Building, 9th Floor
231 E. Baltimore Street
Baltimore, Maryland 21202

Mr. Jay E. Silberg, Esq.
Shaw, Pittman, Potts and Trowbridge
2300 N Street, NW
Washington, DC 20037

Mr. W. J. Lippold, General Supervisor
Technical Services Engineering
Calvert Cliffs Nuclear Power Plant
MD Rts 2 & 4, P. O. Box 1535
Lusby, Maryland 20657

Resident Inspector
c/o U.S. Nuclear Regulatory Commission
P. O. Box 437
Lusby, Maryland 20657

Mr. Thomas Magette
Administrator - Nuclear Evaluations
Department of Natural Resources
580 Taylor Avenue
Tawes State Office Building
PPER B3
Annapolis, Maryland 21401

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406