

REVISION	0	1	2	3
----------	---	---	---	---

Subject Safety Analysis of the Dose Consequences of a Locked Rotor Accident at BVPS-1 with 18% Fuel Failure -- EAB, LPZ, Control Room	ERS - SFL-89-021	PAGE 1 OF 107
--	------------------	------------------

Reference -----n/a-----

RCM RP _____ EPP _____ T/S _____ EM _____ DCP _____ Other _____

RIP _____

Review Category

RSC Req'd RSC Not Req'd

10CFR 50.59 Required

Purpose

The purpose of this calculation package is to determine the dose consequences at the EAB, LPZ and in the control room from a locked rotor accident at BVPS-1, with the assumption of 18% fuel failures.

	BY _____ Date _____
	CHK _____ Date _____
	APP _____ Date _____
3	BY _____ Date _____
	CHK _____ Date _____
	APP _____ Date _____
2	BY _____ Date _____
	CHK _____ Date _____
	APP _____ Date _____
1	BY _____ Date _____
	CHK _____ Date _____
	APP _____ Date _____

0	BY <i>[Signature]</i> 19 JUL 1989 Date	<p>Checklist</p> <input checked="" type="checkbox"/> PURPOSE <input type="checkbox"/> INPUT DATA <input checked="" type="checkbox"/> ASSUMPTIONS <input checked="" type="checkbox"/> RESULTS <input checked="" type="checkbox"/> METHODOLOGY <input type="checkbox"/> REFERENCES	<p>Attachments</p> <input type="checkbox"/> DATA SHEETS <input checked="" type="checkbox"/> ILLUSTRATIONS <input checked="" type="checkbox"/> PRINTOUTS <input checked="" type="checkbox"/> CODE LISTING
	CHK <i>[Signature]</i> 7/25/89 Date		
	APP FOR RADIATION SAFETY ANALYSIS ATE 15-89 <i>[Signature]</i> Date		

<input checked="" type="checkbox"/> Document Control	<input type="checkbox"/> DIR, RadOps-1	<input checked="" type="checkbox"/> Trng. Dept.
<input checked="" type="checkbox"/> Calculation File	<input type="checkbox"/> DIR, RadOps-2	<input checked="" type="checkbox"/> Author: <u>S.F. LaVie</u>
<input checked="" type="checkbox"/> MGR, RADCON	<input type="checkbox"/> DIR, RadHealth	<input checked="" type="checkbox"/> <u>R. Ireland</u>
<input checked="" type="checkbox"/> DIR, RadEng	<input type="checkbox"/> DIR, Eff. & Env.	<input type="checkbox"/> _____



TABLE OF CONTENTS

Purpose	1
Discussion	3
Methodology	4
Input Data/Assumptions	5
Calculations	
X/Q for 1-4 Day Period at LPZ	8
Source Term Development	8
Release Transfer Lambdas	9
Release Models	10
Control Room Modeling	11
Control Room Dose Rate Versus Time	12
Offsite and Control Room Doses	13
Isotopic Releases	13
Results	13
Conclusions	15
References	15
Attachments	
1. Source Term Table	18
2. Release Model Illustration	19
3. Control Room Intake/Exhaust Model	21
4. Computer Runs for Control Room Dose Rate	22
5. Control Room Dose Rate Versus Time - 10% F.F.	48
6. Control Room Dose Rate Versus Time - 1% F.F.	49
7. Computer Runs for Offsite/Control Room Doses - 10% F.F.	50
8. Computer Runs for Offsite/Control Room Doses - 1% F.F.	90
9. 0-2 hour Isotopic Releases	106
10. 0-8 hour Isotopic Releases	107



DISCUSSION

The locked rotor is an ANS Condition IV event that is analyzed for determination of peak RCS pressure and peak fuel clad temperature assuming DNB has occurred in the core [Ref: 1]. The Unit 1 UFSAR [Ref: 2] Section 14.2.7 analyzed the locked rotor accident for nuclear and thermodynamic consequences. The evaluation concluded that the peak clad temperature would be less than 2700°F. The Radiological consequences were not evaluated since the UFSAR postulated no fuel damage. The NRC Safety Evaluation Report [Ref: 3] did not address radiological consequences of the locked rotor accident.

For cycle 8 at Unit 1, it is proposed that fuel of a different design be used for the reload. In support of this change and at the request of DLC, Westinghouse prepared a safety evaluation [Ref: 1], based largely on the generic licensing topical report WCAP-10444 [Ref: 4]. The locked rotor analysis performed therein assessed the peak RCS pressure and peak fuel clad temperature concerns, but concluded that because the fuel clad temperature did not exceed 2700°F, there would be no fuel damage, and therefore, no change in postulated consequences.

The NRC, in their acceptance letter for WCAP-10444 (included in Ref: 4), took exception to the conclusions regarding locked rotor accidents noting that: "...It has been and continues to be the NRC position that cladding failure is assumed to occur when the fuel rod DNBR is less than the safety limit...." The acceptance letter further stipulated that all licensees referencing WCAP-10444 should assume that all fuel which experiences a DNBR of less than the DNBR limit fails and should calculate the offsite dose consequences. The letter established several key analysis assumptions.

Since the peak RCS pressure and fuel clad temperature analyses are performed assuming the existence of DNB in the core, DLC requested that Westinghouse provide an evaluation of DNB resulting from a locked rotor event at Unit 1. A summary of this analysis was provided in Ref: 5. Significant conclusions are listed below:

- o 12.5% of the fuel rods will exceed DNB for the cycle 8 fuel rod power census.
- o 18% of the fuel rods will exceed DNB based on conservative fuel rod power census. This is expected to bound all fuel cycles.
- o There is available margin in the assumed DNB and FAH limits that could be reduced for cycle 8 should dose consequences exceed limits.
- o The existing licensing basis for Unit 1, i.e., maximum fuel clad temperature does not exceed 2700°F, is not exceeded by the new analyses, and therefore, no fuel rod cladding failures are predicted (even though DNB is exceeded).
- o Westinghouse has submitted a topical report (WCAP-11157) to the NRC addressing the integrity of fuel rods during locked rotor accidents. However, this report has not been reviewed by the NRC.



In anticipation of NRC comments, an analysis of the radiological consequences was initiated and before the analysis could be documented, the NRC did formally request that DLC provide results of analyses of the radiological consequences (along with other related data). The analysis documented herein, which is based on the Standard Review Plan [Ref: 6] Sections 15.3.3 - 15.3.4, is intended to provide the requested evaluation.

It is important to note that the Standard Review Plan was not part of the original design base for Unit 1. In addition, the Unit 1 FSAR [Ref: 2] postulated accident analyses do not assume coincident loss of offsite power capability, without which loss, the environmental releases are negligible.

METHODOLOGY

This analysis will be performed using the TRAILS code documented in ERS-SFL-89-020 [Ref: 7]. TRAILS is a simple FORTRAN program that mechanizes the solution of first order linear equations and dose calculations. Although the code is documented in detail in reference 7, the more significant methodologies, constants, and assumptions incorporated into the code are listed below:

- o The code implements a model of the release that incorporates one or two compartments (or nodes) prior to the release to the environment. The transport of radioactive material through the system is governed by simple first order linear equations based on the postulated flow rates and the radionuclide decay constants.
- o The offsite dose calculational methods are those provided in Regulatory Guide 1.4 [Ref: 8]. Thyroid dose conversion factors and breathing rates are those provided in TID14844 [Ref: 9] and Regulatory Guide 1.4. The average energy per disintegration for included isotopes (Kr, Xe, I) were calculated from the spectra data provided in the DRALIST data library [Ref: 10], which is a subset of the ORNL Evaluated Nuclear Structure Data File, and which is available in hardcopy as DOE/TIC-11026 [Ref: 11]. This data source was used in lieu of the suggested 6th Edition, Table of Isotopes, which is no longer in print.
- o The control room is treated as a compartment with variable (by time step) intake, filtration, X/Q, breathing rate, and exhaust rates.

The 0-2 hour isotopic releases and EAB doses, the 0-8 hour isotopic releases and LPZ doses, and the duration control room doses will be evaluated. The release modeling that will be utilized is similar to that used by SWEC in the evaluation of the combined control room habitability in 1987 [Ref: 12, 13]. In that analysis, SWEC performed an evaluation of control room doses due to a locked rotor accident at Unit 1 in order to meet Unit 2 licensing commitments, assuming no fuel failures.

Since the control room doses are sensitive to the timing of control room isolation initiated by area radiation monitors, an evaluation of the control room dose rate at various times post-accident is assessed first.



Based on these results, an isolation time is postulated and included as an analysis assumption during evaluation of control room dose over the duration of the accident.

The analyses address the following release components:

1. Release of iodine activity from the three steam generators due to technical specification primary-to-secondary leakage. Iodine partitioning is assumed. The activity is based on 18% fuel clad failure, with the fuel clad activity based on Standard Review Plan assumptions (i.e., 30% Kr-85, 10% all others), with the exception of I-131, which is assumed to be 12% in keeping with the conclusions of NUREG/CR-5009 [Ref: 14].
2. Same as #1, but for noble gases with no credit for partitioning.
3. Release of activity released into the RCS and hence to the three steam generators by an iodine spike that occurs concurrent with the locked rotor. RCS leak rate based on technical specifications.
4. Release of the initial activity contained in the steam in all three steam generators at time=0. This activity based on technical specifications.
5. Release of the initial activity of iodine contained in the secondary liquid in all three steam generators at time=0. (Noble gases are assumed to be in the steam space.) This activity based on technical specifications.

Releases from steam generators are based on the steam mass releases postulated by Westinghouse for 0-2 hours and 0-8 hours [Ref: 18].

The release of activity based on 18% fuel failure results in unisolated, unfiltered control room dose rates that exceed the area radiation monitor alarm setpoint within 30 seconds of the start of the release. This radiation monitor initiates control room isolation and pressurization. To assess a concern that the rapid control room isolation might not be the most restrictive situation, cases 4 and 5 above were evaluated assuming 1% fuel failure (results in an isolation delay of 20 minutes). These cases were not limiting, i.e., did not result in doses in excess of GDC-19 in 10 CFR 50 Appendix A [Ref: 15]. In order to provide flexibility for potential future control room integrity technical specification amendments, the control room analyses were performed assuming a 15 minute isolation period, which includes the previously assumed 3 minute isolation delay (e.g., monitor response time, damper closure time, etc)

INPUT DATA/ASSUMPTIONS

1. General Methodology Based on SRP 15.3.3-15.3.4 [6]
2. Core Inventory from Table 14B-1 [2]

Based on 2766 MWT



3. Core-Gap Fractions

Kr-85	0.30	[16]
I-131	0.12	[14]
Others	0.10	[16]

The assumptions of references 14 and 16 are included, even though they are not specifically applicable to a locked rotor accident. This is conservative.

4. Fraction of Rods in DNB = 18% [5]

5. Fraction of Rods Assumed Failed = 18% (Section 15.3.3) [6]

6. Concurrent Spike Appearance Rates, $\mu\text{Ci}/\text{sec}$ (Tbl 15.0-10) [16]

I-131	1.36E6
I-132	2.52E6
I-133	3.08E6
I-134	3.68E6
I-135	2.81E6

7. Concurrent Spike Duration 0-4 hours [18]

Assume appearance rates are 1/500 for 4-8 hours

8. RCS Volume = $3.9\text{E}5$ lbs [18]

9. RCS Primary-to-Secondary Leakage = 1 gpm total [19]

10. Steam Generator Mass [18]

Liquid	= 97900 lbs
Steam	= 6460 lbs

11. Steam Generator Mass Release [18]

0-2 hours	= 443,878 lbs
2-8 hours	= 793,644 lbs

12. Iodine Partitioning in Steam Generators = 0.01 [18]

13. Duration of Plant Cooldown by Secondary System, i.e., [18]
Duration of Release = 8 hours

14. Receptor Distances [2]

EAB	= 610 meters
LPZ	= 3.6 mi (5800 meters)



15. I/Q Values EAB/LPZ [2,20]

0-2 hours EAB = $3.9E-4$ sec/m³
 0-8 hours LPZ = $4.2E-5$ *
 8-24 hours LPZ = $2.7E-5$
 24-720 hrs LPZ = $6.8E-6$
 Worst Sector LPZ Annual Average = $2.56E-6$

*UFSAR table 2.2-11 identifies a 0-2 hour value. However, in accordance with reference 22, a 0-8 hour value is used for all time steps upto 8 hours.

16. I/Q Values Control Room Intake [21]

0-8 hours = $2.97E-3$ sec/m³
 8-24 hours = $1.94E-3$ sec/m³
 24-96 hours = $6.92E-4$ sec/m³
 96-720 hrs = $1.54E-4$ sec/m³

17. Monitor Response Delay Time = 3 minutes [13]

based on: ramp time of 97 sec to reach 1 m²/hr plus
 C.R. isolation time (diesel sequence delay) of
 77 seconds (BVI controlling)

18. Control Room Volume = $1.73E5$ ft³ [18]

19. Control Room Normal Intake = 500 ft³/min [18]

20. Control Room Pressurization Rate = 690 ft³/min [13]

21. Control Room Infiltration = 10 ft³/min (Section 6.4) [6]

22. Control Room Filter Efficiency = 95% [18]

To account for 10 cfm infiltration bypass, this is reduced to:

$$\frac{690(.95) + 10(0)}{690 + 10} = .936$$

23. Control Room Purge Flow = 33000 ft³/min [2]

Based on recirculation fan flow rate which can be used to purge the control room.

24. Purge Initiation = T=8 hours [Assumption]



CALCULATIONS

1. Calculate X/Q for 1-4 day period for LPZ

The 1-4 day X/Q value for the LPZ was not tabulated in the UFSAR nor in the supporting calculation package ERS-SFL-83-015, but is needed since the 1-4 day time step is included consistent with the original SWEC LRA analysis for control room habitability.

Regulatory Guide 1.145 [Ref: 22] provides that the LPZ X/Q values versus time can be calculated using regression between the 0.5% observation and the annual average X/Q values. The slope is found by:

$$\text{Slope} = \frac{\ln \left(\frac{\text{Annual Avg X/Q}}{0.5\% \text{ X/Q}} \right)}{\ln (8760)} = \frac{\ln \left(\frac{2.56\text{E-}6}{9.50\text{E-}5} \right)}{\ln (8760)} = -0.398$$

The 1-4 day (96 hours) X/Q is found from:

$$\text{X/Q} = (2.56\text{E-}6) \left(\frac{96}{8760} \right)^{-0.398} = 1.54\text{E-}5$$

(Methodology extracted from PAVAN [Ref: 23] and XQDOQ [Ref: 24] codes.)

2. Source Term Development

Attachment 1 documents the development of the source terms used for the different cases involved with the locked rotor accident.

The gap activity is calculated from the core inventory values provided in Table 14B-1 of the Unit 1 UFSAR [Ref: 2], using the core-gap fractions provided as input item #3. The gap activity is used as the basis for RCS activity rather than UFSAR table 14B-6, as the latter is based on equilibrium activity (i.e., credit for letdown cleanup). The instantaneous increase is modeled herein.

The 1% and 18% failed fuel gap release is determined from the gap activity as follows:

$$\begin{aligned} 1\% \text{ F.F. gap release, Ci} &= \text{Gap Activity, Ci} \times 0.01 \\ 18\% \text{ F.F. gap release, Ci} &= \text{Gap Activity, Ci} \times 0.18 \end{aligned}$$

This analysis assumes that the gap release is instantaneously and homogeneously dispersed throughout the RCS. The initial technical specification concentration ($\mu\text{Ci/gm}$) in the RCS is converted to added activity in Ci and added to the gap release activity to obtain the total activity available for release via a primary-to-secondary leak.

Note: In this analysis, reference is made to technical specification concentrations in the RCS and the steam generators. The BVPS-1 technical specifications [Ref: 19] do not provide isotopic limits, but rather specify dose equivalent iodine of 1.0 $\mu\text{Ci/gm}$ in the RCS and 0.1 $\mu\text{Ci/gm}$ in the steam generator. Isotopic values that equate



to these limits were developed by SWEC for the control room habitability effort in calculation 12241-UR(B)-451. These isotopic values will be referred to as the "technical specification concentrations" in this package.

The activity, Ci, in the liquid phase of the three steam generators is based on the technical specification concentrations determined from the $\mu\text{Ci/gm}$ data provided in SWEC 12241-UR(B)-451, as follows:

$$C_l = (\text{Sec Conc, } \mu\text{Ci/gm})(3 \text{ SG})(97900 \text{ \#/SG})(453.59 \text{ gm/\#})(1\text{E-}6 \text{ Ci}/\mu\text{Ci})$$

The activity, Ci, in the steam phase of the three steam generators is based on the technical specification concentrations determined from the $\mu\text{Ci/gm}$ data provided in SWEC 12241-UR(B)-451, as follows:

$$C_s = (\text{Sec Conc, } \mu\text{Ci/gm})(3 \text{ SG})(6460 \text{ \#/SG})(453.59 \text{ gm/\#})(1\text{E-}6 \text{ Ci}/\mu\text{Ci})$$

3. Determine Transfer Lambdas

The RCS leak rate lambda is obtained from:

$$\frac{1.0 \frac{\text{gal}}{\text{min}} \times \frac{\text{min}}{60 \text{ sec}} \times 8.34 \frac{\text{lbs}}{\text{gal}}}{3.9\text{E}5 \text{ \#}} = 3.564\text{E-}7 \text{ sec}^{-1}$$

The 0-2 hour steam generator release lambda is obtained from:

$$\frac{\frac{443878 \text{ \#}}{2 \text{ hr}} \times \frac{\text{hr}}{3600 \text{ sec}}}{(3)(97900)\text{ \#}} = 2.099\text{E-}4 \text{ sec}^{-1}$$

The 2-8 hour steam generator release lambda is obtained from:

$$\frac{\frac{793644 \text{ \#}}{6 \text{ hr}} \times \frac{\text{hr}}{3600 \text{ sec}}}{(3)(97900)\text{ \#}} = 1.251\text{E-}4 \text{ sec}^{-1}$$

The 0-2 hour value will be used as the base value. The multiplier for the 2-8 hour period is:

$$1.251\text{E-}4 / 2.099\text{E-}4 = 0.596$$

To model the iodine partitioning in the steam generators, the transfer lambda will be reduced by a factor of 100 to $2.099\text{E-}6$ for those cases involving iodine (other than initial steam). The reduction in transfer lambda is proper in this case, since the partitioned iodine remains in the steam generator.

To model the initial steam release as a puff, the release lambda for this case was taken as $1.28\text{E-}3 \text{ sec}^{-1}$. This was based on an SWEC assumption of 99.99% of the release being complete by 2 hours (0.0833 days). However,



it was subsequently decided to increase this by a factor of 100, since initial code runs showed significant activity remaining in the steam generator at time=2 hours. The original value was based on:

$$N_t = N_0 e^{-\lambda t}$$

$$\ln \frac{N_t}{N_0} = -\lambda t$$

$$\ln \frac{(1-.9999)}{1} = -\lambda(0.0833)$$

$$\lambda = 111 \text{ d}^{-1} = 1.285\text{E-}3 \text{ s}^{-1} = 1.285\text{E-}1 \text{ s}^{-1}$$

4. Release Models

The release models are illustrated in Attachment 2. These models are described briefly below.

In all cases, the offsite X/Q values are set to the values for the LPZ. The 0-2 hour EAE doses will be calculated from the 0-2 hour LPZ value by ratioing the applicable X/Q values.

Case 1a & b

Models 1a and 1b evaluated the technical specification leakage of iodines from the RCS to the three steam generators. The RCS is modeled as compartment one and the three steam generators together are modeled as compartment two. Transfer lambdas determined above are used. S/G lambdas were reduced by 100 to account for partitioning. The RCS release is modeled at a constant rate for 720 hours. The steam generator release is halted at 8 hours. The source terms for cases 1a and 1b are taken from column J of Attachment 1.

Note: Case 1a (18% F.F.) was not evaluated for the control room dose rate evaluation. Case 1b (1% F.F.) had been run first, and based on those results, it was determined that case 2a would be more limiting than case 1a.

Case 2a & 2b

Cases 2a and 2b evaluated the technical specification leakage of noble gases from the RCS to the three steam generators. Since no holdup of noble gases is assumed in the steam generators, the release is modeled as being from the RCS directly to the environment. The RCS is modeled as compartment two (compartment one not used). RCS transfer lambda determined above is the basis of the release. The release is halted at 8 hours. The source terms are taken from column J of Attachment 1.

NOTE: In this package, the terms "model" and "case" are used to denote components of the overall solution, rather than an alternative solution. The total consequence is the sum of the consequences of the individual models or cases. However, cases 1b and 2b are alternate solutions for cases 1a and 2a respectively.

Case 3

Case 3 evaluated the release of concurrent iodine spike activity via primary-to-secondary leakage. The modeling is similar to that of Case 1a, with the following exceptions: (1) there is no initial activity; (2) the iodine spike is introduced into the RCS as an independent production equal to the isotopic appearance rates for 0-4 hours; (3) the production rate is reduced to 1/500 for the period of 4-8 hours. (The concurrent iodine spike is based on the assumption of a 500 times increase in the iodine appearance rate.)

Case 4

Case 4 evaluated the release of the initial activity in the steam space of all three steam generators. The steam generators are modeled as compartment two (compartment one is not used). The activity in the steam space is as shown in column F of Attachment 1. The release duration is 2 hours.

Case 5

Case 5 evaluated the release of the initial activity in the secondary liquid in all three steam generators. The steam generators are modeled as compartment two (compartment one is not used). The activity in the steam space is as shown in column E of Attachment 1. The release duration is 8 hours. S/G transfer lambdas reduced by a factor of 100 to account for partitioning.

5. Control Room Intake Modeling

See Attachment 3.

For the dose rate evaluation, the control room intake and exhaust are set to the normal system arrangement of 500 ft³/min with no isolation and no filtration. The time steps evaluated were 1000, 1100, 1200, 1300, 1800, 2400, and 3000 seconds for cases 1b, 2b, and 3-5. For case 2a, the time steps were 30, 40, 50, 60, 90, 120, and 180 seconds.

For the dose evaluation, the following modeling was performed:

- o The control room intake and exhaust were assumed to be equal to the normal intake rate (500 ft³/min) without filtration until the area radiation monitor initiates isolation and pressurization (assumed to be 900 seconds).
- For the one hour period following isolation in which the control room is pressurized, the only intake is the unfiltered 10 ft³/min infiltration. The exhaust is equal to the pressurization rate of 690 ft³/min plus the infiltration, for a total of 700 ft³/min.



- o At one hour following isolation, the control room ventilation re-aligns for emergency filtered intake of approximately 1000 ft³. Since the emergency fans were designed to maintain the requisite 1/8" water gage pressure differential, and since the assumed exfiltration rate is 700 ft³/min, the ai. intake necessary to maintain the differential is assumed to be 700 ft³/min. This emergency ventilation continues for 8 hours.
- o Following the stop of the release at 8 hours, the recirculation fans will be used to purge (unfiltered intake) the control room for 30 minutes.
- o Normal system alignment is restored at 8.5 hours.

6. Control Room Dose Rate versus Time

Models 1b, 2b, and 3-5 were run. The printouts from these runs are provided in Attachment 4. In summary:

Control Room Photon Dose Rates (mR/hr) versus Time

sec	Case 1b	Case 2b	Case 3	Case 4	Case 5	Total
1000	2.16E-3	7.10E-1	1.55E-5	1.01E-4	2.94E-4	7.12E-1
1100	2.60E-3	7.44E-1	2.07E-5	9.98E-5	3.22E-4	7.47E-1
1200	3.06E-3	7.78E-1	2.68E-5	9.90E-5	3.49E-4	7.81E-1
1300	3.55E-3	8.13E-1	3.39E-5	9.81E-5	3.76E-4	8.17E-1
1400	6.43E-3	9.78E-1	8.65E-5	9.40E-5	5.06E-4	9.84E-1
2400	1.06E-2	1.15E+0	1.94E-4	8.95E-5	6.53E-4	1.16E+0
3000	1.55E-2	1.30E+0	3.60E-4	8.52E-5	7.90E-4	1.32E+0

Control Room Photon Dose Rates (mR/hr) versus Time

sec	Case 2a
30	0.752
40	0.989
50	1.22
60	1.44
90	2.07
120	2.66
180	3.71

See Attachments 5 and 6 for graphs of these results. Based on the these results, the control room dose rate will reach the safety limit of 1.0 mR/hr (Ref: 2) in approximately 32 minutes for the 1% F.F. case and in approximately 42 seconds for the 18% F.F. case. The area radiation monitor is set to alarm at approximately 50% of this value (accounts for response uncertainties).



It is assumed that the total delay time associated with the response time of the monitor and the delay time of the isolation is 3 minutes. See input item 17. Thus, the isolation times are $32 + 3 = 35$ minutes for the 1% F.F. cases, and about 4 minutes for the 18% F.F. cases.

In support of a possible future technical specification amendment that will allow short-term reductions in control room pressurization envelope integrity, it has been decided to assume that the control room isolation does not occur until 900 seconds (15 minutes) from the start of the accident. This period includes the assumed monitor isolation delay. (A safety analysis [Ref: 17] was previously performed for the DBAs currently analyzed in the UFSAR.

7. Offsite and Control Room Doses

Attachment 7 includes the printouts for the determination of the offsite dose (LPZ) and control room dose due to Cases 1a, 2a, 3-5. Attachment 8 provides the printouts for Cases 1b and 2b. These calculations were performed using the models, input data, and assumptions developed above.

8. Isotopic Releases

Attachment 9 tabulates the isotopic releases for the time steps upto 2 hours. Attachment 10 tabulates the isotopic release for the duration of the release -- 0-8 hours. These values were obtained from the Attachment 7 printouts.

RESULTS

The results of the dose calculations for 18% fuel failure (i.e., Cases 1a, 2a, 3-5) are provided below:

Control Room Doses, rem
(Duration)

Case	Photon	Beta	Thyroid
1a	0.00108	0.00746	18.9
2a	0.214	2.92	0.0
3	1.01E-5	6.62E-5	0.142
4	2.90E-7	2.67E-6	0.00795
5	<u>1.44E-6</u>	<u>1.23E-5</u>	<u>0.0452</u>
totals	0.215	2.93	19.1



0-2 Hour LPZ Doses, rem

Case	Photon	Beta	Thyroid
1a	0.00236	6.55E-4	1.01
2a	0.106	0.0654	0.0
3	7.44E-6	1.98E-6	0.00247
4	1.71E-7	7.29E-8	1.90E-4
5	<u>3.25E-6</u>	<u>1.30E-6</u>	<u>0.00424</u>
totals	0.108	0.066	1.017

The ratio of the EAB X/Q to the LPZ X/Q used in the calculations
 $8.9E-4 / 4.2E-5 = 21.19$. This factor is multiplied against the 0-2 hour
 LPZ totals to obtain the 0-2 hour EAB results:

0-2 hour EAB Doses, rem

Case	Photon	Beta	Thyroid
all	2.29	1.40	21.6

0-8 hour LPZ Doses, rem

Case	Photon	Beta	Thyroid
1a	0.0118	0.00391	9.10
2a	0.213	0.136	0.0
3	1.25E-4	3.92E-5	0.0754
4	1.71E-7	7.29E-8	1.90E-4
5	<u>7.46E-6</u>	<u>3.15E-6</u>	<u>0.0113</u>
totals	0.225	0.140	9.19

The results of cases 1b and 2b (i.e., 1% F.F. and 35 minute isolation
 delay) provide the following:



Duration Control Room Doses (1%F.F.), rem

<u>Case</u>	<u>Photon</u>	<u>Beta</u>	<u>Thyroid</u>
1b	7.18E-5	4.84E-4	1.18
2b	<u>1.19E-2</u>	<u>1.62E-1</u>	<u>0.0</u>
totals	0.0120	0.162	1.18

These cases show that the increased delay in control room isolation due to lower release concentrations does not result in dose consequences more limiting than those for the higher concentrations and faster isolation. In 12241-UR(B)-449 [Ref: 12] SWEC determined that control room isolation was not necessary in order to maintain control room doses below the GDC-19 [Ref: 15] guidelines for technical specification releases with a concurrent iodine spike (accounts for 5.66 rem).

CONCLUSIONS

The offsite dose consequences of a locked rotor accident are a small fraction of the 10 CFR 100 siting guidelines and therefore are acceptable.

The dose consequences to the control room operators from the intake of the activity released from a locked rotor accident are less than the requirements of GDC-19 and therefore are acceptable.

REFERENCES

1. Westinghouse, Plant Safety Evaluation for the Fuel Upgrade and Increased Peaking Factors for Beaver Valley Power Station Unit 1, 1989
2. DLC, Unit 1 Updated Final Safety Analysis Report
3. NRC, Safety Evaluation Report for Beaver Valley Power Station Unit 1
4. Westinghouse, Vantage 5 Fuel Assembly, WCAP-10444
5. Westinghouse, ltr 89DL*-G-0055 dtd 7/13/89, Rods in DNB for Locked Rotor Event
6. NRC, Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants, LWR Edition, NUREG-0800, 1984
7. DLC, calculation ERS-SFL-89-020, TRAILS: Transport of Radioactive Material in Linear Systems, 1989
8. NRC, Assumptions Used for Evaluating the Potential Radiological Consequences of a Loss of Coolant Accident for Pressurized Water Reactors, Regulatory Guide 1.4, 1974



9. USAEC, Calculation of Distance Factors for Power and Test Reactor Sites, TID-14844, 1962
10. ORNL, DRA/IST: Radioactive Decay Data for Application to Radiation Dosimetry and Radiological Assessments, DLC-80, 1981
11. D.C. Kocher, Radioactive Decay Data Tables, DOE/TIC-11026, 1981
12. SWEC, Calculation 12241-UR(B)-449, Doses in the BV1 & BV2 Combined Control Room Due to a Locked Rotor Accident and a Loss of Non-Emergency AC Power to Station Auxiliaries Accident at Unit 1 with 500 cfm Normal Ventilation, 1987
13. SWEC, Calculation 12241-UR(B)-456, Combined BV1-BV2 Control Room Habitability Due to Design Basis Accidents (except LOCA) at BV1, 1987
14. WRC, Assessment of the Use of Extended Burnup Fuel in Light Water Power Reactors, NUREG/CR-5009, 1988
15. NRC, Title 10, Code of Federal Regulations
16. DLC, Unit 2 Updated Final Safety Analysis Report
17. DLC, Calculation ERS-SFL-88-035, Combined Control Room Doses Due to DBA's at Unit 1 with Delayed Isolation, 1988
18. DLC, Ltr NDIWEM:1144 dtd 4/7/87
19. DLC, Unit 1 Technical Specifications
20. DLC, Calculation ERS-SFL-83-015, Accident Analysis X/Q Values, 1983
21. SWEC, Calculation 211-EM-ME-98, Control Room X/Q's for Unit 1 Releases, 1987
22. NRC, Atmospheric Dispersion Models for Potential Accident Consequence Assessments at Nuclear Power Plants, Regulatory Guide 1.145
23. NRC, PAVAN: An Atmospheric Dispersion Program for Evaluating Design Basis Accidental Releases of Radioactive Material from Nuclear Power Stations, NUREG/CR-2858, 1982
24. NRC, XQDDQ: Computer Program for the Meteorological Evaluation of Routine Effluent Releases at Nuclear Power Stations, NUREG/CR-2919, 1982

ATTACHMENTS

1. Source Term Table
2. Locked Rotor Release Models
3. Control Room Intake/Exhaust Model



4. Control Room Dose Rate Printouts
5. Graph: 18% Dose Rate versus Time
6. Graph: 1% Dose Rate versus Time
7. Offsite and Control Room Dose Printouts
8. Case 1b and 2b Printouts
9. 0-2 Hour Isotopic Releases
10. 0-8 Hour Isotopic Releases



UNIT 1 LOCKED ROTOR ACCIDENT SOURCE TERM DEVELOPMENT


ROM/COL	A=1	B=2	C=3	D=4	E=5	F=6	G=7	H=8	I=9	J=10
1>	NUCLIDE	GAP ACTIVITY	SEC LIG CONC	SEC STRN CONC	SEC LIG 3-56	SEC STRN 3-56	18% GAP RELEASE	RCS T/S CONCEN	T/S RCS ACT	TOTAL RCS ACT
2>		CI	UCI/GM	UCI/GM	CI	CI	CI	UCI/GM	CI	CI
4>	KR-B3M	1.27E+06	4.87E-06	4.87E-06	4.28E-05	4.28E-05	2.29E+05	1.13E-01	2.00E+01	2.29E+03
5>	KR-B5M	3.06E+06	2.37E-05	2.37E-05	2.08E-04	2.08E-04	5.51E+05	5.51E-01	75E+01	5.51E+03
6>	KR-B5	2.33E+05	1.25E-04	1.25E-04	1.10E-03	1.10E-03	4.19E+04	2.91E+00	5.15E+02	4.24E+04
7>	KR-B7	5.89E+06	1.36E-05	1.36E-05	1.20E-04	1.20E-04	1.06E+06	3.18E-01	5.97E+01	1.06E+06
8>	KR-B8	8.38E+06	3.82E-05	3.82E-05	3.18E-04	3.18E-04	1.51E+06	8.40E-01	1.49E+02	1.51E+06
9>	KR-B9	1.08E+07	1.14E-06	1.14E-06	1.07E-05	1.07E-05	1.98E+06	2.69E-02	4.69E+00	1.94E+06
10>	XE-131M	2.18E+04	1.23E-05	1.23E-05	3.07E-04	3.07E-04	7.20E+04	8.09E-01	1.43E+02	7.21E+04
11>	XE-133M	4.00E+05	3.49E-05	3.49E-05	2.97E-04	2.97E-04	2.84E+06	2.83E-02	5.01E+00	9.33E+03
12>	XE-133	1.58E+07	2.97E-04	2.97E-04	1.23E-05	1.23E-05	7.62E+05	2.86E-01	1.52E+03	2.85E+06
13>	XE-135M	4.24E+06	3.64E-05	3.64E-05	1.08E-04	1.08E-04	7.62E+05	2.86E-01	5.06E+01	7.63E+05
14>	XE-135	4.31E+06	4.31E+06	4.31E+06	3.20E-04	3.20E-04	7.76E+05	8.45E-01	1.49E+02	7.76E+05
15>	XE-137	1.39E+07	1.39E+07	1.39E+07	1.63E-05	1.63E-05	2.50E+06	4.29E-02	7.59E+00	2.50E+06
16>	XE-138	8.20E+06	7.14E-02	7.14E-02	6.71E-05	6.71E-05	2.50E+06	1.77E-01	3.13E+01	2.50E+06
17>	I-131	1.04E+07	1.27E-02	1.27E-02	9.51E+00	9.51E+00	1.48E+06	6.60E-01	1.17E+02	1.48E+06
18>	I-132	1.53E+07	9.32E-02	9.32E-02	1.59E+00	1.59E+00	1.87E+06	2.30E-01	4.07E+01	1.87E+06
19>	I-133	1.79E+07	2.23E-03	2.23E-03	1.24E+01	1.24E+01	2.75E+06	1.82E+00	1.82E+02	2.75E+06
20>	I-134	1.39E+07	3.41E-02	3.41E-02	2.97E-01	2.97E-01	3.22E+06	1.48E-01	2.55E+01	3.22E+06
21>	I-135	1.39E+07	3.41E-02	3.41E-02	4.54E+00	4.54E+00	2.50E+06	5.54E-01	9.80E+01	2.50E+06

22> COL C, D FROM SSEC 12241-UR(B)-451; COL B FROM UFSAR TBL 148-1
 23> COL E = COLUMN C X (3.56)/(97900 #/56)(453.59 #/GM)(1E-6)
 24> COLUMN F = COLUMN D X (3.56)/(6460 #/56)(453.59 #/GM)(1E-6)
 25> COLUMN G = COLUMN B X 0.18
 26> COLUMN H FROM SSEC 12241-UR(B)-451; COLUMN I = H * 390000 * 453.59 * 1E-6
 27> COLUMN J = SUM COLUMN G AND COLUMN I

UNIT 1 LOCKED ROTOR ACCIDENT SOURCE TERM DEVELOPMENT


ROM/COL	A=1	B=2	C=3	H=4	I=5	J=6
1>	NUCLIDE	GAP ACTIVITY	1X GAP RELEASE	RCS T/S CONCEN	T/S RCS ACT	TOTAL RCS ACT
2>		CI	CI	UCI/GM	CI	CI
4>	KR-B3M	1.27E+06	1.27E+04	1.13E-01	2.00E+01	1.27E+04
5>	KR-B5M	3.06E+06	3.06E+04	5.51E-01	9.75E+01	3.07E+04
6>	KR-B5	2.33E+05	2.33E+03	2.91E+00	5.15E+02	2.84E+03
7>	KR-B7	5.89E+06	5.89E+04	3.18E-01	5.97E+01	5.90E+04
8>	KR-B8	8.38E+06	8.38E+04	8.40E-01	1.49E+02	8.39E+04
9>	KR-B9	1.08E+07	1.08E+05	2.69E-02	4.69E+00	1.08E+05
10>	XE-131M	5.18E+04	5.18E+02	2.83E-02	5.01E+00	5.23E+02
11>	XE-133M	4.00E+05	4.00E+03	6.69E-01	1.43E+02	4.14E+03
12>	XE-133	1.58E+07	1.58E+05	6.89E+00	1.22E+03	1.59E+05
13>	XE-135M	4.24E+06	4.24E+04	2.86E-01	5.06E+01	4.25E+04
14>	XE-135	4.31E+06	4.31E+04	8.45E-01	1.49E+02	4.32E+04
15>	XE-137	1.39E+07	1.39E+05	4.29E-02	7.59E+00	1.39E+05
16>	XE-138	8.20E+06	8.20E+04	1.77E-01	3.13E+01	8.21E+04
17>	I-131	1.04E+07	1.04E+05	6.60E-01	1.17E+02	1.04E+05
18>	I-132	1.53E+07	1.53E+05	2.30E-01	4.07E+01	1.53E+05
19>	I-133	1.79E+07	1.79E+05	1.82E+00	1.82E+02	1.79E+05
20>	I-134	1.39E+07	1.39E+05	1.44E-01	2.55E+01	1.79E+05
21>	I-135	1.39E+07	1.39E+05	5.54E-01	9.80E+01	1.39E+05

U1 Locked Rotor Acc. Modeling




All Transfer Rates are 1/s

U1 Locked Rotor Acc. Modeling



All Transfer Rates are 1/s

CONTROL ROOM MODELING



Ti = 900 seconds

Ti: Dampers Shut - Pressurization

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 p1-to-sec leak iodines in UI LRA, 1% FF; for dose rate; no isol

COMP: RCS 1% FF PER BRP	COMP: 3 Steam Generators	COMP: Control Room
VOLUME: 1.730E+05 Cu Ft		
INITIAL:		
0.000E+00 KR-B3m	0.000E+00 KR-B3m	0.000E+00 KR-B3m
0.000E+00 KR-B5m	0.000E+00 KR-B5m	0.000E+00 KR-B5m
0.000E+00 KR-B5	0.000E+00 KR-B5	0.000E+00 KR-B5
0.000E+00 KR-B7	0.000E+00 KR-B7	0.000E+00 KR-B7
0.000E+00 KR-B8	0.000E+00 KR-B8	0.000E+00 KR-B8
0.000E+00 KR-B9	0.000E+00 KR-B9	0.000E+00 KR-B9
0.000E+00 KR-90	0.000E+00 KR-90	0.000E+00 KR-90
0.000E+00 XE-131M	0.000E+00 XE-131M	0.000E+00 XE-131M
0.000E+00 XE-133M	0.000E+00 XE-133M	0.000E+00 XE-133M
0.000E+00 XE-133	0.000E+00 XE-133	0.000E+00 XE-133
0.000E+00 XE-135M	0.000E+00 XE-135M	0.000E+00 XE-135M
0.000E+00 XE-135	0.000E+00 XE-135	0.000E+00 XE-135
0.000E+00 XE-137	0.000E+00 XE-137	0.000E+00 XE-137
0.000E+00 XE-138	0.000E+00 XE-138	0.000E+00 XE-138
8.210E+04 I-131	0.000E+00 I-131	0.000E+00 I-131
1.040E+05 I-132	0.000E+00 I-132	0.000E+00 I-132
1.530E+05 I-133	0.000E+00 I-133	0.000E+00 I-133
1.790E+05 I-134	0.000E+00 I-134	0.000E+00 I-134
1.390E+05 I-135	0.000E+00 I-135	0.000E+00 I-135
1.000E+06	1.000E+00	1.000E+00

ACT MULT (to uCi):

PRODUCTION, uCi/s:	3.564E-07 1/sec	2.099E-06 1/sec	1.000E+01 cfm
0.000E+00 KR-B3m	0.000E+00 KR-B3m	0.000E+00 KR-B3m	1.000E+01 cfm
0.000E+00 KR-B5m	0.000E+00 KR-B5m	0.000E+00 KR-B5m	INTAKE REDUCT: 0.000E+00
0.000E+00 KR-B5	0.000E+00 KR-B5	0.000E+00 KR-B5	INTAKE FILTER: 0.000E+00
0.000E+00 KR-B7	0.000E+00 KR-B7	0.000E+00 KR-B7	
0.000E+00 KR-B8	0.000E+00 KR-B8	0.000E+00 KR-B8	
0.000E+00 KR-B9	0.000E+00 KR-B9	0.000E+00 KR-B9	
0.000E+00 KR-90	0.000E+00 KR-90	0.000E+00 KR-90	
0.000E+00 XE-131M	0.000E+00 XE-131M	0.000E+00 XE-131M	
0.000E+00 XE-133M	0.000E+00 XE-133M	0.000E+00 XE-133M	
0.000E+00 XE-133	0.000E+00 XE-133	0.000E+00 XE-133	
0.000E+00 XE-135M	0.000E+00 XE-135M	0.000E+00 XE-135M	
0.000E+00 XE-135	0.000E+00 XE-135	0.000E+00 XE-135	
0.000E+00 XE-137	0.000E+00 XE-137	0.000E+00 XE-137	
0.000E+00 XE-138	0.000E+00 XE-138	0.000E+00 XE-138	
0.000E+00 I-131	0.000E+00 I-131	0.000E+00 I-131	
0.000E+00 I-132	0.000E+00 I-132	0.000E+00 I-132	
0.000E+00 I-133	0.000E+00 I-133	0.000E+00 I-133	
0.000E+00 I-134	0.000E+00 I-134	0.000E+00 I-134	
0.000E+00 I-135	0.000E+00 I-135	0.000E+00 I-135	

REMOVAL:

NUC 1-14 REL FR:	1.000E+00		
NUC 15-20 REL FR:	1.000E+00		

CASE 1B

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 pri-to-sec leak iodines in UI LRA; 1% F.F.; for dose rate; no isol

MULTIPLIERS====>

STEP	TIME	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF
1	1.000E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00	50.0	50.0	0.000E+00
2	1.100E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00	50.0	50.0	0.000E+00
3	1.200E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00	50.0	50.0	0.000E+00
4	1.300E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00	50.0	50.0	0.000E+00
5	1.800E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00	50.0	50.0	0.000E+00
6	2.400E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00	50.0	50.0	0.000E+00
7	3.000E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00	50.0	50.0	0.000E+00

----- CONTROL ROOM ----- ENVIRONMENT -----

X/g	Breathing	Occupancy	X/g	Breathing
s/M3	M3/s		s/M3	M3/s
1.000E-03	3.470E-04	1.000E+00	1.000E+00	3.470E-04

MULTIPLIERS====>

STEP	TIME, s	X/g	Breathing	Occupancy	X/g	Breathing
		s/M3	M3/s		s/M3	M3/s
1	1.000E+03	2.97	1.00	1.00	0.000E+00	1.00
2	1.100E+03	2.97	1.00	1.00	0.000E+00	1.00
3	1.200E+03	2.97	1.00	1.00	0.000E+00	1.00
4	1.300E+03	2.97	1.00	1.00	0.000E+00	1.00
5	1.800E+03	2.97	1.00	1.00	0.000E+00	1.00
6	2.400E+03	2.97	1.00	1.00	0.000E+00	1.00
7	3.000E+03	2.97	1.00	1.00	0.000E+00	1.00

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 p1 to-sec leak iodines in UI LRA; 1% F.F.; for dose rate, no iso!

STEP	TIME	RCS 1% FF PER SRP		3 Steam Generators		AVERAGE RELEASE		CONTROL ROOM	
		CURRENT uCi	INTEGRD uCi-sec	CURRENT uCi	INTEGRD uCi-sec	RELEASED uCi	RELEASE uCi/sep.	CURRENT uCi	INTEGRD uCi-sec
I-131	INITIAL	8 210E+10	2 458E+14	0 000E+00	1 311E+11	2 752E+05		0 000E+00	1 912E+05
I-131	TOTALS								
I-132	INITIAL	1 040E+11	2 758E+14	0 000E+00	1 410E+11	2 959E+05		0 000E+00	2 006E+05
I-132	TOTALS								
I-133	INITIAL	1 530E+11	4 524E+14	0 000E+00	2 403E+11	5 044E+05		0 000E+00	3 497E+05
I-133	TOTALS								
I-134	INITIAL	1 790E+11	3 931E+14	0 000E+00	1 869E+11	3 923E+05		0 000E+00	2 549E+05
I-134	TOTALS								
I-135	INITIAL	1 390E+11	3 991E+14	0 000E+00	2 098E+11	4 405E+05		0 000E+00	3 036E+05
I-135	TOTALS								
ALL NUCLIDES		5 310E+11		5 663E+08				1 190E+03	2 429E-07

@ STEP 7

TAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 pri-to-sec leak iodines in UI LRA: 1% F.F. for dose rate: no isol

	PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL	
	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.87E-04	1.71E-03	1.71E-03	2.00E+01								
TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.87E-04	1.71E-03	1.71E-03	2.00E+01								
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.18E-03	4.62E-03	4.62E-03	7.60E-01								
TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.18E-03	4.62E-03	4.62E-03	7.60E-01								
I-133	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.44E-04	6.73E-03	6.73E-03	9.91E+00								
TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.44E-04	6.73E-03	6.73E-03	9.91E+00								
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.72E-03	7.27E-03	7.27E-03	4.51E-01								
TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.72E-03	7.27E-03	7.27E-03	4.51E-01								
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.23E-03	5.25E-03	5.25E-03	2.57E+00								
TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.23E-03	5.25E-03	5.25E-03	2.57E+00								

ALL NUCLIDES

0.2778 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.09E-04	2.16E-03	1.59E-03	1.12E-02	1.89E+00	1.35E+01
0.3056 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.61E-05	2.50E-03	3.41E-04	1.34E-02	1.34E-02	4.14E-01	1.63E+01
0.3333 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.86E-05	3.06E-03	4.06E-04	1.58E-02	1.58E-02	4.96E-01	1.94E+01
0.3611 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.18E-05	3.55E-03	4.75E-04	1.84E-02	1.84E-02	5.85E-01	2.27E+01
0.5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.96E-04	6.43E-03	3.62E-03	3.36E-02	3.36E-02	4.58E+00	4.31E+01
0.6667 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.43E-03	1.06E-02	7.51E-03	5.63E-02	5.63E-02	9.87E+00	7.54E+01
0.8333 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.18E-03	1.55E-02	1.16E-02	8.30E-02	8.30E-02	1.60E+01	1.16E+02
TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.85E-03	2.56E-02	2.56E-02	2.56E-02	2.56E-02	3.38E+01	3.38E+01

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Pri-to-sec leak N.G. in U1 LRA 18% F.F. (non-equilibrium) for dose rate

COMP: NOT USED THIS CASE COMP: RCS 18XFF PER SRP 3/88 COMP: Control Room
 VOLUME: 1.730E+05 Cu Ft

INITIAL:

0.000E+00	KR-83m	2.290E+05	KR-83m	C1	0.000E+00	KR-83m
0.000E+00	KR-85m	5.510E+03	KR-85m		0.000E+00	KR-85m
0.000E+00	KR-85	4.240E+04	KR-85		0.000E+00	KR-85
0.000E+00	KR-87	1.060E+06	KR-87		0.000E+00	KR-87
0.000E+00	KR-88	1.510E+06	KR-88		0.000E+00	KR-88
0.000E+00	KR-89	1.940E+06	KR-89		0.000E+00	KR-89
0.000E+00	KR-90	0.000E+00	KR-90		0.000E+00	KR-90
0.000E+00	XE-131M	9.330E+03	XE-131M		0.000E+00	XE-131M
0.000E+00	XE-133M	7.210E+04	XE-133M		0.000E+00	XE-133M
0.000E+00	XE-133	2.850E+06	XE-133		0.000E+00	XE-133
0.000E+00	XE-135M	7.630E+05	XE-135M		0.000E+00	XE-135M
0.000E+00	XE-135	7.760E+05	XE-135		0.000E+00	XE-135
0.000E+00	XE-137	2.500E+06	XE-137		0.000E+00	XE-137
0.000E+00	XE-138	2.500E+06	XE-138		0.000E+00	XE-138
0.000E+00	I-131	0.000E+00	I-131		0.000E+00	I-131
0.000E+00	I-132	0.000E+00	I-132		0.000E+00	I-132
0.000E+00	I-133	0.000E+00	I-133		0.000E+00	I-133
0.000E+00	I-134	0.000E+00	I-134		0.000E+00	I-134
0.000E+00	I-135	0.000E+00	I-135		0.000E+00	I-135
1.000E+00		1.000E+06			1.000E+00	

ACT MULT (to uCi):

PRODUCTION, uCi/s:

0.000E+00	KR-83m	0.000E+00	KR-83m
0.000E+00	KR-85m	0.000E+00	KR-85m
0.000E+00	KR-85	0.000E+00	KR-85
0.000E+00	KR-87	0.000E+00	KR-87
0.000E+00	KR-88	0.000E+00	KR-88
0.000E+00	KR-89	0.000E+00	KR-89
0.000E+00	KR-90	0.000E+00	KR-90
0.000E+00	XE-131M	0.000E+00	XE-131M
0.000E+00	XE-133M	0.000E+00	XE-133M
0.000E+00	XE-133	0.000E+00	XE-133
0.000E+00	XE-135M	0.000E+00	XE-135M
0.000E+00	XE-135	0.000E+00	XE-135
0.000E+00	XE-137	0.000E+00	XE-137
0.000E+00	XE-138	0.000E+00	XE-138
0.000E+00	I-131	0.000E+00	I-131
0.000E+00	I-132	0.000E+00	I-132
0.000E+00	I-133	0.000E+00	I-133
0.000E+00	I-134	0.000E+00	I-134
0.000E+00	I-135	0.000E+00	I-135

REMOVAL:
 NUC 1-14 REL FR:
 NUC 15-20 REL FR:

0.000E+00	1/sec	3.564E-07	1/sec	1.000E+01	CFM
0.000E+00		1.000E+00		INTAKE REDUCT:	0.000E+00
0.000E+00		1.000E+00		INTAKE FILTER:	0.000E+00

INTAKE: 1.000E+01 CFM

CASE 2A

TRAILS --- Transport of Radioactive Material in Linear Systems, v1.0
 Pri-to-sec leak N.C. in UI LRF, 18% F.F. (non-equilibrium) for dose rate

MULTIPLIERS====>

STEP	TIME	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF
1	3 000E+01	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
2	4 000E+01	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
3	5 000E+01	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
4	6 000E+01	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
5	9 000E+01	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
6	1 200E+02	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
7	1 800E+02	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00

----- CONTROL ROOM ----- ENVIRONMENT -----
 X/G Breathing Occupancy X/G Breathing
 s/M3 R3/s M3/s
 1.000E-03 3.470E-04 1.000E+00 1.000E+00 3.470E-04

MULTIPLIERS====>

STEP	TIME	XPR	XREM	XRF	XPR	XREM	XRF
1	3 000E+01	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00
2	4 000E+01	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00
3	5 000E+01	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00
4	6 000E+01	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00
5	9 000E+01	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00
6	1 200E+02	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00
7	1 800E+02	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Pri-to-ser leak N.G. in UI LRA 18% F.F. (non-equilibrium) for dose rate

STEP TIME	MGT USED THIS CASE		RCS 182FF PER BRP 3/		AVERAGE		CONTROL ROOM	
	CURRENT uCi	INTEGRD uCi-sec	CURRENT uCi	INTEGRD uCi-sec	RELEASED uCi	RELEASE uCi/sec	CURRENT uCi/cc	INTEGRD uCi-sec
KR-83m INITIAL	0.000E+00	0.000E+00	2.290E+11	4.083E+13	1.453E+07		0.000E+00	9.122E+05
KR-83m TOTALS								
KR-85m INITIAL	0.000E+00	0.000E+00	5.510E+11	9.379E+13	3.521E+07		0.000E+00	2.212E+06
KR-85m TOTALS								
KR-85 INITIAL	0.000E+00	0.000E+00	4.240E+10	7.632E+12	2.720E+06		0.000E+00	1.711E+05
KR-85 TOTALS								
KR-87 INITIAL	0.000E+00	0.000E+00	1.060E+12	1.882E+14	6.708E+07		0.000E+00	4.199E+06
KR-87 TOTALS								
KR-88 INITIAL	0.000E+00	0.000E+00	1.510E+12	2.701E+14	9.628E+07		0.000E+00	6.042E+06
KR-88 TOTALS								
KR-89 INITIAL	0.000E+00	0.000E+00	1.940E+12	2.558E+14	9.118E+07		0.000E+00	5.088E+06
KR-89 TOTALS								
XE-131m INITIAL	0.000E+00	0.000E+00	9.330E+09	1.679E+12	3.985E+05		0.000E+00	3.764E+04
XE-131m TOTALS								
XE-133m INITIAL	0.000E+00	0.000E+00	7.210E+10	1.297E+13	4.624E+06		0.000E+00	2.908E+05
XE-133m TOTALS								
XE-133 INITIAL	0.000E+00	0.000E+00	2.850E+12	5.129E+14	1.828E+08		0.000E+00	1.150E+07
XE-133 TOTALS								
XE-135m INITIAL	0.000E+00	0.000E+00	7.630E+11	1.284E+14	4.378E+07		0.000E+00	2.811E+06
XE-135m TOTALS								
XE-135 INITIAL	0.000E+00	0.000E+00	7.760E+11	1.394E+14	4.969E+07		0.000E+00	3.123E+06
XE-135 TOTALS								
XE-137 INITIAL	0.000E+00	0.000E+00	2.500E+12	3.472E+14	1.238E+08		0.000E+00	7.057E+06
XE-137 TOTALS								
XE-138 INITIAL	0.000E+00	0.000E+00	2.500E+12	4.184E+14	1.491E+08		0.000E+00	9.139E+06
XE-138 TOTALS								
ALL NUCLIDES	0.000E+00	0.000E+00	1.232E+13				5.518E+05	1.126E-04

STEP 7

FRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 pri-to-sec leak N.G. in U1 LRA 1B2 F.F. (non-equilibrium) for dose rate

	PHOTON-SUBMG		BETA-SUBMS		ENVIRONMENT		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMS		CONTROL ROOM		THYROID-INHAL	
	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr
KR-B7M TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.08E-06	1.64E-03	1.64E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-B5M TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.95E-04	2.65E-02	2.65E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-B5 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.65E-07	2.02E-03	2.02E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-B7 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.54E-03	2.61E-01	2.61E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-B8 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.03E-02	1.03E-01	1.03E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-B9 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.39E-02	3.25E-01	3.25E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-131M TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.94E-06	2.51E-04	2.51E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-133M TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.10E-05	2.60E-03	2.60E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-133 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.34E-03	7.31E-02	7.31E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-135M TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.11E-03	1.26E-02	1.26E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-135 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.99E-03	4.66E-02	4.66E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-137 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.40E-03	5.89E-01	5.89E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-138 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.64E-02	2.71E-01	2.71E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ALL NUCLIDES TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.16E-03	7.52E-01	7.52E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
0.0083 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.42E-03	9.89E-01	9.89E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
0.0111 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.07E-03	1.22E+00	1.22E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
0.0139 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.69E-03	1.44E+00	1.44E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
0.0167 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.97E-02	2.07E+00	2.07E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
0.0250 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.97E-02	2.66E+00	2.66E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
0.0333 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.32E-02	3.71E+00	3.71E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
0.0500 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.99E-02	1.71E+00	1.71E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Pri-to-sec leak N.G. in UI LRA 1% F.F. (non-equilibrium) per dose rate

COMP: NOT USED THIS CASE COMP: RCS 1XFF PC: SRP 3/56 COMP: Control Room
 VOLUME: 1.730E+05 Cu Ft

INITIAL:

0.000E+00	KR-83m	1.270E+04	KR-83m	0.000E+00	KR-83m
0.000E+00	KR-85m	3.070E+04	KR-85m	0.000E+00	KR-85m
0.000E+00	KR-85	2.840E+03	KR-85	0.000E+00	KR-85
0.000E+00	KR-87	5.900E+04	KR-87	0.000E+00	KR-87
0.000E+00	KR-88	5.390E+04	KR-88	0.000E+00	KR-88
0.000E+00	KR-89	1.080E+05	KR-89	0.000E+00	KR-89
0.000E+00	KR-90	0.000E+00	KR-90	0.000E+00	KR-90
0.000E+00	XE-131M	5.230E+02	XE-131M	0.000E+00	XE-131M
0.000E+00	XE-133M	4.140E+03	XE-133M	0.000E+00	XE-133M
0.000E+00	XE-133	1.590E+05	XE-133	0.000E+00	XE-133
0.000E+00	XE-135M	4.250E+04	XE-135M	0.000E+00	XE-135M
0.000E+00	XE-135	4.320E+04	XE-135	0.000E+00	XE-135
0.000E+00	XE-137	1.390E+05	XE-137	0.000E+00	XE-137
0.000E+00	XE-138	1.390E+05	XE-138	0.000E+00	XE-138
0.000E+00	I-131	0.000E+00	I-131	0.000E+00	I-131
0.000E+00	I-132	0.000E+00	I-132	0.000E+00	I-132
0.000E+00	I-133	0.000E+00	I-133	0.000E+00	I-133
0.000E+00	I-134	0.000E+00	I-134	0.000E+00	I-134
0.000E+00	I-135	0.000E+00	I-135	0.000E+00	I-135
1.000E+00		1.000E+06		1.000E+00	

ACT MULT (to vCi):

PRODUCTION, vCi/s:

0.000E+00	KR-83m	0.000E+00	KR-83m
0.000E+00	KR-85m	0.000E+00	KR-85m
0.000E+00	KR-85	0.000E+00	KR-85
0.000E+00	KR-87	0.000E+00	KR-87
0.000E+00	KR-88	0.000E+00	KR-88
0.000E+00	KR-89	0.000E+00	KR-89
0.000E+00	KR-90	0.000E+00	KR-90
0.000E+00	XE-131M	0.000E+00	XE-131M
0.000E+00	XE-133M	0.000E+00	XE-133M
0.000E+00	XE-133	0.000E+00	XE-133
0.000E+00	XE-135M	0.000E+00	XE-135M
0.000E+00	XE-135	0.000E+00	XE-135
0.000E+00	XE-137	0.000E+00	XE-137
0.000E+00	XE-138	0.000E+00	XE-138
0.000E+00	I-131	0.000E+00	I-131
0.000E+00	I-132	0.000E+00	I-132
0.000E+00	I-133	0.000E+00	I-133
0.000E+00	I-134	0.000E+00	I-134
0.000E+00	I-135	0.000E+00	I-135

REMOVAL:
 NUC 1-14 REL FR:
 NUC 15-20 REL FR:

0.000E+00	1/sec	3.54E-07	1/sec	1.000E+01	cfm
0.000E+00		1.000E+00		INTAKE REDUCT.	0.000E+00
0.000E+00		1.000E+00		INTAKE FILTER	0.000E+00

INTAKE: 1.000E+01 CFM

CASE 23

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Pri-to-sec leak N.G. in UI LRA 12 F.F. (non-equilibrium) for dose rate

MULTIPLIERS====>

STEP	TIME	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF
1	1 000E+03	0 000E+00	1 00	0 000E+00	0 000E+00	1 00	0 000E+00	0 000E+00	50 0	0 000E+00	50 0	0 000E+00	0 000E+00
2	1 100E+03	0 000E+00	1 00	0 000E+00	0 000E+00	1 00	0 000E+00	0 000E+00	50 0	0 000E+00	50 0	0 000E+00	0 000E+00
3	1 200E+03	0 000E+00	1 00	0 000E+00	0 000E+00	1 00	0 000E+00	0 000E+00	50 0	0 000E+00	50 0	0 000E+00	0 000E+00
4	1 300E+03	0 000E+00	1 00	0 000E+00	0 000E+00	1 00	0 000E+00	0 000E+00	50 0	0 000E+00	50 0	0 000E+00	0 000E+00
5	1 400E+03	0 000E+00	1 00	0 000E+00	0 000E+00	1 00	0 000E+00	0 000E+00	50 0	0 000E+00	50 0	0 000E+00	0 000E+00
6	2 400E+03	0 000E+00	1 00	0 000E+00	0 000E+00	1 00	0 000E+00	0 000E+00	50 0	0 000E+00	50 0	0 000E+00	0 000E+00
7	3 000E+03	0 000E+00	1 00	0 000E+00	0 000E+00	1 00	0 000E+00	0 000E+00	50 0	0 000E+00	50 0	0 000E+00	0 000E+00

----- CONTROL ROOM ----- ENVIRONMENT ----

X/g s/M3	Breathing M3/s	Occupancy	X/g s/M3	Breathing M3/s
1.000E-03	3.470E-04	1.000E+00	1.000E+00	3.470E-04
2.97	1.00	1.00	0.000E+00	1.00
2.97	1.00	1.00	0.000E+00	1.00
2.97	1.00	1.00	0.000E+00	1.00
2.97	1.00	1.00	0.000E+00	1.00
2.97	1.00	1.00	0.000E+00	1.00
2.97	1.00	1.00	0.000E+00	1.00

MULTIPLIERS====>

STEP	TIME, s
1	1 000E+03
2	1 100E+03
3	1 200E+03
4	1 300E+03
5	1 400E+03
6	2 400E+03
7	3 000E+03

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Pri-to-sec leak N.G. in U1 LRA 1% F. (non-equilibrium) for dose rate

STEP TIME	NOT USED THIS CASE		RCS 1% F PER SRP 3/S		AVERAGE RELEASE		CONTROL ROOM		
	CURRENT uCi	INTEGRD uCi-sec	CURRENT uCi	INTEGRD uCi-sec	RELEASED uCi	RELEASE uCi/sec	CURRENT uCi	CURRENT uCi/cc	INTEGRD uCi-sec
KR-83m INITIAL	0.000E+00	0.000E+00	1.270E+10	3.266E+13	1.164E+07		0.000E+00		1.104E+07
KR-83m TOTALS									
KR-85m INITIAL	0.000E+00	0.000E+00	3.070E+10	8.636E+13	3.078E+07		0.000E+00		3.018E+07
KR-85m TOTALS									
KR-85 INITIAL	0.000E+00	0.000E+00	2.840E+09	8.915E+12	3.035E+06		0.000E+00		3.043E+06
KR-85 TOTALS									
KR-87 INITIAL	0.000E+00	0.000E+00	5.900E+10	1.422E+14	5.068E+07		0.000E+00		4.689E+07
KR-87 TOTALS									
KR-88 INITIAL	0.000E+00	0.000E+00	8.390E+10	2.276E+14	8.113E+07		0.000E+00		7.851E+07
KR-88 TOTALS									
KR-89 INITIAL	0.000E+00	0.000E+00	1.080E+11	2.954E+13	1.053E+07		0.000E+00		1.991E+06
KR-89 TOTALS									
XE-131m INITIAL	0.000E+00	0.000E+00	5.230E+08	1.567E+12	5.583E+05		0.000E+00		5.596E+05
XE-131m TOTALS									
XE-133m INITIAL	0.000E+00	0.000E+00	4.140E+09	1.233E+13	4.400E+06		0.000E+00		4.403E+06
XE-133m TOTALS									
XE-133 INITIAL	0.000E+00	0.000E+00	1.590E+11	4.757E+14	1.695E+08		0.000E+00		1.698E+08
XE-133 TOTALS									
XE-135m INITIAL	0.000E+00	0.000E+00	4.250E+10	3.057E+13	1.803E+07		0.000E+00		1.181E+07
XE-135m TOTALS									
XE-135 INITIAL	0.000E+00	0.000E+00	4.320E+10	1.255E+14	4.473E+07		0.000E+00		4.436E+07
XE-135 TOTALS									
XE-137 INITIAL	0.000E+00	0.000E+00	1.390E+11	4.608E+13	1.642E+07		0.000E+00		3.750E+06
XE-137 TOTALS									
XE-138 INITIAL	0.000E+00	0.000E+00	1.390E+11	1.553E+14	5.536E+07		0.000E+00		3.488E+07
XE-138 TOTALS									
ALL NUCLIDES	0.000E+00	0.000E+00	3.645E+11				2.548E+05	5.202E-05	

@ STEP 7

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Pri-to-sec leak N.G. in UI LRA 1% F.F. (non-equilibrium) for dose rate

	PHOTON-SUBMG		BETA-SUBMG		E N V I R O N M E N T		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		C O N T R O L		R O O M		THYROID-INHAL	
	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr
KR-83m TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.36E-05	1.98E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-85m TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.22E-02	3.62E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-85 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.72E-05	3.58E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-87 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.54E-02	2.91E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-88 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.94E-01	1.34E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-89 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.37E-03	1.27E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-131M TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.88E-05	3.73E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-133M TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.69E-04	3.93E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-133 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.97E-02	1.08E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-135M TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.30E-02	5.31E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-135 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.82E-02	6.62E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-137 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.81E-03	3.13E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-138 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.01E-01	1.03E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
ALL NUCLIDES	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.06E-01	7.10E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
0 2778 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.02E-02	7.44E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
0 3056 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.11E-02	7.78E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
0 3333 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.21E-02	8.13E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
0 3611 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.24E-01	9.78E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
0 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.77E-01	1.15E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
0 6667 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.04E-01	1.30E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
0 8333 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.75E-01	7.99E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.75E-01	7.99E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 concurrent spike: for c. r. dose rate w/o isolation

COMP: Reactor Coolant System COMP: 3 Steam Generators COMP: Control Room
 VOLUME: 1.730E+05 Cm. Ft.

INITIAL	COMP: Reactor Coolant System	COMP: 3 Steam Generators	COMP: Control Room
0.000E+00	KR-83m	0.000E+00	KR-83m
0.000E+00	KR-85m	0.000E+00	KR-85m
0.000E+00	KR-85	0.000E+00	KR-85
0.000E+00	KR-87	0.000E+00	KR-87
0.000E+00	KR-88	0.000E+00	KR-88
0.000E+00	KR-89	0.000E+00	KR-89
0.000E+00	KR-90	0.000E+00	KR-90
0.000E+00	XE-131M	0.000E+00	XE-131M
0.000E+00	XE-133M	0.000E+00	XE-133M
0.000E+00	XE-133	0.000E+00	XE-133
0.000E+00	XE-135M	0.000E+00	XE-135M
0.000E+00	XE-135	0.000E+00	XE-135
0.000E+00	XE-137	0.000E+00	XE-137
0.000E+00	XE-138	0.000E+00	XE-138
0.000E+00	I-131	0.000E+00	I-131
0.000E+00	I-132	0.000E+00	I-132
0.000E+00	I-133	0.000E+00	I-133
0.000E+00	I-134	0.000E+00	I-134
0.000E+00	I-135	0.000E+00	I-135
1.000E+00		1.000E+00	

ACT MULT (to uCi)	COMP: Reactor Coolant System	COMP: 3 Steam Generators	COMP: Control Room
0.000E+00	KR-83m	0.000E+00	KR-83m
0.000E+00	KR-85m	0.000E+00	KR-85m
0.000E+00	KR-85	0.000E+00	KR-85
0.000E+00	KR-87	0.000E+00	KR-87
0.000E+00	KR-88	0.000E+00	KR-88
0.000E+00	KR-89	0.000E+00	KR-89
0.000E+00	KR-90	0.000E+00	KR-90
0.000E+00	XE-131M	0.000E+00	XE-131M
0.000E+00	XE-133M	0.000E+00	XE-133M
0.000E+00	XE-133	0.000E+00	XE-133
0.000E+00	XE-135M	0.000E+00	XE-135M
0.000E+00	XE-135	0.000E+00	XE-135
0.000E+00	XE-137	0.000E+00	XE-137
0.000E+00	XE-138	0.000E+00	XE-138
1.360E+06	I-131	2.099E-06	I-131
2.320E+06	I-132	0.000E+00	I-132
3.060E+06	I-133	0.000E+00	I-133
3.680E+06	I-134	0.000E+00	I-134
2.810E+06	I-135	0.000E+00	I-135

REMOVAL:
 NUC 1-14 REL FR: 0.000E+00
 NUC 15-20 REL FR: 0.000E+00

IN TAKE: 1.000E+01 CFM IN TAKE: 1.000E+01 CFM
 IN TAKE REDUCT: 0.000E+00 IN TAKE REDUCT: 0.000E+00
 IN TAKE FILTER: 0.000E+00 IN TAKE FILTER: 0.000E+00

CASE 3

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 concurrent spike; for c.r. dose rate w/o isolation

MULTIPLIERS====>

STEP	TIME	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF
1	1 000E+03	1.00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
2	1 100E+03	1.00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
3	1 200E+03	1.00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
4	1 300E+03	1.00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
5	1 800E+03	1.00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
6	2 400E+03	1.00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
7	3 000E+03	1.00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00

----- CONTROL ROOM ----- ENVIRONMENT -----
 X/G Breathing Occupancy X/G Breathing
 s/M3 M3/s s/M3 s/M3
 1.000E-03 3.470E-04 1.000E+00 1.000E+00 3.470E-04

MULTIPLIERS====>

STEP	TIME, s	XPR	XREM	XRF	XPR	XREM	XRF
1	1 000E+03	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00
2	1 100E+03	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00
3	1 200E+03	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00
4	1 300E+03	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00
5	1 800E+03	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00
6	2 400E+03	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00
7	3 000E+03	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00

TRAILS -- Transport of Radioactive Material in Linear Systems, vi.0
 concurrent spike: for c. r. dose rate w/o isolation

STEP	TIME	Reactor Coolant Syst		3 Steam Generators		AVERAGE		CONTROL ROOM	
		CURRENT uCi	INTEGRD uCi-sec	CURRENT uCi	INTEGRD uCi-sec	RELEASED uCi	RELEASE uCi/sec	CURRENT uCi/cc	INTEGRD uCi-sec
I-131	INITIAL								
I-131	TOTALS	0.000E+00	6.112E+12	0.000E+00	2.181E+09	4.577E+03		0.000E+00	2.442E+03
I-132	INITIAL								
I-132	TOTALS	0.000E+00	1.044E+13	0.000E+00	3.564E+09	7.482E+03		0.000E+00	3.869E+03
I-133	INITIAL								
I-133	TOTALS	0.000E+00	1.373E+13	0.000E+00	4.864E+09	1.021E+04		0.000E+00	5.408E+03
I-134	INITIAL								
I-134	TOTALS	0.000E+00	1.345E+13	0.000E+00	4.285E+09	8.993E+03		0.000E+00	4.434E+03
I-135	INITIAL								
I-135	TOTALS	0.000E+00	1.228E+13	0.000E+00	4.307E+09	9.040E+03		0.000E+00	4.760E+03
ALL NUCLIDES		3.601E+10		1.851E+07				2.575E+01	5.256E+09
@ STEP	7								

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 concurrent spike: for c. r. dose rate w/o isolation

	PHOTON-SUBMG		BETA-SUBMG		ENVIRONMENT		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		CONTROL		THYROID-INHAL	
	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.39E-06	2.18E-02	2.18E-02	2.18E-02	2.18E-02	2.18E-02	2.56E-01	2.56E-01
TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.27E-05	8.90E-05	8.90E-05	8.90E-05	8.90E-05	1.47E-02	1.47E-02	1.47E-02
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.42E-06	1.04E-04	1.04E-04	1.04E-04	1.04E-04	1.53E-01	1.53E-01	1.53E-01
TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.99E-05	1.26E-04	1.26E-04	1.26E-04	1.26E-04	7.85E-03	7.85E-03	7.85E-03
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.92E-05	8.24E-05	8.24E-05	8.24E-05	8.24E-05	4.18E-02	4.18E-02	4.18E-02
TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.11E-05	7.84E-05	7.84E-05	7.84E-05	7.84E-05	1.16E-02	1.16E-02	1.16E-02
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.22E-06	2.54E-06	2.54E-06	2.54E-06	2.54E-06	2.68E-03	2.68E-03	2.68E-03
TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.04E-07	3.33E-06	3.33E-06	3.33E-06	3.33E-06	3.51E-03	3.51E-03	3.51E-03
ALL NUCLIDES	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.60E-07	4.26E-06	4.26E-06	4.26E-06	4.26E-06	4.51E-03	4.51E-03	4.51E-03
0.2778 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.44E-07	4.27E-05	4.27E-05	4.27E-05	4.27E-05	4.58E-02	4.58E-02	4.58E-02
0.3056 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.41E-06	1.20E-04	1.20E-04	1.20E-04	1.20E-04	1.33E-01	1.33E-01	1.33E-01
0.3333 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.64E-05	2.39E-04	2.39E-04	2.39E-04	2.39E-04	2.73E-01	2.73E-01	2.73E-01
0.3611 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.26E-05	4.24E-04	4.24E-04	4.24E-04	4.24E-04	4.74E-01	4.74E-01	4.74E-01
0.5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.26E-05	4.24E-04	4.24E-04	4.24E-04	4.24E-04	4.74E-01	4.74E-01	4.74E-01
0.6667 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.26E-05	4.24E-04	4.24E-04	4.24E-04	4.24E-04	4.74E-01	4.74E-01	4.74E-01
0.8333 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.26E-05	4.24E-04	4.24E-04	4.24E-04	4.24E-04	4.74E-01	4.74E-01	4.74E-01
TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.26E-05	4.24E-04	4.24E-04	4.24E-04	4.24E-04	4.74E-01	4.74E-01	4.74E-01

COMP: NOT USED THIS CASE COMP: 3 S/G initial steam rel COMP: Control Room
 VOLUME: 1.730E+05 Cu Ft

INITIAL:	COMP: 3 S/G initial steam rel	COMP: Control Room
0.000E+00 KR-83m	4.280E-05 KR-83m	0.000E+00 KR-83m
0.000E+00 KR-85m	1.100E-04 KR-85m	0.000E+00 KR-85m
0.000E+00 KR-87	1.200E-04 KR-87	0.000E+00 KR-87
0.000E+00 KR-88	3.180E-04 KR-88	0.000E+00 KR-88
0.000E+00 KR-89	1.000E-05 KR-89	0.000E+00 KR-89
0.000E+00 KR-90	0.000E+00 KR-90	0.000E+00 KR-90
0.000E+00 KR-131M	1.070E-05 KR-131M	0.000E+00 KR-131M
0.000E+00 KR-133M	3.070E-04 KR-133M	0.000E+00 KR-133M
0.000E+00 KR-133	2.610E-03 KR-133	0.000E+00 KR-133
0.000E+00 KR-135M	1.080E-04 KR-135M	0.000E+00 KR-135M
0.000E+00 KR-135	3.200E-04 KR-135	0.000E+00 KR-135
0.000E+00 KR-137	1.630E-05 KR-137	0.000E+00 KR-137
0.000E+00 KR-138	6.710E-05 KR-138	0.000E+00 KR-138
0.000E+00 I-131	6.280E-03 I-131	0.000E+00 I-131
0.000E+00 I-132	1.120E-03 I-132	0.000E+00 I-132
0.000E+00 I-133	8.190E-03 I-133	0.000E+00 I-133
0.000E+00 I-134	1.960E-04 I-134	0.000E+00 I-134
0.000E+00 I-135	3.000E-03 I-135	0.000E+00 I-135
1.000E+00	1.000E+06	1.000E+00

ACT MULT (to uCi):	COMP: 3 S/G initial steam rel	COMP: Control Room
0.000E+00 KR-83m	4.280E-05 KR-83m	0.000E+00 KR-83m
0.000E+00 KR-85m	1.100E-04 KR-85m	0.000E+00 KR-85m
0.000E+00 KR-87	1.200E-04 KR-87	0.000E+00 KR-87
0.000E+00 KR-88	3.180E-04 KR-88	0.000E+00 KR-88
0.000E+00 KR-89	1.000E-05 KR-89	0.000E+00 KR-89
0.000E+00 KR-90	0.000E+00 KR-90	0.000E+00 KR-90
0.000E+00 KR-131M	1.070E-05 KR-131M	0.000E+00 KR-131M
0.000E+00 KR-133M	3.070E-04 KR-133M	0.000E+00 KR-133M
0.000E+00 KR-133	2.610E-03 KR-133	0.000E+00 KR-133
0.000E+00 KR-135M	1.080E-04 KR-135M	0.000E+00 KR-135M
0.000E+00 KR-135	3.200E-04 KR-135	0.000E+00 KR-135
0.000E+00 KR-137	1.630E-05 KR-137	0.000E+00 KR-137
0.000E+00 KR-138	6.710E-05 KR-138	0.000E+00 KR-138
0.000E+00 I-131	6.280E-03 I-131	0.000E+00 I-131
0.000E+00 I-132	1.120E-03 I-132	0.000E+00 I-132
0.000E+00 I-133	8.190E-03 I-133	0.000E+00 I-133
0.000E+00 I-134	1.960E-04 I-134	0.000E+00 I-134
0.000E+00 I-135	3.000E-03 I-135	0.000E+00 I-135
1.000E+00	1.000E+06	1.000E+00

REMOVAL:	COMP: 3 S/G initial steam rel	COMP: Control Room
NUC 1-14 REL FR:	0.000E+00 I/sec	1.000E+01 CFM
NUC 15-20 REL FR:	0.000E+00 I/sec	1.000E+01 CFM
	0.000E+00	INTAKE DUCT: 0.000E+00
	0.000E+00	INTAKE FILTER: 0.000E+00

CASE 4

TRAILS --- Transport of Radioactive Material in Linear Systems, v1 0
 initial steam release: for C.R. dose rate w/iso1

MULTIPLIERS====>

STEP	TIME	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF
1	1 000E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
2	1 100E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
3	1 200E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
4	1 300E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
5	1 400E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
6	2 400E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
7	3 000E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00

----- CONTROL ROOM -----
 X/G Breathing Occupancy
 s/M3 M3/s
 1.000E-03 3.470E-04 1.000E+00

----- ENVIRONMENT -----
 X/G Breathing
 s/M3 M3/s
 1.000E+00 3.470E-04

MULTIPLIERS====>

STEP	TIME, s	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF
1	1 000E+03	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
2	1 100E+03	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
3	1 200E+03	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
4	1 300E+03	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
5	1 400E+03	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
6	2 400E+03	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
7	3 000E+03	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 initial steam release; for c. r. dose rate w/iso1

STEP TIME	NOT USED THIS CASE		3 S/G initial steam		AVERAGE		CONTROL ROOM	
	CURRENT uCi	INTEGRD uCi-sec	CURRENT uCi	INTEGRD uCi-sec	RELEASED uCi	RELEASE uCi/sec	CURRENT uCi/cc	INTEGRD uCi-sec
KR-83m KR-83m	0.000E+00	0.000E+00	4.280E+01	3.328E+02	4.276E+01	0.000E+00	0.000E+00	6.211E+01
KR-85m KR-85m	0.000E+00	0.000E+00	2.080E+02	1.618E+03	2.079E+02	0.000E+00	0.000E+00	3.253E+02
KR-85 KR-85	0.000E+00	0.000E+00	1.100E+03	8.560E+03	1.100E+03	0.000E+00	0.000E+00	1.814E+03
KR-87 KR-87	0.000E+00	0.000E+00	1.200E+02	9.328E+02	1.199E+02	0.000E+00	0.000E+00	1.649E+02
KR-88 KR-88	0.000E+00	0.000E+00	3.180E+02	2.473E+03	3.178E+02	0.000E+00	0.000E+00	4.826E+02
KR-89 KR-89	0.000E+00	0.000E+00	1.000E+01	7.567E+01	9.723E+00	0.000E+00	0.000E+00	1.939E+00
XE-131M XE-131M	0.000E+00	0.000E+00	1.070E+01	8.327E+01	1.070E+01	0.000E+00	0.000E+00	1.763E+01
XE-133M XE-133M	0.000E+00	0.000E+00	3.070E+02	2.389E+03	3.070E+02	0.000E+00	0.000E+00	5.041E+02
XE-133 XE-133	0.000E+00	0.000E+00	2.610E+03	2.031E+04	2.610E+03	0.000E+00	0.000E+00	4.297E+03
XE-135M XE-135M	0.000E+00	0.000E+00	1.080E+02	8.356E+02	1.074E+02	0.000E+00	0.000E+00	8.097E+01
XE-135 XE-135	0.000E+00	0.000E+00	3.200E+02	2.490E+03	3.199E+02	0.000E+00	0.000E+00	5.142E+02
XE-137 XE-137	0.000E+00	0.000E+00	1.630E+01	1.239E+02	1.593E+01	0.000E+00	0.000E+00	3.640E+00
XE-138 XE-138	0.000E+00	0.000E+00	6.710E+01	5.189E+02	6.668E+01	0.000E+00	0.000E+00	4.758E+01
I-131 I-131	0.000E+00	0.000E+00	6.280E+03	4.887E+04	6.280E+03	0.000E+00	0.000E+00	1.035E+04
I-132 I-132	0.000E+00	0.000E+00	1.120E+03	8.710E+03	1.119E+03	0.000E+00	0.000E+00	1.667E+03
I-133 I-133	0.000E+00	0.000E+00	8.190E+03	6.373E+04	8.189E+03	0.000E+00	0.000E+00	1.335E+04
I-134 I-134	0.000E+00	0.000E+00	1.960E+02	1.523E+03	1.957E+02	0.000E+00	0.000E+00	2.491E+02
I-135 I-135	0.000E+00	0.000E+00	3.000E+03	2.334E+04	2.999E+03	0.000E+00	0.000E+00	4.773E+03

ERS-SFL-89-021

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
initial steam release; for c. r. dose rate w/iso1

-----CONTROL ROOM-----
CURRENT CURRENT INTEGRD
uCi uCi/cc uCi-sec
1.429E+01 2.916E-09

AVERAGE
RELEASED RELEASE
uCi uCi/sec

3 S/G initial steam
CURRENT INTEGRD
uCi uCi-sec
0.000E+00

HOT USED THIS CASE
CURRENT INTEGRD
uCi uCi-sec
0.000E+00

STEP TIME
ALL NUCLIDES
@ STEP 7

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 initial steam release: for c.f. dose rate w/iso1

	PHOTON-SUBMG		ENVIRONMENT		THYROID-INHAL		PHOTON-SUBMG		CONTROL ROOM		THYROID-INHAL	
	DOSE mrem	RATE mrem/hr	DOSE mrem	RATE mrem/hr	DOSE mrem	RATE mrem/hr	DOSE mrem	RATE mrem/hr	DOSE mrem	RATE mrem/hr	DOSE mrem	RATE mrem/hr
KR-83m TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.14E-10	1.11E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-85m TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.32E-07	3.90E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-85 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.02E-08	2.14E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-87 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.35E-07	1.02E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-88 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.42E-06	8.26E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00
KR-89 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.66E-09	1.18E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-131M TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.09E-10	1.18E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-133M TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.37E-08	4.50E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-133 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.99E-07	2.73E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-135M TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.95E-08	3.64E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-135 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.27E-07	7.68E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-137 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.75E-09	3.04E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00
XE-138 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.37E-07	1.41E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00
I-131 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.01E-05	9.25E-05	1.08E+00	1.08E+00	1.08E+00	1.08E+00
I-132 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.80E-06	3.84E-05	6.32E-03	6.32E-03	6.32E-03	6.32E-03
I-133 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.06E-05	2.57E-04	3.78E-01	3.78E-01	3.78E-01	3.78E-01
I-134 TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.68E-06	7.11E-06	4.41E-04	4.41E-04	4.41E-04	4.41E-04

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 initial steam release, for c.r. dose rate w/iso1

	PHOTON-SUBMG		ENVIRO NMENT		THYROID-INHAL		PHOTON-SUBMG		S O N T R O I L		R O D M		THYROID-INHAL	
	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr
1-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.93E-05	1.01E-04	8.26E-05	8.57E-04	3.17E-01	4.19E-02	2.26E+00	2.25E+00
TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.42E-05	9.98E-05	5.63E-04	8.57E-04	3.17E-01	4.19E-02	2.26E+00	2.25E+00
ALL NUCLIDES	0.2778 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.79E-06	9.90E-05	2.37E-05	8.50E-04	6.27E-02	6.24E-02	2.24E+00	2.23E+00
0.3056 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.74E-06	9.81E-05	2.35E-05	8.44E-04	6.24E-02	6.21E-02	2.23E+00	2.17E+00
0.3333 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.74E-06	9.40E-05	1.14E-04	8.07E-04	3.06E-01	3.56E-01	2.10E+00	2.04E+00
0.3611 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.33E-05	8.95E-05	1.32E-04	7.74E-04	3.56E-01	3.45E-01	2.04E+00	1.91E+00
0.5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.53E-05	8.52E-05	1.26E-04	7.42E-04	3.45E-01	3.45E-01	2.04E+00	1.91E+00
0.6667 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.46E-05	8.52E-05	5.63E-04	7.42E-04	3.45E-01	3.45E-01	2.04E+00	1.91E+00
0.8333 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.57E-05	8.52E-05	5.63E-04	7.42E-04	3.45E-01	3.45E-01	2.04E+00	1.91E+00
TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.57E-05	8.52E-05	5.63E-04	7.42E-04	3.45E-01	3.45E-01	2.04E+00	1.91E+00

COMP: NOT USED THIS CASE	COMP: 3 Steam Generators	COMP: Control Room
	VOLUME: 1.730E+05 Cu. Ft.	
INITIAL:		
0.000E+00 KR-83m	0.000E+00 KR-83m	0.000E+00 KR-83m
0.000E+00 KR-85m	0.000E+00 KR-85m	0.000E+00 KR-85m
0.000E+00 KR-87	0.000E+00 KR-87	0.000E+00 KR-87
0.000E+00 KR-88	0.000E+00 KR-88	0.000E+00 KR-88
0.000E+00 KR-89	0.000E+00 KR-89	0.000E+00 KR-89
0.000E+00 KR-90	0.000E+00 KR-90	0.000E+00 KR-90
0.000E+00 XE-131M	0.000E+00 XE-131M	0.000E+00 XE-131M
0.000E+00 XE-133M	0.000E+00 XE-133M	0.000E+00 XE-133M
0.000E+00 XE-133	0.000E+00 XE-133	0.000E+00 XE-133
0.000E+00 XE-135M	0.000E+00 XE-135M	0.000E+00 XE-135M
0.000E+00 XE-135	0.000E+00 XE-135	0.000E+00 XE-135
0.000E+00 XE-137	0.000E+00 XE-137	0.000E+00 XE-137
0.000E+00 XE-138	0.000E+00 XE-138	0.000E+00 XE-138
0.000E+00 I-131	9.510E+00 I-131	0.000E+00 I-131
0.000E+00 I-132	1.690E+00 I-132	0.000E+00 I-132
0.000E+00 I-133	1.240E+01 I-133	0.000E+00 I-133
0.000E+00 I-134	2.970E-01 I-134	0.000E+00 I-134
0.000E+00 I-135	4.540E+00 I-135	0.000E+00 I-135
1.000E+00	1.000E+06	1.000E+00

ACT MULT (to uCi):

PRODUCTION, uCi/s:	2.099E-06 1/sec	1.000E+01 CFM
0.000E+00 KR-83m	0.000E+00	0.000E+01 CFM
0.000E+00 KR-85m	0.000E+00	0.000E+00
0.000E+00 KR-87	0.000E+00	0.000E+00
0.000E+00 KR-88	0.000E+00	0.000E+00
0.000E+00 KR-89	0.000E+00	0.000E+00
0.000E+00 KR-90	0.000E+00	0.000E+00
0.000E+00 XE-131M	0.000E+00	0.000E+00
0.000E+00 XE-133M	0.000E+00	0.000E+00
0.000E+00 XE-133	0.000E+00	0.000E+00
0.000E+00 XE-135M	0.000E+00	0.000E+00
0.000E+00 XE-135	0.000E+00	0.000E+00
0.000E+00 XE-137	0.000E+00	0.000E+00
0.000E+00 XE-138	0.000E+00	0.000E+00
0.000E+00 I-131	0.000E+00	0.000E+00
0.000E+00 I-132	0.000E+00	0.000E+00
0.000E+00 I-133	0.000E+00	0.000E+00
0.000E+00 I-134	0.000E+00	0.000E+00
0.000E+00 I-135	0.000E+00	0.000E+00

REMOVAL:	1.000E+01 CFM	1.000E+01 CFM
NUC 1-14 REL FR:	0.000E+00	0.000E+00
NUC 15-20 REL FR:	0.000E+00	0.000E+00

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 initial sec liquid iodine dose rate w/o iso1

MULTIPLIERS====>

STEP	TIME	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF
1	1 000E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00	50.0	50.0	0.000E+00
2	1 100E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00	50.0	50.0	0.000E+00
3	1 200E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00	50.0	50.0	0.000E+00
4	1 300E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00	50.0	50.0	0.000E+00
5	1 800E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00	50.0	50.0	0.000E+00
6	2 400E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00	50.0	50.0	0.000E+00
7	3 000E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00	50.0	50.0	0.000E+00

----- CONTROL ROOM -----

X/G Breathing Occupancy
 s/M3 M3/s

1.000E-03 3.470E-04 1.000E+00

----- ENVIRONMENT -----

X/G Breathing
 s/M3 M3/s

1.000E+00 3.470E-04

MULTIPLIERS====>

STEP	TIME, s	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF
1	1 000E+03	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
2	1 100E+03	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
3	1 200E+03	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
4	1 300E+03	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
5	1 800E+03	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
6	2 400E+03	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
7	3 000E+03	2.97	1.00	1.00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 initial sec liquid iodine; dose rate w/o iso1


STEP	TIME	NOT USED THIS CASE		3 Steam Generators		AVERAGE		CONTROL ROOM	
		CURRENT uCi	INTEGRD uCi-sec	CURRENT uCi	INTEGRD uCi-sec	RELEASED uCi	RELEASE uCi/sec	CURRENT uCi/cc	INTEGRD uCi-sec
I-131	INITIAL	0.000E+00	0.000E+00	9.510E+06	2.840E+10	3.961E+04		0.000E+00	5.978E+04
I-131	TOTALS								
I-132	INITIAL	0.000E+00	0.000E+00	1.690E+06	4.470E+09	9.383E+03		0.000E+00	9.010E+03
I-132	TOTALS								
I-133	INITIAL	0.000E+00	0.000E+00	1.240E+07	3.657E+10	7.677E+04		0.000E+00	7.666E+04
I-133	TOTALS								
I-134	INITIAL	0.000E+00	0.000E+00	2.970E+05	6.508E+08	1.366E+03		0.000E+00	1.218E+03
I-134	TOTALS								
I-135	INITIAL	0.000E+00	0.000E+00	4.540E+06	1.300E+10	2.729E+04		0.000E+00	2.697E+04
I-135	TOTALS								
ALL NUCLIDES		0.000E+00	0.000E+00	2.700E+07				1.113E+02	2.272E-08
@ STEP	7								

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 initial sec liquid iodine; dose rate w/o isol

	PHOTON-SUBMG		ENVIRO NMENT		THYROID-INHAL		PHOTON-SUBMG		C O N T R O L		THYROID-INHAL	
	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE
	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
I-131	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.84E-05	5.34E-04			5.27E+00	
TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.30E-05	2.07E-04			3.41E-02	
I-132	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.19E-04	1.47E-03			2.17E+00	
TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.20E-05	3.48E-05			2.16E-03	
I-134	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.09E-04	4.67E-04			2.37E-01	
TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.19E-04	3.19E-04			1.01E+00	
I-135	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.14E-05	2.94E-04	2.27E-03	2.27E-03	1.01E+00	7.17E+00
TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.56E-06	3.23E-04	3.49E-04	2.49E-03	2.09E-01	7.87E+00
ALL NUCLIDES	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.32E-06	7.21E-05	2.71E-03	2.71E-03	2.28E-01	8.56E+00
0 2778 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.01E-05	7.81E-05	2.92E-03	2.92E-03	2.47E-01	9.25E+00
0 3056 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.06E-04	4.77E-04	3.95E-03	3.95E-03	1.52E+00	1.26E+01
0 3333 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.13E-05	7.57E-04	5.13E-03	5.13E-03	2.43E+00	1.69E+01
0 3611 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.67E-05	7.57E-04	6.25E-03	6.25E-03	3.07E+00	2.03E+01
0 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.20E-04	9.48E-04	7.90E-04	7.90E-04	3.07E+00	2.03E+01
0 6667 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.48E-04	2.72E-03	2.72E-03	2.72E-03	8.71E+00	
0 8333 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00						
TOTALS	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00						




CONTROL ROOM DOSE RATE





CONTROL ROOM DOSE RATE



COMP: RCS 18% FF PER SRP COMP: 3 Steam Generators COMP: Control Room
 VOLUME: 1.730E+03 Cu. Ft.

INITIAL:	COMP: RCS 18% FF PER SRP	COMP: 3 Steam Generators	COMP: Control Room
0.000E+00	KR-B3m	0.000E+00	KR-B3m
0.000E+00	KR-B5m	0.000E+00	KR-B5m
0.000E+00	KR-B7	0.000E+00	KR-B7
0.000E+00	KR-B8	0.000E+00	KR-B8
0.000E+00	KR-B9	0.000E+00	KR-B9
0.000E+00	KR-90	0.000E+00	KR-90
0.000E+00	XE-131M	0.000E+00	XE-131M
0.000E+00	XE-133M	0.000E+00	XE-133M
0.000E+00	XE-133	0.000E+00	XE-133
0.000E+00	XE-135M	0.000E+00	XE-135M
0.000E+00	XE-135	0.000E+00	XE-135
0.000E+00	XE-137	0.000E+00	XE-137
0.000E+00	XE-138	0.000E+00	XE-138
1.480E+06	I-131	0.000E+00	I-131
1.870E+06	I-132	0.000E+00	I-132
2.750E+06	I-133	0.000E+00	I-133
3.220E+06	I-134	0.000E+00	I-134
2.500E+06	I-135	0.000E+00	I-135
1.000E+06		1.000E+00	

ACT MULT (to uCi):

PRODUCTION, uCi/s:

0.000E+00	KR-B3m	0.000E+00	KR-B3m
0.000E+00	KR-B5m	0.000E+00	KR-B5m
0.000E+00	KR-B7	0.000E+00	KR-B7
0.000E+00	KR-B8	0.000E+00	KR-B8
0.000E+00	KR-B9	0.000E+00	KR-B9
0.000E+00	KR-90	0.000E+00	KR-90
0.000E+00	XE-131M	0.000E+00	XE-131M
0.000E+00	XE-133M	0.000E+00	XE-133M
0.000E+00	XE-133	0.000E+00	XE-133
0.000E+00	XE-135M	0.000E+00	XE-135M
0.000E+00	XE-135	0.000E+00	XE-135
0.000E+00	XE-137	0.000E+00	XE-137
0.000E+00	XE-138	0.000E+00	XE-138
0.000E+00	I-131	0.000E+00	I-131
0.000E+00	I-132	0.000E+00	I-132
0.000E+00	I-133	0.000E+00	I-133
0.000E+00	I-134	0.000E+00	I-134
0.000E+00	I-135	0.000E+00	I-135

REMOVAL:
 NUC 1-14 REL FR:
 NUC 15-20 REL FR:

3.564E-07	1/sec	2.099E-06	1/sec	1.000E+01	cfm
1.000E+00		0.000E+00		0.000E+00	INTAKE REDUCT
1.000E+00		0.000E+00		0.000E+00	INTAKE FILTER
				9.360E-01	

INTAKE: 1.000E+01 CFM

CASE 1A

MULTIPLIERS====>

STEP	TIME	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF
1	9.000E+02	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
2	4.500E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	1.00	70.0	0.000E+00
3	7.200E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	70.0	70.0	1.00
4	1.440E+04	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	0.000E+00	0.596	0.000E+00	70.0	70.0	1.00
5	2.880E+04	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	0.000E+00	0.596	0.000E+00	70.0	70.0	1.00
6	3.060E+04	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	3.300E+03	3.300E+03	0.000E+00
7	8.640E+04	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	50.0	50.0	0.000E+00
8	3.456E+05	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	50.0	50.0	0.000E+00
9	2.592E+06	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	50.0	50.0	0.000E+00

----- CONTROL ROOM -----

X/g	Breathing	Occupancy
s/M3	M3/s	
1.000E-03	3.470E-04	1.000E+00

----- ENVIRONMENT -----

X/g	Breathing
s/M3	M3/s
1.000E+00	3.470E-04
4.200E-05	1.00
4.200E-05	1.00
4.200E-05	1.00
4.200E-05	1.00
2.700E-05	1.00
2.700E-05	1.00
1.540E-03	1.00
6.800E-06	1.00

MULTIPLIERS====>

STEP	TIME, s
1	9.000E+02
2	4.500E+03
3	7.200E+03
4	1.440E+04
5	2.880E+04
6	3.060E+04
7	8.640E+04
8	3.456E+05
9	2.592E+06

STEP	TIME	RCS 18% FF PER SRP		3 Steam Generators		AVERAGE		CONTROL ROOM	
		CURRENT uCi	INTEGRD uCi-sec	CURRENT uCi	INTEGRD uCi-sec	RELEASED uCi	RELEASE uCi/sec	CURRENT uCi/cc	CURRENT uCi-sec
1-131	INITIAL	1.480E+12	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00
1	0 2500 h	1.478E+12	1.331E+11	4.738E+08	2.133E+11	4.478E+05	4.975E+02	3.070E+02	6.266E-08
2	1 2500 h	1.471E+12	5.309E+11	2.350E+09	5.092E+12	1.069E+07	2.969E+03	3.727E+02	7.608E-08
3	2 0000 h	1.466E+12	3.964E+11	7.377E+09	8.222E+12	1.726E+07	6.392E+03	1.299E+03	2.652E-07
4	4 0000 h	1.451E+12	1.050E+11	7.390E+09	4.012E+13	5.019E+07	6.970E+03	3.282E+03	6.700E-07
5	8 0000 h	1.423E+12	2.070E+11	1.441E+10	1.574E+14	1.969E+02	1.368E+04	9.090E+03	1.856E-06
6	8 5000 h	1.420E+12	2.559E+11	1.530E+10	2.674E+13	0.000E+00	0.000E+00	2.968E+01	6.059E-09
7	24 0000 h	1.317E+12	7.631E+11	4.091E+10	1.585E+15	0.000E+00	0.000E+00	1.910E+00	3.899E-10
8	96 0000 h	9.268E+11	2.878E+17	1.213E+11	2.224E+16	0.000E+00	0.000E+00	5.576E-06	1.138E-15
9	720 0000 h	4.424E+10	6.518E+17	6.718E+10	2.870E+17	0.000E+00	0.000E+00	0.000E+00	0.000E+00
1-131	TOTALS	1.060E+18	3.111E+17	0.000E+00	0.000E+00	2.755E+08	0.000E+00	0.000E+00	1.134E-01
1-132	INITIAL	1.870E+12	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00
1	0 2500 h	1.734E+12	1.621E+11	5.557E+08	2.565E+11	5.385E+05	5.983E+02	3.559E+02	7.264E-08
2	1 2500 h	1.281E+12	5.385E+11	2.046E+09	4.995E+12	1.048E+07	2.912E+03	3.199E+02	6.530E-08
3	2 0000 h	1.021E+12	3.094E+11	2.603E+09	6.362E+12	1.335E+07	4.946E+03	9.013E+02	1.840E-07
4	4 0000 h	5.573E+11	5.14E+11	2.838E+09	2.037E+13	2.549E+07	3.540E+03	1.279E+03	2.611E-07
5	8 0000 h	1.661E+11	4.654E+11	1.682E+09	3.312E+13	4.144E+07	2.378E+03	1.205E+03	2.460E-07
6	8 5000 h	1.428E+11	2.775E+14	1.538E+09	2.897E+12	0.000E+00	0.000E+00	3.391E+00	6.921E-10
7	24 0000 h	1.310E+09	1.683E+15	4.072E+07	2.505E+13	0.000E+00	0.000E+00	2.160E-03	4.408E-13
8	96 0000 h	4.510E-01	1.559E+13	5.901E-02	5.288E+11	0.000E+00	0.000E+00	3.082E-18	6.291E-28
9	720 0000 h	0.000E+00	5.364E+13	0.000E+00	7.278E+12	0.000E+00	0.000E+00	0.000E+00	0.000E+00
1-132	TOTALS	2.224E+16	9.362E+13	0.000E+00	0.000E+00	9.130E+07	0.000E+00	0.000E+00	2.927E+07
1-133	INITIAL	2.750E+12	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00
1	0 2500 h	2.726E+12	2.464E+11	8.738E+08	3.945E+11	8.280E+05	9.200E+02	5.656E+02	1.154E-07
2	1 2500 h	2.634E+12	9.647E+11	4.207E+09	9.222E+12	1.936E+07	5.377E+03	6.662E+02	1.360E-07
3	2 0000 h	2.566E+12	7.019E+11	6.544E+09	1.454E+13	3.053E+07	1.131E+04	2.273E+03	4.640E-07
4	4 0000 h	2.394E+12	1.785E+11	1.219E+10	6.797E+13	8.593E+07	1.181E+04	5.412E+03	1.105E-06
5	8 0000 h	2.085E+12	3.220E+11	2.111E+10	2.433E+14	3.634E+08	2.114E+04	1.336E+04	2.728E-06
6	8 5000 h	2.049E+12	3.721E+11	2.208E+10	3.888E+13	0.000E+00	0.000E+00	4.300E+01	8.777E-09
7	24 0000 h	1.198E+12	8.800E+11	3.724E+10	1.769E+15	0.000E+00	0.000E+00	1.745E+00	3.562E-10
8	96 0000 h	9.918E+10	1.143E+17	1.298E+10	7.023E+15	0.000E+00	0.000E+00	5.989E-07	1.222E-16
9	720 0000 h	4.146E+01	1.032E+16	6.295E+01	1.799E+15	0.000E+00	0.000E+00	0.000E+00	0.000E+00
1-133	TOTALS	2.861E+17	2.861E+16	0.000E+00	0.000E+00	4.401E+08	0.000E+00	0.000E+00	1.857E+08
1-134	INITIAL	3.220E+12	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00
1	0 2500 h	2.642E+12	2.629E+11	8.467E+08	4.076E+11	8.555E+05	9.505E+02	5.328E+02	1.088E-07
2	1 2500 h	1.197E+12	6.569E+11	1.912E+09	5.757E+12	1.208E+07	3.356E+03	2.952E+02	6.025E-08
3	2 0000 h	6.608E+11	2.436E+11	1.685E+09	4.939E+12	1.037E+07	3.840E+03	5.890E+02	1.202E-07
4	4 0000 h	1.356E+11	2.388E+11	6.904E+08	8.357E+12	1.045E+07	1.452E+03	3.520E+02	7.186E-08
5	8 0000 h	5.711E+09	9.06E+14	5.783E+07	3.816E+12	4.776E+06	3.316E+02	7.703E+01	1.573E-08
6	8 5000 h	3.844E+09	8.85E+12	4.141E+07	8.852E+10	0.000E+00	0.000E+00	1.697E-01	3.465E-11
7	24 0000 h	1.796E+04	1.748E+13	5.583E+02	2.169E+11	0.000E+00	0.000E+00	5.505E-08	1.24E-17
8	96 0000 h	3.120E-21	8.167E+07	4.083E-22	2.675E+06	0.000E+00	0.000E+00	3.964E-38	0.000E+00
9	720 0000 h	0.000E+00	1.418E-17	0.000E+00	1.883E-18	0.000E+00	0.000E+00	0.000E+00	0.000E+00
1-134	TOTALS	1.454E+16	2.358E+13	0.000E+00	0.000E+00	3.854E+07	0.000E+00	0.000E+00	8.051E+06

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 pri-to-sec leak iodines in UI LRA assuming 18% F.F.

STEP	TIME	RCS 18% FF PER SRP		3 Steam Generators		AVERAGE		CONTROL ROOM		
		CURRENT uCi	INTEGRD uCi-sec	CURRENT uCi	INTEGRD uCi-sec	RELEASED uCi	RELEASE uCi/sec	CURRENT uCi	CURRENT uCi/cc	INTEGRD uCi-sec
1-135	INITIAL									
1	0 2500 h	2.435E+12	2.220E+15	7.803E+08	3.544E+11	7.438E+05	8.265E+02	5.036E+02	1.028E-07	2.292E+05
2	1 2500 h	2.189E+12	8.315E+15	3.498E+09	7.884E+12	1.653E+07	4.598E+03	5.517E+02	1.126E-07	1.905E+06
3	2 0000 h	2.022E+12	5.682E+15	5.156E+09	1.175E+13	2.466E+07	9.134E+03	1.788E+03	3.651E-07	3.232E+06
4	4 0000 h	1.639E+12	1.312E+16	8.325E+09	4.954E+13	6.197E+07	8.608E+03	3.697E+03	7.547E-07	2.054E+07
5	8 0000 h	1.069E+12	1.918E+16	1.083E+10	1.427E+14	1.785E+08	1.239E+04	6.974E+03	1.424E-06	8.213E+07
6	8 5000 h	1.014E+12	1.875E+15	1.093E+10	1.958E+13	0.000E+00	0.000E+00	2.169E+01	4.419E-09	2.167E+06
7	24 0000 h	1.957E+11	2.776E+16	6.081E+09	5.039E+14	0.000E+00	0.000E+00	2.898E-01	5.917E-11	2.763E+05
8	96 0000 h	9.381E+07	6.633E+15	1.228E+07	2.895E+14	0.000E+00	0.000E+00	5.763E-10	1.174E-19	3.750E+03
9	720 0000 h	1.605E-21	3.182E+12	2.436E-21	4.604E+11	0.000E+00	0.000E+00	0.000E+00	0.000E+00	7.435E-06
1-135	TOTALS		8.478E+16		1.028E+15		2.824E+08			1.109E+08
ALL NUCLIDES		4.424E+10		6.718E+10				0.000E+00	0.000E+00	
@ STEP	9									

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 p1-c-sec leak iodines in U1 LRA assuming 18% F F

		C N T R O L R O O M		P H O T O N - S U B M G		T H Y R O I D - I N H A L		P H O T O N - S U B M G		T H Y R O I D - I N H A L	
		DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE
		mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
1-131	0 2500 h	1.79E-03	7.17E-03	8.24E-04	3.86E+01	1.36E-04	1.08E-03	1.24E-03	9.88E-03	1.46E+01	1.16E+02
	1 2500 h	4.28E-02	4.28E-02	1.97E-02	2.31E+02	2.20E-03	1.31E-03	1.10E-02	1.24E-02	1.29E+02	1.41E+02
	2 0000 h	6.91E-02	9.21E-02	3.18E-02	4.96E+02	2.24E-03	4.57E-03	2.05E-02	4.18E-02	2.41E+02	4.90E+02
	4 0000 h	2.01E-01	1.00E-01	9.24E-02	4.62E+02	1.67E-02	1.15E-02	1.53E-01	1.06E-01	1.79E+03	1.24E+03
	8 0000 h	7.88E-01	1.97E-01	3.62E-01	9.06E+02	9.37E-02	3.20E-02	8.57E-01	2.93E-01	1.00E+04	3.43E+03
	8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.93E-03	1.04E-04	2.55E-02	9.56E-04	2.99E+02	1.12E+01
	24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.52E-04	6.72E-06	5.05E-03	6.15E-05	5.92E+01	7.21E-01
	96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.80E-05	1.96E-11	3.47E-04	1.80E-10	4.07E+00	2.10E-06
	720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.11E-10	0.00E+00	1.01E-09	0.00E+00	1.19E-05	0.00E+00
	TOTALS	1.10E+00	5.07E-01	5.94E+03	0.00E+00	1.17E-01	0.00E+00	1.07E+00	0.00E+00	1.26E+04	0.00E+00

1-132	0 2500 h	1.30E-02	5.18E-02	2.55E-03	1.02E-02	4.20E-01	1.68E+00	9.60E-04	7.53E-03	3.76E-03	2.95E-02	6.19E-01	4.85E+00
	1 2500 h	2.52E-01	4.97E-02	8.18E+00	4.97E-02	8.18E+00	8.18E+00	7.11E-03	6.77E-03	2.79E-02	2.65E-02	4.59E+00	4.36E+00
	2 0000 h	3.21E-01	4.28E-01	6.33E-01	8.44E-02	1.04E-01	1.39E+01	1.00E-02	1.91E-02	3.92E-02	7.47E-02	6.45E+00	1.23E+01
	4 0000 h	6.13E-01	3.07E-01	1.21E-01	6.04E-02	1.99E+01	9.94E+00	4.75E-02	2.71E-02	1.86E-01	1.06E-01	3.07E+01	1.74E+01
	8 0000 h	9.97E-01	2.49E-01	1.96E-01	4.91E-02	3.23E+01	8.08E+00	1.04E-01	2.55E-02	4.08E-01	9.99E-02	6.71E+01	1.64E+01
	8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.16E-03	4.17E-05	8.48E-03	2.61E-04	1.40E+00	4.63E-02
	24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.51E-04	7.15E-08	5.91E-04	1.79E-07	9.74E-02	2.95E-05
	96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.62E-08	6.52E-23	3.77E-07	2.55E-22	6.21E-05	4.20E-20
	720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.37E-22	0.00E+00	5.38E-22	0.00E+00	8.86E-20	0.00E+00
	TOTALS	2.20E+00	4.33E-01	7.12E+01	0.00E+00	1.72E-01	0.00E+00	6.74E-01	0.00E+00	6.74E-01	1.11E+02	1.11E+02	0.00E+00

1-133	0 2500 h	5.27E-03	2.11E-02	3.28E-03	1.31E-02	4.83E+00	1.93E+01	3.99E-04	3.17E-03	4.94E-03	3.92E-02	7.27E+00	5.77E+01
	1 2500 h	1.23E-01	1.23E-01	7.67E-02	7.67E-02	1.13E+02	1.13E+02	3.46E-03	3.73E-03	4.28E-02	4.62E-02	6.31E+01	6.80E+01
	2 0000 h	1.94E-01	2.59E-01	1.21E-01	1.61E-01	1.78E+02	2.37E+02	6.29E-03	1.27E-02	7.78E-02	1.57E-01	1.15E+02	2.32E+02
	4 0000 h	5.42E-01	2.71E-01	3.37E-01	1.68E-01	4.96E+02	2.48E+02	4.47E-02	3.03E-02	5.52E-01	3.75E-01	8.13E+02	5.52E+02
	8 0000 h	1.94E+00	4.85E-01	1.21E+00	3.01E-01	1.77E+03	4.44E+02	2.26E-01	7.49E-02	2.80E+00	9.26E-01	4.12E+03	1.36E+03
	8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.50E-03	2.41E-04	8.04E-02	2.98E-03	1.18E+02	4.39E+00
	24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.12E-03	9.77E-06	1.38E-02	1.21E-04	2.04E+01	1.78E-01
	96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.73E-05	3.35E-12	5.85E-04	4.15E-11	6.61E-01	6.11E-08
	720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.62E-11	0.00E+00	2.01E-10	0.00E+00	2.93E-07	0.00E+00
	TOTALS	2.80E+00	1.74E+00	2.57E+03	0.00E+00	2.89E-01	0.00E+00	3.57E+00	0.00E+00	3.57E+00	0.00E+00	5.26E+03	0.00E+00

1-134	0 2500 h	2.36E-02	9.43E-02	5.02E-03	2.01E-02	3.12E-01	1.29E+00	1.68E-03	1.29E-02	7.11E-03	5.47E-02	4.42E-01	3.40E+00
	1 2500 h	3.33E-01	3.33E-01	7.09E-02	7.09E-02	4.40E+00	4.40E+00	9.55E-03	7.15E-03	4.04E-02	3.03E-02	2.51E+00	1.88E+00
	2 0000 h	2.86E-01	3.81E-01	6.07E-02	8.12E-02	3.78E+00	5.04E+00	8.38E-03	1.43E-02	3.55E-02	6.05E-02	2.20E+00	3.76E+00
	4 0000 h	2.88E-01	1.44E-01	6.14E-02	3.07E-02	3.81E+00	1.90E+00	2.10E-02	8.53E-03	8.88E-02	3.62E-02	5.51E+00	2.24E+00
	8 0000 h	1.32E-01	3.29E-02	2.80E-02	7.01E-03	1.74E+00	4.35E-01	1.87E-03	1.87E-03	5.71E-02	7.91E-03	3.55E+00	4.91E-01
	8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.52E-04	4.11E-06	6.45E-04	1.74E-05	4.00E-02	1.08E-03
	24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.27E-06	1.33E-12	1.81E-05	5.65E-12	1.12E-03	3.51E-10
	96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.38E-12	0.00E+00	5.86E-12	0.00E+00	3.64E-10	0.00E+00
	720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
	TOTALS	1.06E+00	2.26E-01	1.40E+01	0.00E+00	5.42E-02	0.00E+00	5.42E-02	0.00E+00	2.30E-01	0.00E+00	1.43E+01	0.00E+00

TRAILS -- Transport of Radioactive Material in Linear Systems, v.1.0
 pri-to-sec leak iodines in UI LRA assuming 18% F.F.

	PHOTON-SUBMG		BETA-SUBMG		ENVIRONMENT		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		CONTROL ROOM		THYROID-INHAL	
	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr
I-135	1.23E-02	4.92E-02	2.65E-03	1.06E-02	1.34E+00	5.38E+00	9.26E-04	7.32E-03	3.97E-03	3.14E-02	2.01E+00	1.59E+01	1.74E+01	1.57E+01	3.44E-02	3.44E-02
0 2500 h	2.74E-01	2.74E-01	5.90E-02	5.90E-02	2.99E+01	2.99E+01	7.69E-03	8.02E-03	3.30E-02	3.30E-02	3.30E-02	3.30E-02	3.30E-02	3.30E-02	3.30E-02	3.30E-02
1 2500 h	4.08E-01	5.44E-01	8.78E-02	1.17E-01	4.46E+01	5.94E+01	1.31E-02	2.60E-02	5.59E-02	1.11E-01	2.84E+01	5.65E+01	5.65E+01	2.84E+01	1.11E-01	1.11E-01
2 0000 h	1.02E+00	5.12E-01	2.21E-01	1.10E-01	1.12E+02	3.60E+01	8.30E-02	5.38E-02	3.59E-01	2.30E-01	1.80E+02	1.17E+02	1.17E+02	2.30E-01	1.80E+02	2.30E-01
8 0000 h	2.95E+00	7.39E-01	6.36E-01	1.59E-01	3.23E+02	6.06E+01	3.32E-01	1.01E-01	1.42E+00	4.35E-01	7.21E+02	2.21E+02	2.21E+02	4.35E-01	7.21E+02	4.35E-01
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.15E-04	3.75E-02	1.35E-03	1.90E+01	6.84E-01	6.84E-01	1.35E-03	1.90E+01	1.35E-03
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.12E-02	4.21E-06	4.78E-03	1.81E-05	2.43E+00	9.16E-03	9.16E-03	1.81E-05	2.43E+00	1.81E-05
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.91E-05	8.38E-15	6.49E-05	3.59E-14	3.29E-02	1.82E-11	1.82E-11	3.59E-14	3.29E-02	3.59E-14
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.01E-14	0.00E+00	1.29E-13	0.00E+00	6.59E-11	0.00E+00	0.00E+00	1.29E-13	6.59E-11	1.29E-13
TOTALS	4.67E+00	1.01E+00	1.01E+00	5.10E+02	5.10E+02	4.46E-01	4.46E-01	0.00E+00	1.91E+00	9.70E+02	9.70E+02	9.70E+02	9.70E+02	9.70E+02	9.70E+02	9.70E+02

ALL NUCLIDES	PHOTON-SUBMG		BETA-SUBMG		ENVIRONMENT		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		CONTROL ROOM		THYROID-INHAL	
	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr
0 2500 h	5.59E-02	2.24E-01	1.43E-02	5.73E-02	1.66E+01	6.62E+01	4.10E-03	3.20E-02	2.10E-02	1.68E-01	2.49E+01	1.98E+02	1.98E+02	1.68E-01	2.49E+01	1.68E-01
1 2500 h	1.03E+00	1.03E+00	2.76E-01	2.76E-01	3.86E+02	3.86E+02	2.90E-02	2.70E-02	1.95E-01	4.46E-01	2.16E+02	2.34E+02	2.34E+02	4.46E-01	2.16E+02	4.46E-01
2 0000 h	1.28E+00	1.70E+00	3.65E-01	4.86E-01	6.09E+02	8.12E+02	4.00E-02	7.67E-02	2.29E-01	4.46E-01	3.92E+02	7.95E+02	7.95E+02	4.46E-01	3.92E+02	4.46E-01
4 0000 h	2.67E+00	1.33E+00	8.32E-01	4.16E-01	1.71E+03	8.57E+02	2.13E-01	1.31E-01	1.34E+00	8.53E-01	1.50E+04	5.03E+03	5.03E+03	1.34E+00	8.53E-01	1.34E+00
8 0000 h	6.81E+00	1.70E+00	2.43E+00	6.07E-01	6.38E+03	1.59E+03	7.69E-01	2.36E-01	5.57E+00	1.76E+00	1.50E+04	5.03E+03	5.03E+03	1.76E+00	1.50E+04	1.76E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.04E-02	7.36E-04	1.92E-01	5.58E-03	4.38E+02	1.63E+01	1.63E+01	5.58E-03	4.38E+02	5.58E-03
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.94E-03	2.08E-05	2.43E-02	2.01E-04	8.21E+01	9.08E-01	9.08E-01	2.01E-04	8.21E+01	2.01E-04
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.01E-04	2.30E-11	2.43E-02	2.21E-10	4.97E+00	2.17E-06	2.17E-06	2.21E-10	4.97E+00	2.21E-10
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.27E-10	0.00E+00	1.21E-09	0.00E+00	1.22E-05	0.00E+00	0.00E+00	1.21E-09	1.22E-05	1.21E-09
TOTALS	1.18E+01	3.91E+00	3.91E+00	5.10E+02	5.10E+02	4.46E-01	4.46E-01	0.00E+00	1.91E+00	9.70E+02	9.70E+02	9.70E+02	9.70E+02	9.70E+02	9.70E+02	9.70E+02

COMP: NOT USED THIS CASE COMP: RCB 18XFF PER SRC -3/50 COMP: Control Room
 VOLUME: 1.730E+03 Cu Ft

INITIAL:	COMP: RCB 18XFF PER SRC -3/50	C1	COMP: Control Room
0.000E+00 KR-83m	2.290E+05 KR-83m	0.000E+00 KR-83m	0.000E+00 KR-83m
0.000E+00 KR-85m	5.310E+05 KR-85m	0.000E+00 KR-85m	0.000E+00 KR-85m
0.000E+00 KR-85	4.240E+04 KR-85	0.000E+00 KR-85	0.000E+00 KR-85
0.000E+00 KR-87	1.060E+06 KR-87	0.000E+00 KR-87	0.000E+00 KR-87
0.000E+00 KR-88	1.310E+06 KR-88	0.000E+00 KR-88	0.000E+00 KR-88
0.000E+00 KR-89	1.940E+06 KR-89	0.000E+00 KR-89	0.000E+00 KR-89
0.000E+00 KR-90	0.000E+00 KR-90	0.000E+00 KR-90	0.000E+00 KR-90
0.000E+00 KR-131M	9.330E+03 KR-131M	0.000E+00 KR-131M	0.000E+00 KR-131M
0.000E+00 KR-133M	7.210E+04 KR-133M	0.000E+00 KR-133M	0.000E+00 KR-133M
0.000E+00 KR-133	2.890E+06 KR-133	0.000E+00 KR-133	0.000E+00 KR-133
0.000E+00 KR-133M	7.530E+05 KR-133M	0.000E+00 KR-133M	0.000E+00 KR-133M
0.000E+00 KR-135	7.760E+05 KR-135	0.000E+00 KR-135	0.000E+00 KR-135
0.000E+00 KR-137	2.500E+06 KR-137	0.000E+00 KR-137	0.000E+00 KR-137
0.000E+00 KR-138	2.500E+06 KR-138	0.000E+00 KR-138	0.000E+00 KR-138
0.000E+00 I-131	0.000E+00 I-131	0.000E+00 I-131	0.000E+00 I-131
0.000E+00 I-132	0.000E+00 I-132	0.000E+00 I-132	0.000E+00 I-132
0.000E+00 I-133	0.000E+00 I-133	0.000E+00 I-133	0.000E+00 I-133
0.000E+00 I-134	0.000E+00 I-134	0.000E+00 I-134	0.000E+00 I-134
0.000E+00 I-135	0.000E+00 I-135	0.000E+00 I-135	0.000E+00 I-135
1.000E+00	1.000E+00	1.000E+00	1.000E+00

ACT MULT (to uCi):	COMP: RCB 18XFF PER SRC -3/50	C1	COMP: Control Room
0.000E+00 KR-83m	2.290E+05 KR-83m	0.000E+00 KR-83m	0.000E+00 KR-83m
0.000E+00 KR-85m	5.310E+05 KR-85m	0.000E+00 KR-85m	0.000E+00 KR-85m
0.000E+00 KR-85	4.240E+04 KR-85	0.000E+00 KR-85	0.000E+00 KR-85
0.000E+00 KR-87	1.060E+06 KR-87	0.000E+00 KR-87	0.000E+00 KR-87
0.000E+00 KR-88	1.310E+06 KR-88	0.000E+00 KR-88	0.000E+00 KR-88
0.000E+00 KR-89	1.940E+06 KR-89	0.000E+00 KR-89	0.000E+00 KR-89
0.000E+00 KR-90	0.000E+00 KR-90	0.000E+00 KR-90	0.000E+00 KR-90
0.000E+00 KR-131M	9.330E+03 KR-131M	0.000E+00 KR-131M	0.000E+00 KR-131M
0.000E+00 KR-133M	7.210E+04 KR-133M	0.000E+00 KR-133M	0.000E+00 KR-133M
0.000E+00 KR-133	2.890E+06 KR-133	0.000E+00 KR-133	0.000E+00 KR-133
0.000E+00 KR-133M	7.530E+05 KR-133M	0.000E+00 KR-133M	0.000E+00 KR-133M
0.000E+00 KR-135	7.760E+05 KR-135	0.000E+00 KR-135	0.000E+00 KR-135
0.000E+00 KR-137	2.500E+06 KR-137	0.000E+00 KR-137	0.000E+00 KR-137
0.000E+00 KR-138	2.500E+06 KR-138	0.000E+00 KR-138	0.000E+00 KR-138
0.000E+00 I-131	0.000E+00 I-131	0.000E+00 I-131	0.000E+00 I-131
0.000E+00 I-132	0.000E+00 I-132	0.000E+00 I-132	0.000E+00 I-132
0.000E+00 I-133	0.000E+00 I-133	0.000E+00 I-133	0.000E+00 I-133
0.000E+00 I-134	0.000E+00 I-134	0.000E+00 I-134	0.000E+00 I-134
0.000E+00 I-135	0.000E+00 I-135	0.000E+00 I-135	0.000E+00 I-135
1.000E+00	1.000E+00	1.000E+00	1.000E+00

REMOVAL:
 NUC 1-14 REL FR: 0.000E+00 1/sec
 NUC 15-20 REL FR: 0.000E+00 0.000E+00

INTAKE: 1.000E+01 CFM
 INTAKE REDUCT: 0.000E+00
 INTAKE FILTER: 9.360E-01

CASE ZA

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Pri-to-sec leak N.0 in J: LRA assuming BX F.F. (non-equil)

MULTIPLIERS====>

STEP	TIME	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF
1	9 000E+02	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00	50.0	50.0	0.000E+00
2	4 500E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	1.00	70.0	0.000E+00	1.00	70.0	0.000E+00
3	7 200E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	70.0	70.0	0.000E+00	70.0	70.0	1.00
4	1 440E+04	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	70.0	70.0	0.000E+00	70.0	70.0	1.00
5	2 860E+04	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	70.0	70.0	0.000E+00	70.0	70.0	1.00
6	3 060E+04	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	3.300E+03	3.300E+03	0.000E+00	3.300E+03	3.300E+03	0.000E+00
7	8 640E+04	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00	50.0	50.0	0.000E+00
8	3 456E+05	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00	50.0	50.0	0.000E+00
9	2 592E+06	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00	50.0	50.0	0.000E+00

----- CONTROL ROOM -----

X/G	Breathing	Occupancy
s/M3	M3/s	
1.000E-03	3.470E-04	1.000E+00

----- ENVIRONMENT -----

X/G	Breathing
s/M3	M3/s
1.000E+00	3.470E-04
4.200E-05	1.00
4.200E-05	1.00
4.200E-05	1.00
4.200E-05	1.00
2.700E-05	1.00
2.700E-05	1.00
1.540E-05	1.00
6.800E-06	1.00

MULTIPLIERS====>

STEP	TIME.s
1	9 000E+02
2	4 500E+03
3	7 200E+03
4	1 440E+04
5	2 860E+04
6	3 060E+04
7	8 640E+04
8	3 456E+05
9	2 592E+06

CONTROL ROOM

AVERAGE RELEASED

NMT USED THIS CASE

STEP	TIME	NMT USED THIS CASE		RCS 18XFF PER SRP -3		AVERAGE RELEASED		CONTROL ROOM	
		CURRENT	INTEGRD	CURRENT	INTEGRD	RELEASED	uCi/sec	CURRENT	INTEGRD
		uCi	uCi-sec	uCi	uCi-sec	uCi	uCi/sec	uCi	uCi-sec
KR-83m	INITIAL	0.000E+00	0.000E+00	2.290E+11	0.000E+00	7.007E+07	7.786E+04	0.000E+00	0.000E+00
1	0 2500 h	0.000E+00	0.000E+00	2.082E+11	1.966E+14	0.223E+08	6.175E+04	4.587E+04	5.364E-06
2	1 2500 h	0.000E+00	0.000E+00	1.424E+11	6.237E+14	1.192E+08	4.416E+04	2.696E+04	5.503E-06
3	2 0000 h	0.000E+00	0.000E+00	1.071E+11	3.346E+14	1.925E+08	2.673E+04	1.104E+05	2.254E-05
4	4 0000 h	0.000E+00	0.000E+00	5.008E+10	5.401E+14	1.321E+08	9.175E+03	1.466E+05	2.657E-05
5	8 0000 h	0.000E+00	0.000E+00	1.095E+10	3.707E+14	0.000E+00	0.000E+00	5.946E+04	1.214E-05
6	8 5000 h	0.000E+00	0.000E+00	2.658E+09	1.796E+13	0.000E+00	0.000E+00	1.610E+03	3.285E-08
7	24 0000 h	0.000E+00	0.000E+00	2.558E+07	8.592E+13	0.000E+00	0.000E+00	3.090E-02	6.302E-12
8	96 0000 h	0.000E+00	0.000E+00	3.679E-05	2.432E+11	0.000E+00	0.000E+00	1.680E-19	3.429E-29
9	720 0000 h	0.000E+00	0.000E+00	0.000E+00	3.497E-01	0.000E+00	0.000E+00	0.000E+00	6.000E+00
KR-83m	TOTALS	0.000E+00	0.000E+00	2.170E+15	7.362E+08	0.000E+00	0.000E+00	0.000E+00	0.000E+00

KR-85m	INITIAL	0.000E+00	0.000E+00	5.510E+11	4.864E+14	1.733E+08	1.926E+05	0.000E+00	0.000E+00
1	0 2500 h	0.000E+00	0.000E+00	5.299E+11	4.864E+14	6.295E+08	1.749E+05	1.166E+05	2.381E-05
2	1 2500 h	0.000E+00	0.000E+00	4.534E+11	1.766E+15	4.117E+08	1.525E+05	9.566E+04	1.749E-05
3	2 0000 h	0.000E+00	0.000E+00	4.033E+11	1.155E+15	8.890E+08	1.235E+05	4.129E+05	8.428E-05
4	4 0000 h	0.000E+00	0.000E+00	2.952E+11	2.494E+15	1.127E+09	7.827E+04	7.882E+05	1.609E-04
5	8 0000 h	0.000E+00	0.000E+00	1.582E+11	3.162E+15	0.000E+00	0.000E+00	7.144E+05	1.458E-04
6	8 5000 h	0.000E+00	0.000E+00	1.464E+11	2.740E+14	0.000E+00	0.000E+00	2.163E+03	4.416E-07
7	24 0000 h	0.000E+00	0.000E+00	1.330E+10	3.097E+15	0.000E+00	0.000E+00	1.337E+01	2.730E-09
8	96 0000 h	0.000E+00	0.000E+00	1.931E+05	3.095E+14	0.000E+00	0.000E+00	7.338E-10	1.498E-19
9	720 0000 h	0.000E+00	0.000E+00	0.000E+00	4.472E+09	0.000E+00	0.000E+00	0.000E+00	6.000E+00
KR-85m	TOTALS	0.000E+00	0.000E+00	1.274E+16	3.231E+09	0.000E+00	0.000E+00	0.000E+00	0.000E+00

KR-85	INITIAL	0.000E+00	0.000E+00	4.240E+10	3.815E+13	1.365E+07	1.511E+04	0.000E+00	0.000E+00
1	0 2500 h	0.000E+00	0.000E+00	4.239E+10	3.815E+13	5.435E+07	1.510E+04	9.326E+03	1.904E-06
2	1 2500 h	0.000E+00	0.000E+00	4.233E+10	1.525E+14	4.075E+07	1.505E+04	7.992E+03	1.632E-06
3	2 0000 h	0.000E+00	0.000E+00	4.229E+10	1.142E+14	4.075E+07	1.505E+04	4.319E+04	8.815E-06
4	4 0000 h	0.000E+00	0.000E+00	4.218E+10	3.041E+14	1.084E+08	1.505E+04	1.108E+05	2.262E-05
5	8 0000 h	0.000E+00	0.000E+00	4.196E+10	6.059E+14	2.159E+08	1.495E+04	1.775E+05	3.624E-05
6	8 5000 h	0.000E+00	0.000E+00	4.196E+10	7.554E+13	0.000E+00	0.000E+00	5.807E+02	1.185E-07
7	24 0000 h	0.000E+00	0.000E+00	4.196E+10	2.341E+15	0.000E+00	0.000E+00	3.950E+01	8.663E-09
8	96 0000 h	0.000E+00	0.000E+00	4.194E+10	1.087E+16	0.000E+00	0.000E+00	1.493E-04	3.047E-14
9	720 0000 h	0.000E+00	0.000E+00	4.174E+10	9.399E+16	0.000E+00	0.000E+00	0.000E+00	6.000E+00
KR-85	TOTALS	0.000E+00	0.000E+00	1.085E+17	4.330E+08	0.000E+00	0.000E+00	0.000E+00	0.000E+00

KR-87	INITIAL	0.000E+00	0.000E+00	1.060E+12	3.917E+14	3.178E+08	3.531E+05	0.000E+00	0.000E+00
1	0 2500 h	0.000E+00	0.000E+00	9.247E+11	3.917E+14	9.141E+08	2.539E+05	2.039E+05	4.162E-05
2	1 2500 h	0.000E+00	0.000E+00	5.355E+11	2.565E+15	4.228E+08	1.566E+05	1.016E+05	2.074E-05
3	2 0000 h	0.000E+00	0.000E+00	3.574E+11	1.186E+15	5.348E+08	7.708E+04	3.695E+05	7.542E-05
4	4 0000 h	0.000E+00	0.000E+00	1.190E+11	1.557E+15	2.484E+08	1.725E+04	3.505E+05	7.154E-05
5	8 0000 h	0.000E+00	0.000E+00	1.340E+10	6.971E+14	0.000E+00	0.000E+00	8.905E+04	1.818E-05
6	8 5000 h	0.000E+00	0.000E+00	1.021E+10	2.112E+13	0.000E+00	0.000E+00	2.218E+02	4.528E-08
7	24 0000 h	0.000E+00	0.000E+00	2.187E+06	6.739E+13	0.000E+00	0.000E+00	3.234E-03	6.601E-13
8	96 0000 h	0.000E+00	0.000E+00	1.981E-11	1.445E+10	0.000E+00	0.000E+00	1.107E-25	2.261E-35
9	720 0000 h	0.000E+00	0.000E+00	0.000E+00	1.308E-07	0.000E+00	0.000E+00	0.000E+00	6.000E+00
KR-87	TOTALS	0.000E+00	0.000E+00	6.985E+15	2.458E+09	0.000E+00	0.000E+00	0.000E+00	0.000E+00

STEP	TIME	NOT USED THIS CASE		RCS 18%FF PER SRP -3		AVERAGE		CONTROL ROOM	
		CURRENT	INTEGRD	CURRENT	INTEGRD	RELEASED	RELEASE	CURRENT	INTEGRD
		uCi	uCi-sec	uCi	uCi-sec	uCi	uCi/sec	uCi/cc	uCi-sec
KR-88	INITIAL	0.000E+00	0.000E+00	1.510E+12	1.318E+15	4.698E+08	5.220E+05	0.000E+00	0.000E+00
1	0 2500 h	0.000E+00	0.000E+00	1.420E+12	4.534E+15	1.616E+09	4.488E+05	2.101E+05	6.382E-05
2	1 2500 h	0.000E+00	0.000E+00	1.111E+12	4.534E+15	9.766E+08	3.617E+05	9.486E+05	1.936E-04
3	2 0000 h	0.000E+00	0.000E+00	9.244E+11	2.740E+15	1.875E+09	2.604E+05	1.534E+06	3.131E-04
4	4 0000 h	0.000E+00	0.000E+00	5.659E+11	5.260E+15	1.855E+09	1.285E+05	1.018E+06	2.078E-04
5	8 0000 h	0.000E+00	0.000E+00	2.121E+11	5.191E+15	0.000E+00	0.000E+00	2.948E+03	6.017E-07
6	8 5000 h	0.000E+00	0.000E+00	1.877E+11	3.594E+14	0.000E+00	0.000E+00	4.562E+00	9.312E-10
7	24 0000 h	0.000E+00	0.000E+00	4.270E+09	2.706E+15	0.000E+00	0.000E+00	4.023E-13	8.212E-23
8	96 0000 h	0.000E+00	0.000E+00	9.960E+01	6.298E+13	0.000E+00	0.000E+00	0.000E+00	0.000E+00
9	720 0000 h	0.000E+00	0.000E+00	0.000E+00	1.469E+06	6.787E+09	0.000E+00	0.000E+00	0.000E+00
KR-88	TOTALS	0.000E+00	0.000E+00	2.217E+16					
KR-89	INITIAL	0.000E+00	0.000E+00	1.940E+12	5.108E+14	1.821E+08	2.023E+05	0.000E+00	0.000E+00
1	0 2500 h	0.000E+00	0.000E+00	1.367E+12	1.975E+13	7.040E+06	1.955E+03	3.691E+00	7.534E-06
2	1 2500 h	0.000E+00	0.000E+00	7.156E+11	3.793E+07	1.352E+01	5.007E-03	1.639E-03	3.345E-13
3	2 0000 h	0.000E+00	0.000E+00	2.640E+11	1.957E+03	6.975E-04	9.688E-08	2.533E-08	2.11E-18
4	4 0000 h	0.000E+00	0.000E+00	3.591E-34	7.219E-09	2.573E-15	1.787E-19	4.702E-20	6.11E-30
5	8 0000 h	0.000E+00	0.000E+00	4.980E-37	9.810E-32	0.000E+00	0.000E+00	2.136E-25	4.260E-35
6	8 5000 h	0.000E+00	0.000E+00	0.000E+00	1.362E-34	0.000E+00	0.000E+00	0.000E+00	0.000E+00
7	24 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00
8	96 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00
9	720 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	1.891E+08	0.000E+00	0.000E+00	0.000E+00
KR-89	TOTALS	0.000E+00	0.000E+00	5.306E+14					
XE-131M	INITIAL	0.000E+00	0.000E+00	9.330E+09	8.393E+12	2.991E+06	3.324E+03	0.000E+00	0.000E+00
1	0 2500 h	0.000E+00	0.000E+00	9.287E+09	3.349E+13	1.194E+07	3.316E+03	1.753E+03	3.579E-07
2	1 2500 h	0.000E+00	0.000E+00	9.261E+09	2.504E+13	8.924E+06	3.305E+03	9.457E+03	1.930E-06
3	2 0000 h	0.000E+00	0.000E+00	9.192E+09	6.643E+13	2.368E+07	3.268E+03	2.415E+04	4.930E-06
4	4 0000 h	0.000E+00	0.000E+00	9.056E+09	1.314E+14	4.683E+07	3.252E+03	3.833E+04	7.825E-06
5	8 0000 h	0.000E+00	0.000E+00	9.045E+09	1.629E+13	0.000E+00	0.000E+00	1.253E+02	2.557E-08
6	8 5000 h	0.000E+00	0.000E+00	8.710E+09	4.953E+14	0.000E+00	0.000E+00	8.204E+00	1.675E-09
7	24 0000 h	0.000E+00	0.000E+00	7.307E+09	2.070E+15	0.000E+00	0.000E+00	2.602E-05	5.312E-15
8	96 0000 h	0.000E+00	0.000E+00	1.595E+09	8.430E+15	0.000E+00	0.000E+00	0.000E+00	0.000E+00
9	720 0000 h	0.000E+00	0.000E+00	1.128E+16		9.435E+07	0.000E+00	0.000E+00	0.000E+00
XE-131M	TOTALS	0.000E+00	0.000E+00						
XE-133M	INITIAL	0.000E+00	0.000E+00	7.210E+10	6.477E+13	2.309E+07	2.565E+04	0.000E+00	0.000E+00
1	0 2500 h	0.000E+00	0.000E+00	7.081E+10	6.568E+14	9.151E+07	2.542E+04	1.337E+04	2.729E-06
2	1 2500 h	0.000E+00	0.000E+00	7.004E+10	1.901E+14	6.777E+07	2.510E+04	7.153E+04	1.460E-05
3	2 0000 h	0.000E+00	0.000E+00	6.805E+10	4.971E+14	3.772E+06	2.461E+04	1.789E+05	3.652E-05
4	4 0000 h	0.000E+00	0.000E+00	6.422E+10	9.520E+14	3.373E+08	2.356E+04	2.726E+05	5.565E-05
5	8 0000 h	0.000E+00	0.000E+00	6.380E+10	1.152E+15	0.000E+00	0.000E+00	8.860E+02	1.809E-07
6	8 5000 h	0.000E+00	0.000E+00	5.200E+10	3.220E+15	0.000E+00	0.000E+00	4.913E+01	1.003E-08
7	24 0000 h	0.000E+00	0.000E+00	2.012E+10	8.703E+15	0.000E+00	0.000E+00	7.188E-05	1.467E-14
8	96 0000 h	0.000E+00	0.000E+00	5.371E+06	5.492E+15	0.000E+00	0.000E+00	0.000E+00	0.000E+00
9	720 0000 h	0.000E+00	0.000E+00	1.949E+16		6.985E+08	0.000E+00	0.000E+00	0.000E+00
XE-133M	TOTALS	0.000E+00	0.000E+00						

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Pri-to-sec leak N.G. in U1 LRA assuming 1BZ F. (non-equi1)

STEP TIME	NOT USED THIS CASE		RCS 1BZFF PER SRP -3		AVERAGE RELEASED		CONTROL ROOM		
	CURRENT uCi	INTEGRD uCi-sec	CURRENT uCi	INTEGRD uCi-sec	RELEASED uCi	RELEASED uCi/sec	CURRENT uCi	CURRENT uCi/cc	INTEGRD uCi-sec
XE-133 INITIAL	0.000E+00	0.000E+00	2.850E+12	2.563E+15	9.134E+08	1.015E+06	0.000E+00	0.000E+00	0.000E+00
1 0 2500 h	0.000E+00	0.000E+00	2.845E+12	2.563E+15	9.134E+08	1.015E+06	6.260E+05	1.278E-04	2.838E+08
2 1 2500 h	0.000E+00	0.000E+00	2.826E+12	1.021E+16	3.638E+09	1.011E+06	5.336E+05	1.089E-04	2.080E+09
3 ~ 0000 h	0.000E+00	0.000E+00	2.812E+12	7.611E+15	2.712E+09	1.003E+06	2.871E+06	5.861E-04	4.694E+09
4 4 0000 h	0.000E+00	0.000E+00	2.774E+12	2.011E+16	7.166E+09	9.953E+05	2.289E+06	1.498E-03	3.789E+10
5 8 0000 h	0.000E+00	0.000E+00	2.699E+12	3.940E+16	1.404E+10	9.752E+05	1.143E+07	2.334E-03	1.397E+11
6 8 5000 h	0.000E+00	0.000E+00	2.692E+12	4.852E+15	0.000E+00	0.000E+00	3.731E+04	7.615E-06	3.583E+09
7 24 0000 h	0.000E+00	0.000E+00	2.472E+12	1.440E+17	0.000E+00	0.000E+00	2.330E+03	4.756E-07	7.037E+08
8 96 0000 h	0.000E+00	0.000E+00	1.662E+12	5.289E+17	0.000E+00	0.000E+00	5.926E-03	1.210E-12	4.688E+07
9 720 0000 h	0.000E+00	0.000E+00	5.347E+10	1.052E+18	0.000E+00	0.000E+00	0.000E+00	0.000E+00	1.192E+02
XE-133 TOTALS	0.000E+00	0.000E+00	2.847E+10	1.809E+18	2.847E+10	0.000E+00	0.000E+00	0.000E+00	1.890E+11
XE-135M INITIAL	0.000E+00	0.000E+00	7.630E+11	4.989E+14	1.778E+08	1.975E+05	0.000E+00	0.000E+00	0.000E+00
1 0 2500 h	0.000E+00	0.000E+00	3.876E+11	4.808E+14	1.714E+08	4.760E+04	8.882E+04	1.813E-05	4.472E+07
2 1 2500 h	0.000E+00	0.000E+00	2.982E+10	4.808E+14	1.714E+08	4.760E+04	5.419E+03	1.106E-06	1.047E+08
3 2 0000 h	0.000E+00	0.000E+00	3.386E+09	2.982E+13	1.063E+07	3.936E+03	4.789E+03	9.777E-07	1.349E+07
4 4 0000 h	0.000E+00	0.000E+00	1.502E+07	4.808E+12	1.597E+06	2.217E+02	2.779E+02	5.672E-08	7.416E+06
5 8 0000 h	0.000E+00	0.000E+00	2.958E+02	1.997E+11	7.116E+03	4.942E-01	5.937E-01	1.212E-10	3.468E+05
6 8 5000 h	0.000E+00	0.000E+00	7.640E+01	2.918E+05	0.000E+00	0.000E+00	5.016E-04	1.024E-13	1.509E+02
7 24 0000 h	0.000E+00	0.000E+00	4.539E-17	1.016E+05	0.000E+00	0.000E+00	2.027E-23	4.138E-33	6.268E-01
8 96 0000 h	0.000E+00	0.000E+00	0.000E+00	6.035E-14	0.000E+00	0.000E+00	0.000E+00	0.000E+00	2.533E-20
9 720 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00
XE-135M TOTALS	0.000E+00	0.000E+00	3.614E+08	1.014E+15	3.614E+08	0.000E+00	0.000E+00	0.000E+00	1.707E+08
XE-135 INITIAL	0.000E+00	0.000E+00	7.760E+11	6.917E+14	2.465E+08	2.739E+05	0.000E+00	0.000E+00	0.000E+00
1 0 2500 h	0.000E+00	0.000E+00	7.611E+11	6.917E+14	2.465E+08	2.739E+05	1.675E+05	3.419E-05	7.616E+07
2 1 2500 h	0.000E+00	0.000E+00	7.049E+11	2.637E+15	9.397E+08	2.610E+05	1.330E+05	2.716E-05	5.377E+08
3 2 0000 h	0.000E+00	0.000E+00	6.647E+11	1.848E+15	6.586E+08	2.439E+05	6.795E+05	1.387E-04	1.126E+09
4 4 0000 h	0.000E+00	0.000E+00	5.694E+11	4.434E+15	1.580E+09	2.195E+05	1.505E+06	3.073E-04	8.180E+09
5 8 0000 h	0.000E+00	0.000E+00	4.178E+11	7.052E+15	2.513E+09	1.745E+05	1.814E+06	3.703E-04	2.436E+10
6 8 5000 h	0.000E+00	0.000E+00	4.022E+11	7.380E+14	0.000E+00	0.000E+00	5.712E+03	1.166E-06	3.650E+08
7 24 0000 h	0.000E+00	0.000E+00	1.236E+11	1.318E+16	0.000E+00	0.000E+00	1.194E+02	2.438E-08	8.069E+07
8 96 0000 h	0.000E+00	0.000E+00	5.158E+08	5.824E+15	0.000E+00	0.000E+00	1.884E-06	3.846E-16	1.723E+06
9 720 0000 h	0.000E+00	0.000E+00	1.225E-12	2.440E+13	0.000E+00	0.000E+00	0.000E+00	0.000E+00	2.718E-02
XE-135 TOTALS	0.000E+00	0.000E+00	3.643E+09	3.643E+16	5.938E+09	0.000E+00	0.000E+00	0.000E+00	3.493E+10
XE-137 INITIAL	0.000E+00	0.000E+00	2.500E+12	7.739E+14	2.758E+08	3.065E+05	0.000E+00	0.000E+00	0.000E+00
1 0 2500 h	0.000E+00	0.000E+00	1.656E+11	7.739E+14	2.758E+08	3.065E+05	6.565E+04	1.340E-05	4.166E+07
2 1 2500 h	0.000E+00	0.000E+00	3.184E+06	5.489E+13	1.956E+07	5.434E+03	2.569E+01	5.245E-09	2.137E+07
3 2 0000 h	0.000E+00	0.000E+00	9.248E+02	1.055E+09	3.761E+02	1.393E-01	5.054E-02	1.032E-11	8.436E+03
4 4 0000 h	0.000E+00	0.000E+00	3.421E-07	3.066E+05	1.093E-01	1.518E-05	4.829E-06	9.858E-16	1.642E+01
5 8 0000 h	0.000E+00	0.000E+00	4.681E-26	1.134E-04	4.042E-11	2.807E-15	8.932E-16	1.823E-25	1.566E-03
6 8 5000 h	0.000E+00	0.000E+00	2.054E-28	1.545E-23	0.000E+00	0.000E+00	1.282E-20	2.617E-30	1.442E-13
7 24 0000 h	0.000E+00	0.000E+00	0.000E+00	6.811E-26	0.000E+00	0.000E+00	0.000E+00	0.000E+00	4.185E-18
8 96 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00
9 720 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00
XE-137 TOTALS	0.000E+00	0.000E+00	8.288E+14	8.288E+14	2.954E+08	0.000E+00	0.000E+00	0.000E+00	6.304E+07

FRILLS -- Transport of Radioactive Material in Linear Systems, v1.0
 Pri-to-sec leak N.G. in UI LRA assuming 18% F.F. (non-equil)

STEP	TIME	NOT USED THIS CASE		RCS 18%FF PER SRP -3		AVERAGE		CONTROL ROOM		
		CURRENT	INTEGRD	CURRENT	INTEGRD	RELEASED	RELEAASE	CURRENT	CURRENT	INTEGRD
		uCi	uCi-sec	uCi	uCi-sec	uCi	uCi/sec	uCi	uCi/cc	uCi-sec
XE-138	INITIAL									
1	0 2500 h	0.000E+00	0.000E+00	2.500E+12	1.593E+19	5.675E+08	6.306E+05	0.000E+00	5.640E-05	1.403E+08
2	1 2500 h	0.000E+00	0.000E+00	1.197E+12	1.387E+15	4.943E+08	1.373E+05	2.763E+05	2.757E-06	3.048E+08
3	2 0000 h	0.000E+00	0.000E+00	6.301E+10	6.357E+13	2.444E+07	9.051E+03	1.350E+04	2.113E-06	3.065E+07
4	4 0000 h	0.000E+00	0.000E+00	6.922E+09	6.440E+12	3.008E+06	4.178E+02	1.035E+04	9.799E-08	1.449E+07
5	8 0000 h	0.000E+00	0.000E+00	1.917E+07	1.470E+02	3.008E+06	4.178E+02	4.800E+02	1.315E-10	5.309E+05
6	8 5000 h	0.000E+00	0.000E+00	1.470E+02	2.343E+10	8.352E+03	5.800E-01	6.444E-01	9.877E-14	1.611E+02
7	24 0000 h	0.000E+00	0.000E+00	3.373E+01	1.383E+05	0.000E+00	0.000E+00	4.839E-04	1.033E-34	5.589E-01
9	96 0000 h	0.000E+00	0.000E+00	5.184E-19	4.126E+04	0.000E+00	0.000E+00	5.058E-23	0.000E+00	5.842E-22
9	720 0000 h	0.000E+00	0.000E+00	0.000E+00	6.340E-16	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00
XE-138	TOTALS	0.000E+00	0.000E+00	9.681E+10	3.056E+15	1.089E+07	0.000E+00	0.000E+00	0.000E+00	4.908E+08
ALL NUCLIDES		0.000E+00		9.681E+10				0.000E+00	0.000E+00	
@ STEP	9									

IRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Pri-to-sec Leak NG in UI LRA assuming 18% F.F. (non-equil)

		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL	
		DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE
		mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
KR-B3m													
0 2500 h	1.91E-03	7.63E-03	1.03E-01	0.00E+00	0.00E+00	1.41E-04	1.0E-03	3.79E-02	2.96E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00
1 2500 h	6.07E-03	6.07E-03	8.20E-02	0.00E+00	0.00E+00	8.51E-04	6.47E-04	2.29E-01	1.74E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2 0000 h	3.26E-03	4.34E-03	5.87E-02	0.00E+00	0.00E+00	1.30E-03	2.65E-03	3.48E-01	7.13E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4 0000 h	5.25E-03	2.63E-03	3.55E-02	0.00E+00	0.00E+00	6.15E-03	3.36E-03	1.55E+00	9.04E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 0000 h	3.61E-03	9.02E-04	4.88E-02	0.00E+00	0.00E+00	8.12E-03	1.43E-03	2.18E+00	3.84E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.20E-04	3.86E-06	3.24E-02	1.04E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.00E-06	7.42E-10	1.88E-03	2.00E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.34E-09	4.03E-27	3.61E-07	1.08E-24	0.00E+00	0.00E+00	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.31E-27	0.00E+00	1.96E-24	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS	2.01E-02		2.72E-01	0.00E+00	0.00E+00	1.67E-02		4.49E+00		0.00E+00		0.00E+00	

		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL	
		DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE
		mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
KR-B5m													
0 2500 h	2.87E-01	1.15E+00	4.27E-01	0.00E+00	0.00E+00	2.15E-02	1.70E-01	6.38E-01	5.03E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
1 2500 h	1.04E+00	1.04E+00	1.55E+00	0.00E+00	0.00E+00	1.46E-01	1.25E-01	4.32E+00	3.70E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2 0000 h	6.82E-01	9.09E-01	1.35E+00	0.00E+00	0.00E+00	2.81E-01	6.01E-01	8.33E+00	1.78E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4 0000 h	1.47E+00	7.36E-01	2.19E+00	0.00E+00	0.00E+00	1.82E+00	1.15E+00	5.39E+01	3.40E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 0000 h	1.87E+00	4.57E-01	2.78E+00	0.00E+00	0.00E+00	4.32E+00	1.04E+00	1.28E+02	3.08E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.94E-02	3.15E-03	2.65E+00	9.33E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.54E-03	1.95E-05	2.83E-01	5.77E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.93E-05	1.07E-15	1.76E-03	3.17E-14	0.00E+00	0.00E+00	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.26E-15	0.00E+00	9.65E-14	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS	5.35E+00		7.97E+00	0.00E+00	0.00E+00	6.69E+00		1.98E+02		0.00E+00		0.00E+00	

		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL	
		DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE
		mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
KR-B5													
0 2500 h	3.14E-04	1.26E-03	1.32E-01	0.00E+00	0.00E+00	2.39E-05	1.89E-04	4.98E-02	3.96E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00
1 2500 h	1.26E-03	1.26E-03	1.32E-01	0.00E+00	0.00E+00	1.75E-04	1.62E-04	3.66E-01	3.39E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2 0000 h	9.41E-04	1.25E-03	8.7E-02	0.00E+00	0.00E+00	3.98E-04	8.77E-04	8.31E-01	1.83E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4 0000 h	2.50E-03	1.25E-03	2.63E-01	0.00E+00	0.00E+00	3.24E-03	2.25E-03	6.76E+00	4.70E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 0000 h	4.99E-03	1.25E-03	5.24E-01	0.00E+00	0.00E+00	1.21E-02	3.61E-03	2.54E+01	7.53E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.14E-04	1.18E-05	6.56E-01	2.46E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.34E-05	8.02E-07	1.32E-01	1.68E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.63E-06	3.03E-12	9.66E-03	6.33E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.75E-11	0.00E+00	3.65E-08	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS	1.00E-02		1.05E+00	0.00E+00	0.00E+00	1.64E-02		3.42E+01		0.00E+00		0.00E+00	

		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL	
		DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE
		mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
KR-B7													
0 2500 h	2.65E+00	1.06E+01	1.63E+01	0.00E+00	0.00E+00	1.92E-01	1.49E+00	5.87E+00	4.56E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00
1 2500 h	7.61E+00	7.61E+00	1.17E+01	0.00E+00	0.00E+00	1.07E+00	7.44E-01	3.27E+01	2.27E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2 0000 h	3.52E+00	4.69E+00	7.21E+00	0.00E+00	0.00E+00	1.37E+00	2.71E+00	4.17E+01	8.27E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4 0000 h	4.62E+00	2.31E+00	3.59E+00	0.00E+00	0.00E+00	5.24E+00	2.51E+00	1.60E+02	7.84E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 0000 h	2.07E+00	5.17E-01	7.94E-01	0.00E+00	0.00E+00	4.70E+00	6.52E-01	1.43E+02	1.99E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.43E-02	1.62E-03	1.66E+00	4.96E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.26E-03	2.37E-08	6.90E-02	7.23E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.30E-08	8.11E-31	1.01E-06	2.48E-29	0.00E+00	0.00E+00	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.13E-30	0.00E+00	3.45E-29	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS	2.05E+01		3.14E+01	0.00E+00	0.00E+00	1.26E+01		3.85E+02		0.00E+00		0.00E+00	

		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL	
		DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE
		mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
KR-88	0 2500 h	9.64E+00	3.86E+01	1.66E+00	6.62E+00	0.00E+00	0.00E+00	7.1E-01	5.64E+00	2.45E+00	1.73E+01	0.00E+00	0.00E+00
	1 2500 h	3.32E+01	3.32E+01	5.69E+00	5.69E+00	0.00E+00	0.00E+00	4.64E+00	3.79E+00	1.59E+01	1.30E+01	0.00E+00	0.00E+00
	2 0000 h	2.00E+01	2.67E+01	3.44E+00	4.59E+00	0.00E+00	0.00E+00	8.15E+00	1.71E+01	2.78E+01	5.85E+01	0.00E+00	0.00E+00
	4 0000 h	3.85E+01	1.92E+01	6.61E+00	3.30E+00	0.00E+00	0.00E+00	4.55E+01	2.77E+01	1.59E+02	9.46E+01	0.00E+00	0.00E+00
	8 0000 h	3.80E+01	9.49E+00	6.52E+00	1.63E+00	0.00E+00	0.00E+00	8.64E+01	1.84E+01	2.95E+02	6.28E+02	0.00E+00	0.00E+00
	8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.57E+00	5.32E-02	5.35E+00	1.82E-01	0.00E+00	0.00E+00
	24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.27E-01	8.23E-05	4.35E-01	2.81E-04	0.00E+00	0.00E+00
	96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.97E-04	7.26E-18	6.74E-04	2.48E-17	0.00E+00	0.00E+00
	720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.74E-17	0.00E+00	5.94E-17	0.00E+00	0.00E+00	0.00E+00
TOTALS		1.39E+02		2.39E+01		0.00E+00		1.48E+02		5.06E+02		0.00E+00	

		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL	
		DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE
		mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
KR-89	0 2500 h	3.51E+00	1.40E+01	2.40E+00	9.58E+00	0.00E+00	0.00E+00	1.15E-01	6.25E-01	1.57E+00	8.50E+00	0.00E+00	0.00E+00
	1 2500 h	1.36E-01	1.36E-01	9.26E-02	9.26E-02	0.00E+00	0.00E+00	4.68E-02	1.25E-04	6.35E-01	1.71E-03	0.00E+00	0.00E+00
	2 0000 h	2.60E-07	3.47E-07	1.78E-07	2.37E-07	0.00E+00	0.00E+00	9.39E-06	2.71E-08	1.28E-04	3.77E-07	0.00E+00	0.00E+00
	4 0000 h	1.34E-11	6.72E-12	8.46E-12	4.59E-12	0.00E+00	0.00E+00	2.07E-09	4.32E-13	2.81E-08	5.88E-12	0.00E+00	0.00E+00
	8 0000 h	4.96E-23	1.24E-23	3.39E-23	8.46E-24	0.00E+00	0.00E+00	3.23E-14	7.97E-25	4.38E-13	1.08E-23	0.00E+00	0.00E+00
	8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.24E-26	3.62E-30	4.40E-25	4.92E-29	0.00E+00	0.00E+00
	24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.71E-31	0.00E+00	3.69E-30	0.00E+00	0.00E+00	0.00E+00
	96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
	720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS		3.64E+00		2.49E+00		0.00E+00		1.62E-01		2.20E+00		0.00E+00	

		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL	
		DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE
		mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
XE-131M	0 2500 h	6.31E-04	2.53E-03	4.11E-03	1.64E-02	0.00E+00	0.00E+00	4.79E-05	3.81E-04	6.21E-03	4.73E-02	0.00E+00	0.00E+00
	1 2500 h	2.52E-03	2.52E-03	1.64E-02	1.64E-02	0.00E+00	0.00E+00	3.52E-04	3.25E-04	4.56E-02	4.51E-02	0.00E+00	0.00E+00
	2 0000 h	1.88E-03	2.51E-03	1.23E-02	1.63E-02	0.00E+00	0.00E+00	7.97E-04	1.75E-03	1.03E-01	2.27E-01	0.00E+00	0.00E+00
	4 0000 h	5.00E-03	2.50E-03	3.25E-02	1.63E-02	0.00E+00	0.00E+00	6.46E-03	4.48E-03	8.36E-01	5.60E-01	0.00E+00	0.00E+00
	8 0000 h	9.88E-03	2.47E-03	6.43E-02	1.61E-02	0.00E+00	0.00E+00	2.40E-02	7.11E-03	3.11E+00	9.21E-01	0.00E+00	0.00E+00
	8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.19E-04	2.32E-05	8.02E-02	3.01E-03	0.00E+00	0.00E+00
	24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.24E-04	1.52E-06	1.60E-02	1.97E-04	0.00E+00	0.00E+00
	96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.66E-06	4.83E-12	1.12E-03	6.25E-10	0.00E+00	0.00E+00
	720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.75E-11	0.00E+00	3.56E-09	0.00E+00	0.00E+00	0.00E+00
TOTALS		1.99E-02		1.30E-01		0.00E+00		7.24E-02		4.20E+00		0.00E+00	

		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL	
		DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE
		mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
XE-133M	0 2500 h	1.01E-02	4.02E-02	4.24E-02	1.70E-01	0.00E+00	0.00E+00	7.63E-04	6.06E-03	6.40E-02	5.08E-01	0.00E+00	0.00E+00
	1 2500 h	3.99E-02	3.99E-02	1.68E-01	1.68E-01	0.00E+00	0.00E+00	5.57E-03	5.12E-03	4.67E-01	4.30E-01	0.00E+00	0.00E+00
	2 0000 h	2.95E-02	3.94E-02	1.25E-01	1.66E-01	0.00E+00	0.00E+00	1.25E-02	2.74E-02	1.05E+00	2.30E+00	0.00E+00	0.00E+00
	4 0000 h	7.72E-02	3.86E-02	3.26E-01	1.63E-01	0.00E+00	0.00E+00	9.95E-02	6.86E-02	8.34E+00	8.75E+00	0.00E+00	0.00E+00
	8 0000 h	1.48E-01	3.70E-02	6.23E-01	1.36E-01	0.00E+00	0.00E+00	3.58E-01	1.04E-01	3.00E+01	8.76E+00	0.00E+00	0.00E+00
	8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.09E-03	3.39E-04	7.62E-01	2.85E-02	0.00E+00	0.00E+00
	24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.72E-03	1.88E-05	1.44E-01	1.58E-03	0.00E+00	0.00E+00
	96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.01E-04	2.75E-11	8.46E-03	2.31E-09	0.00E+00	0.00E+00
	720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.48E-10	0.00E+00	1.24E-08	0.00E+00	0.00E+00	0.00E+00
TOTALS		3.05E-01		1.28E+00		0.00E+00		4.87E-01		4.09E+01		0.00E+00	

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Pri-to-sec leak N.G. in UI LRA assuming 18% F.F. (non-equil)

TIME	PHOTON-SUBMG			BETA-SUBMG			THYROID-INHAL			PHOTON-SUBMG			BETA-SUBMG			THYROID-INHAL		
	DOSE mrem	DOSE RATE mrem/hr	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE RATE mrem/hr
0 2500 h	4.34E-01	1.74E+00	4.78E+00	0.00E+00	0.00E+00	0.00E+00	3.30E-02	2.62E-01	1.81E+00	1.43E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
1 2500 h	1.73E+00	1.73E+00	4.76E+00	0.00E+00	0.00E+00	0.00E+00	2.42E-01	2.23E-01	1.32E+01	1.22E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2 0000 h	1.29E+00	1.72E+00	4.73E+00	0.00E+00	0.00E+00	0.00E+00	5.45E-01	1.20E+00	2.99E+01	6.58E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4 0000 h	3.41E+00	1.70E+00	4.69E+00	0.00E+00	0.00E+00	0.00E+00	4.40E+00	3.03E+00	2.41E+02	1.67E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 0000 h	6.68E+00	1.67E+00	4.60E+00	0.00E+00	0.00E+00	0.00E+00	1.62E+01	4.78E+00	8.88E+02	2.62E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.16E-01	1.56E-02	2.28E+01	5.54E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.18E-02	9.74E-04	4.48E+00	5.34E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.45E-03	2.48E-09	2.98E-01	1.36E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.39E-08	0.00E+00	7.58E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS	1.35E+01		3.73E+01	0.00E+00	0.00E+00	0.00E+00	2.20E+01		1.20E+03		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

TIME	PHOTON-SUBMG			BETA-SUBMG			THYROID-INHAL			PHOTON-SUBMG			BETA-SUBMG			THYROID-INHAL		
	DOSE mrem	DOSE RATE mrem/hr	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE RATE mrem/hr
0 2500 h	8.04E-01	3.22E+00	6.58E-01	0.00E+00	0.00E+00	0.00E+00	4.94E-02	3.53E-01	2.01E-01	1.44E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
1 2500 h	7.75E-01	7.75E-01	1.59E-01	0.00E+00	0.00E+00	0.00E+00	1.16E-01	2.15E-02	4.71E-01	8.77E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2 0000 h	4.81E-02	6.41E-02	1.31E-02	0.00E+00	0.00E+00	0.00E+00	1.49E-02	1.90E-02	6.07E-02	7.75E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4 0000 h	7.22E-03	3.61E-03	7.39E-04	0.00E+00	0.00E+00	0.00E+00	8.19E-03	1.10E-03	3.33E-02	4.50E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 0000 h	3.22E-05	8.05E-06	1.65E-06	0.00E+00	0.00E+00	0.00E+00	3.83E-04	2.36E-06	1.56E-03	9.61E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.67E-07	1.99E-09	4.78E-07	8.12E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.92E-10	8.06E-29	2.82E-09	3.28E-28	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.80E-29	0.00E+00	1.14E-28	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS	1.63E+00		3.34E-01	0.00E+00	0.00E+00	0.00E+00	1.89E-01		7.67E-01		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

TIME	PHOTON-SUBMG			BETA-SUBMG			THYROID-INHAL			PHOTON-SUBMG			BETA-SUBMG			THYROID-INHAL		
	DOSE mrem	DOSE RATE mrem/hr	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE RATE mrem/hr
0 2500 h	6.42E-01	2.57E+00	7.58E-01	0.00E+00	0.00E+00	0.00E+00	4.84E-02	3.80E-01	1.14E+00	9.01E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
1 2500 h	2.45E+00	2.45E+00	2.89E+00	0.00E+00	0.00E+00	0.00E+00	3.42E-01	3.04E-01	8.03E+00	7.15E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2 0000 h	1.71E+00	2.29E+00	2.02E+00	0.00E+00	0.00E+00	0.00E+00	7.16E-01	1.56E+00	1.68E+01	3.65E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4 0000 h	4.11E+00	2.06E+00	4.86E+00	0.00E+00	0.00E+00	0.00E+00	3.20E+00	3.45E+00	1.22E+02	8.09E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 0000 h	6.54E+00	1.64E+00	7.72E+00	0.00E+00	0.00E+00	0.00E+00	1.55E+01	4.15E+00	3.64E+02	9.75E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.59E-01	1.31E-02	8.44E+00	3.07E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.13E-02	2.73E-04	1.20E+00	6.42E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.10E-03	4.31E-12	2.57E-02	1.01E-10	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.73E-11	0.00E+00	4.06E-10	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS	1.55E+01		1.82E+01	0.00E+00	0.00E+00	0.00E+00	2.22E+01		5.21E+02		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

TIME	PHOTON-SUBMG			BETA-SUBMG			THYROID-INHAL			PHOTON-SUBMG			BETA-SUBMG			THYROID-INHAL		
	DOSE mrem	DOSE RATE mrem/hr	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE RATE mrem/hr
0 2500 h	5.44E-01	2.17E+00	4.74E+00	0.00E+00	0.00E+00	0.00E+00	2.01E-02	1.14E-01	3.48E+00	1.97E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
1 2500 h	3.66E-02	3.66E-02	3.36E-01	0.00E+00	0.00E+00	0.00E+00	1.03E-02	4.45E-05	1.78E+00	7.72E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2 0000 h	7.41E-07	9.88E-07	6.46E-06	0.00E+00	0.00E+00	0.00E+00	4.06E-06	8.76E-08	7.04E-04	1.52E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4 0000 h	2.15E-10	1.08E-10	1.88E-09	0.00E+00	0.00E+00	0.00E+00	7.91E-09	8.37E-12	1.37E-06	1.45E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 0000 h	7.97E-20	1.99E-20	6.94E-19	0.00E+00	0.00E+00	0.00E+00	7.54E-13	1.55E-21	1.31E-10	2.68E-19	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.94E-23	2.22E-26	1.20E-20	3.85E-24	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.01E-27	0.00E+00	3.49E-25	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS	5.82E-01		5.07E+00	0.00E+00	0.00E+00	0.00E+00	3.04E-02		5.26E+00		0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Pri-to-sec leak N.G. in U1 LRA assuming 18% F.F. (non-equil)

TIME	PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		R D O M		B E T A		T H Y R O I D	
	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE
	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
0 2500 h	6.71E+00	2.68E+01	3.46E+00	1.38E+01	0.00E+00	0.00E+00	4.05E-01	2.87E+00	4.16E+00	2.95E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
1 2500 h	5.84E+00	5.84E+00	3.02E+00	3.02E+00	0.00E+00	0.00E+00	8.80E-01	1.40E-01	9.03E+00	1.44E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2 0000 h	2.89E-01	3.85E-01	1.87E-01	1.97E-01	0.00E+00	0.00E+00	8.85E-02	1.08E-01	9.09E-01	1.10E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4 0000 h	3.56E-02	1.78E-02	1.83E-02	9.17E-03	0.00E+00	0.00E+00	4.18E-02	4.99E-03	4.29E-01	5.12E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 0000 h	9.87E-05	2.47E-05	5.09E-05	1.27E-05	0.00E+00	0.00E+00	1.59E-03	6.70E-06	1.63E-02	6.88E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.65E-07	5.03E-07	4.79E-06	5.16E-08	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.61E-09	5.26E-30	1.66E-08	5.40E-29	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.69E-30	0.00E+00	1.73E-29	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS	1.29E+01	1.29E+01	6.65E+00	6.65E+00	0.00E+00	0.00E+00	1.42E+00	1.42E+00	1.45E+01	1.45E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

TIME	PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		R D O M		B E T A		T H Y R O I D	
	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE
	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
0 2500 h	2.52E+01	1.01E+02	1.90E+01	7.59E+01	0.00E+00	0.00E+00	1.60E+00	1.19E+01	2.15E+01	1.54E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
1 2500 h	5.28E+01	5.28E+01	3.06E+01	3.06E+01	0.00E+00	0.00E+00	7.50E+00	5.36E+00	8.71E+01	6.13E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2 0000 h	2.76E+01	3.68E+01	1.59E+01	2.12E+01	0.00E+00	0.00E+00	1.12E+01	2.33E+01	1.28E+02	2.68E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4 0000 h	5.22E+01	2.61E+01	3.08E+01	1.54E+01	0.00E+00	0.00E+00	6.33E+01	3.80E+01	7.54E+02	4.67E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 0000 h	5.53E+01	1.38E+01	3.98E+01	9.96E+00	0.00E+00	0.00E+00	1.28E+02	2.91E+01	1.88E+03	4.91E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.50E+00	8.70E-02	4.24E+01	1.54E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.74E-01	1.37E-03	6.76E+00	6.41E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.91E-03	2.52E-09	3.46E-01	1.45E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.41E-08	0.00E+00	8.11E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS	2.13E+02	2.13E+02	1.36E+02	1.36E+02	0.00E+00	0.00E+00	2.14E+02	2.14E+02	2.92E+03	2.92E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Concurrent iodine spike - LPZ and C.R. Doses

COMP: Reactor Coolant System COMP: 3 Steam Generators COMP: Control Room
 VOLUME: 1.730E+05 Cu.Ft

INITIAL	COMP: Reactor Coolant System	COMP: 3 Steam Generators	COMP: Control Room
0.000E+00	KR-83m	0.000E+00	KR-83m
0.000E+00	KR-85m	0.000E+00	KR-85m
0.000E+00	KR-85	0.000E+00	KR-85
0.000E+00	KR-87	0.000E+00	KR-87
0.000E+00	KR-88	0.000E+00	KR-88
0.000E+00	KR-89	0.000E+00	KR-89
0.000E+00	KR-90	0.000E+00	KR-90
0.000E+00	XE-131M	0.000E+00	XE-131M
0.000E+00	XE-133M	0.000E+00	XE-133M
0.000E+00	XE-133	0.000E+00	XE-133
0.000E+00	XE-135M	0.000E+00	XE-135M
0.000E+00	XE-135	0.000E+00	XE-135
0.000E+00	XE-137	0.000E+00	XE-137
0.000E+00	XE-138	0.000E+00	XE-138
0.000E+00	I-131	0.000E+00	I-131
0.000E+00	I-132	0.000E+00	I-132
0.000E+00	I-133	0.000E+00	I-133
0.000E+00	I-134	0.000E+00	I-134
0.000E+00	I-135	0.000E+00	I-135
1.000E+00		1.000E+00	

ACT MULT (to uCi):

PRODUCTION, uCi/s	COMP: Reactor Coolant System	COMP: 3 Steam Generators	COMP: Control Room
0.000E+00	KR-83m	0.000E+00	KR-83m
0.000E+00	KR-85m	0.000E+00	KR-85m
0.000E+00	KR-85	0.000E+00	KR-85
0.000E+00	KR-87	0.000E+00	KR-87
0.000E+00	KR-88	0.000E+00	KR-88
0.000E+00	KR-89	0.000E+00	KR-89
0.000E+00	KR-90	0.000E+00	KR-90
0.000E+00	XE-131M	0.000E+00	XE-131M
0.000E+00	XE-133M	0.000E+00	XE-133M
0.000E+00	XE-133	0.000E+00	XE-133
0.000E+00	XE-135M	0.000E+00	XE-135M
0.000E+00	XE-135	0.000E+00	XE-135
0.000E+00	XE-137	0.000E+00	XE-137
0.000E+00	XE-138	0.000E+00	XE-138
1.360E+06	I-131	0.000E+00	I-131
2.520E+06	I-132	0.000E+00	I-132
3.080E+06	I-133	0.000E+00	I-133
3.680E+06	I-134	0.000E+00	I-134
2.810E+06	I-135	0.000E+00	I-135
3.564E-07		2.099E-06	
0.000E+00		0.000E+00	
0.000E+00		0.000E+00	

REMOVAL:
 NUC 1-1a REL FR:
 NUC 15-20 REL FR:

INTAKE: 1.000E+01 CFM
 INTAKE: 1.000E+01 CFM
 INTAKE REDUCT: 0.000E+00
 INTAKE FILTER: 9.360E-01

CASE 3

TRAILS --- Transport of Radioactive Material in Linear Systems, v1.0
 Concurrent iodine spike - LPZ and C.R. Doses

MULTIPLIERS====>

STEP	TIME	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF
1	2 000E+02	1.00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00	50.0	50.0	0.000E+00
2	4 500E+03	1.00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	1.00	70.0	0.000E+00	1.00	70.0	0.000E+00
3	7 200E+03	1.00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	70.0	70.0	0.000E+00	70.0	70.0	1.00
4	1 440E+04	1.00	1.00	0.000E+00	0.000E+00	0.596	0.000E+00	70.0	70.0	0.000E+00	70.0	70.0	1.00
5	2 880E+04	2.000E-03	1.00	0.000E+00	0.000E+00	0.596	0.000E+00	70.0	70.0	0.000E+00	70.0	70.0	1.00
6	3 060E+04	0.000E+00	1.00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	3.300E+03	3.300E+03	0.000E+00	3.300E+03	3.300E+03	0.000E+00
7	8 640E+04	0.000E+00	1.00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	50.0	50.0	0.000E+00	50.0	50.0	0.000E+00
8	3 456E+05	0.000E+00	1.00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	50.0	50.0	0.000E+00	50.0	50.0	0.000E+00
9	2 592E+06	0.000E+00	1.00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	50.0	50.0	0.000E+00	50.0	50.0	0.000E+00

----- ENVIRONMENT -----

X/G	Breathing	X/G	Breathing
s/M3	M3/s	s/M3	M3/s
1.000E-03	3.470E-04	1.000E+00	3.470E-04
2.97	1.00	4.200E-05	1.00
2.97	1.00	4.200E-05	1.00
2.97	1.00	4.200E-05	1.00
2.97	1.00	4.200E-05	1.00
1.94	1.00	2.700E-05	1.00
1.94	1.00	2.700E-05	1.00
0.592	1.00	1.540E-05	1.00
0.154	1.00	4.800E-06	1.00

----- CONTROL ROOM -----

X/G	Breathing	Occupancy
s/M3	M3/s	
1.000E-03	3.470E-04	1.000E+00
2.97	1.00	1.00
2.97	1.00	1.00
2.97	1.00	1.00
2.97	1.00	1.00
1.94	1.00	1.00
1.94	1.00	1.00
0.592	1.00	1.00
0.154	1.00	1.00

MULTIPLIERS====>

STEP	TIME
1	9 000E+02
2	4 500E+03
3	7 200E+03
4	1 440E+04
5	2 880E+04
6	3 060E+04
7	8 640E+04
8	3 456E+05
9	2 592E+06

STEP	TIME	Reactor Coolant Syst		3 Steam Generators		AVERAGE RELEASED		CONTROL ROOM	
		CURRENT uCi	INTEGRD uCi-sec	CURRENT uCi	INTEGRD uCi-sec	RELEASED uCi	RELEASE uCi/sec	CURRENT uCi/cc	INTEGRD uCi-sec
I-131	INITIAL	0	0.000E+00	0	0.000E+00	1	1.349E+02	0	0.000E+00
1	0 2500 h	1	223E+09	5	506E+11	1	530E+04	4	249E+00
2	1 2500 h	6	101E+09	1	319E+13	4	738E+04	1	755E+01
3	2 0000 h	9	244E+09	2	139E+13	2	602E+03	3	614E+01
4	4 0000 h	1	939E+10	1	050E+14	1	757E+06	1	220E+02
5	8 0000 h	1	906E+10	2	769E+14	0	0.000E+00	0	0.000E+00
6	8 5000 h	1	901E+10	3	426E+13	0	0.000E+00	0	0.000E+00
7	24 0000 h	1	763E+10	1	022E+15	0	0.000E+00	0	0.000E+00
8	96 0000 h	1	241E+10	3	854E+15	0	0.000E+00	0	0.000E+00
9	720 0000 h	5	924E+08	8	727E+15	0	0.000E+00	0	0.000E+00
I-131	TOTALS			1	403E+16	2	080E+06		
I-132	INITIAL	0	0.000E+00	0	0.000E+00	2	206E+02	2	451E-01
1	0 2500 h	2	184E+09	9	953E+11	2	352E+04	6	532E+00
2	1 2500 h	9	442E+09	2	158E+13	6	345E+04	3	550E+01
3	2 0000 h	1	361E+10	3	133E+13	4	634E+05	3	659E+01
4	4 0000 h	2	104E+10	1	274E+14	9	005E+05	6	254E+01
5	8 0000 h	6	313E+09	1	761E+14	0	0.000E+00	0	0.000E+00
6	8 5000 h	5	427E+09	1	055E+13	0	0.000E+00	0	0.000E+00
7	24 0000 h	4	981E+07	6	396E+13	0	0.000E+00	0	0.000E+00
8	96 0000 h	1	714E-02	3	925E+11	0	0.000E+00	0	0.000E+00
9	720 0000 h	0	0.000E+00	2	039E+02	0	0.000E+00	0	0.000E+00
I-132	TOTALS			4	325E+14	1	251E+06		
I-133	INITIAL	0	0.000E+00	0	0.000E+00	2	745E+02	3	050E-01
1	0 2500 h	2	760E+09	1	244E+12	3	389E+04	9	413E+00
2	1 2500 h	1	356E+10	2	950E+13	1	039E+03	3	847E+01
3	2 0000 h	2	143E+10	4	728E+13	5	530E+03	7	681E+01
4	4 0000 h	4	142E+10	2	271E+14	3	468E+06	2	409E+02
5	8 0000 h	3	615E+10	5	576E+14	0	0.000E+00	0	0.000E+00
6	8 5000 h	3	553E+10	6	451E+13	0	0.000E+00	0	0.000E+00
7	24 0000 h	2	078E+10	1	534E+15	0	0.000E+00	0	0.000E+00
8	96 0000 h	1	720E+07	1	982E+15	0	0.000E+00	0	0.000E+00
9	720 0000 h	7	188E-01	1	789E+14	0	0.000E+00	0	0.000E+00
I-133	TOTALS			4	623E+15	4	159E+06		
I-134	INITIAL	0	0.000E+00	0	0.000E+00	3	031E+02	3	368E-01
1	0 2500 h	3	005E+09	1	397E+12	2	577E+04	7	158E+00
2	1 2500 h	1	051E+10	2	610E+13	5	624E+04	2	084E+01
3	2 0000 h	1	330E+10	3	251E+13	1	638E+05	2	275E+01
4	4 0000 h	1	603E+10	1	081E+14	2	428E+05	1	686E+01
5	8 0000 h	7	070E+08	7	013E+13	0	0.000E+00	0	0.000E+00
6	8 5000 h	4	758E+08	1	051E+12	0	0.000E+00	0	0.000E+00
7	24 0000 h	2	224E+03	2	163E+11	0	0.000E+00	0	0.000E+00
8	96 0000 h	3	862E-22	1	011E+07	0	0.000E+00	0	0.000E+00
9	720 0000 h	0	0.000E+00	1	756E-18	0	0.000E+00	0	0.000E+00
I-134	TOTALS			2	414E+14	4	889E+05		

TRAILS -- Transport of Radioactive Material in Linear Systems. v1.0
 Concurrent iodine spike - LPZ and C.R. Doses

STEP	TIME	Reactor Coolant Syst		3 Steam Generators		AVERAGE RELEASE		CONTROL ROOM	
		CURRENT uCi	INTEGRD uCi-sec	CURRENT uCi	INTEGRD uCi-sec	RELEASED uCi	RELEASE uCi/sec	CURRENT uCi/r/c	INTEGRD uCi-sec
I-135	INITIAL	0.000E+00		0.000E+00					
1	0 2500 h	2.496E+09	1.128E+12	3.983E+05	1.192E+08	2.503E+02	2.781E-01	1.694E-01	3.458E-11
2	1 2500 h	1.184E+10	2.611E+13	9.262E+06	1.409E+10	2.957E+04	8.215E+00	4.678E-01	9.591E-11
3	2 0000 h	1.823E+10	4.071E+13	2.247E+07	4.170E+10	8.753E+04	3.242E+01	5.201E+00	1.062E-09
4	4 5000 h	3.297E+10	1.862E+14	7.828E+07	3.473E+11	4.343E+05	6.035E+01	2.228E+01	4.544E-09
5	8 0000 h	2.163E+10	3.874E+14	1.607E+08	1.833E+12	2.293E+06	1.592E+02	8.335E+01	1.700E-08
6	8 5000 h	2.051E+10	3.792E+13	1.656E+08	2.938E+11	0.000E+00	0.000E+00	2.586E-01	5.278E-11
7	24 0000 h	3.958E+09	5.614E+14	1.121E+08	8.706E+12	0.000E+00	0.000E+00	3.462E-03	7.067E-13
8	96 0000 h	1.897E+06	1.342E+14	2.425E+05	5.481E+12	0.000E+00	0.000E+00	6.883E-12	1.405E-21
9	720 0000 h	3.245E-23	6.435E+10	4.906E-23	9.115E+09	0.000E+00	0.000E+00	0.000E+00	0.000E+00
I-135	TOTALS		1.375E+15		1.673E+13	2.844E+06			
ALL NUCLIDES		5.924E+08		8.957E+08				0.000E+00	0.000E+00
# STEP	9								

IRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Concurrent iodine spike - L2Z and C.R. Doses

PHOTON-SUBMG		BETA-SUBMG		ENVIRONMENT		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL	
DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE
mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
1-131													
0 2500 h	5 40E-07	2 48E-07	2 93E-07	2 91E-03	1 16E-02	4 10E-08	3 25E-07	3 75E-07	2 98E-06	4 39E-03	2 98E-06	4 39E-03	2 98E-06
1 2500 h	6 12E-05	2 81E-05	2 91E-05	3 30E-01	3 30E-01	6 37E-07	9 23E-07	5 82E-06	8 45E-06	6 83E-02	8 45E-06	6 83E-02	9 90E-02
2 0000 h	1 90E-04	2 53E-04	1 16E-04	1 02E+00	1 36E+00	4 33E-06	1 03E-05	3 96E-05	9 45E-05	4 64E-01	9 45E-05	4 64E-01	1 11E+00
4 0000 h	1 04E-03	5 21E-04	4 79E-04	5 61E+00	2 81E+00	6 34E-05	5 17E-05	5 98E-04	4 73E-04	7 02E+00	4 73E-04	7 02E+00	5 55E+00
8 0000 h	7 03E-03	3 23E-03	8 08E-04	3 79E+01	7 47E+00	7 05E-04	2 66E-04	6 45E-03	2 44E-03	7 56E+01	2 44E-03	7 56E+01	2 86E+01
8 5000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	2 32E-05	8 69E-07	2 12E-04	7 95E-05	2 49E+00	7 95E-05	2 49E+00	9 32E-02
24 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	4 60E-06	5 59E-08	4 20E-05	5 12E-07	4 93E-01	5 12E-07	4 93E-01	6 00E-03
96 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	3 16E-07	1 63E-13	2 89E-06	1 49E-12	3 39E-02	1 49E-12	3 39E-02	1 75E-08
720 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	9 22E-13	0 00E+00	8 44E-12	0 00E+00	9 89E-08	0 00E+00	9 89E-08	0 00E+00
TOTALS	8 32E-03	3 83E-03	3 83E-03	4 49E+01	8 04E-04	8 04E-04	0 00E+00	7 35E-03	0 00E+00	8 62E+01	0 00E+00	8 62E+01	0 00E+00

1-132													
0 2500 h	5 31E-06	2 12E-05	1 04E-06	1 72E-04	6 88E-04	3 93E-07	3 08E-06	1 54E-06	1 21E-05	2 53E-04	1 21E-05	2 53E-04	1 99E-03
1 2500 h	5 66E-04	5 66E-04	1 11E-04	1 83E-02	1 83E-02	5 31E-06	7 17E-06	2 08E-05	2 81E-05	3 42E-03	2 81E-05	3 42E-03	4 62E-03
2 0000 h	1 53E-03	2 04E-03	3 01E-04	4 95E-02	6 66E-02	3 21E-05	7 40E-05	1 26E-04	2 90E-04	2 07E-02	2 90E-04	2 07E-02	4 77E-02
4 0000 h	6 34E-03	3 17E-03	1 25E-03	6 24E-02	1 03E-01	3 41E-04	2 38E-04	1 34E-04	9 33E-04	2 20E-01	9 33E-04	2 20E-01	1 54E-01
8 0000 h	2 17E-02	5 42E-03	4 27E-03	1 07E-03	1 76E-01	1 69E-03	5 14E-04	6 62E-03	2 02E-03	1 09E+00	2 02E-03	1 09E+00	3 32E-01
8 5000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	4 37E-05	1 45E-06	1 71E-04	5 67E-06	2 82E-02	5 67E-06	2 82E-02	9 33E-04
24 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	3 05E-06	9 22E-10	1 19E-05	3 61E-09	1 96E-03	3 61E-09	1 96E-03	5 94E-07
96 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	1 94E-09	1 32E-24	7 60E-09	5 15E-24	1 25E-06	5 15E-24	1 25E-06	8 48E-22
720 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	2 77E-24	0 00E+00	1 09E-23	0 00E+00	1 79E-21	0 00E+00	1 79E-21	0 00E+00
TOTALS	3 01E-02	5 93E-03	5 93E-03	9 76E-01	2 12E-03	2 12E-03	0 00E+00	8 29E-03	0 00E+00	1 37E+00	0 00E+00	1 37E+00	0 00E+00

1-133													
0 2500 h	1 75E-06	1 09E-06	4 35E-06	1 60E-03	6 40E-03	1 32E-07	1 05E-06	1 64E-06	1 30E-05	2 41E-03	1 30E-05	2 41E-03	1 91E-02
1 2500 h	2 16E-04	2 16E-04	1 34E-04	1 98E-01	1 98E-01	2 13E-06	3 12E-06	2 64E-05	3 86E-05	3 88E-02	3 86E-05	3 88E-02	5 68E-02
2 0000 h	6 62E-04	8 82E-04	4 11E-04	6 05E-01	8 07E-01	1 49E-05	3 55E-05	1 84E-04	4 40E-04	2 72E-01	4 40E-04	2 72E-01	6 47E-01
4 0000 h	3 52E-03	1 76E-03	2 19E-03	3 22E+00	1 61E+00	2 18E-04	1 79E-04	2 69E-03	2 10E-03	3 97E+00	2 10E-03	3 97E+00	3 09E+00
8 0000 h	2 21E-02	5 52E-03	1 37E-02	2 02E+01	5 05E+00	2 16E-03	7 95E-04	2 66E-02	9 83E-03	3 92E+01	9 83E-03	3 92E+01	1 45E+01
8 5000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	5 90E-05	2 52E-06	8 54E-04	3 16E-05	1 26E+00	3 16E-05	1 26E+00	4 66E-02
24 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	1 19E-05	1 65E-07	1 47E-04	1 28E-06	2 16E-01	1 28E-06	2 16E-01	1 89E-03
96 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	5 02E-07	3 58E-14	6 21E-06	4 41E-13	9 11E-03	4 41E-13	9 11E-03	6 49E-10
720 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	1 72E-13	0 00E+00	2 13E-12	0 00E+00	3 14E-09	0 00E+00	3 14E-09	0 00E+00
TOTALS	2 65E-02	1 65E-02	1 65E-02	2 42E+01	2 42E+01	2 47E-03	0 00E+00	3 06E-02	0 00E+00	4 50E+01	0 00E+00	4 50E+01	0 00E+00

1-134													
0 2500 h	8 36E-06	3 34E-05	1 78E-06	1 10E-04	4 42E-04	5 95E-07	4 55E-06	2 52E-06	1 94E-05	1 56E-04	1 94E-05	1 56E-04	1 20E-03
1 2500 h	7 10E-04	7 10E-04	1 51E-04	9 39E-03	9 39E-03	6 04E-06	7 09E-06	2 56E-05	3 00E-05	1 59E-03	3 00E-05	1 59E-03	1 86E-03
2 0000 h	1 55E-03	2 07E-03	3 30E-04	2 05E-02	2 73E-02	2 89E-05	6 27E-05	1 22E-04	2 66E-04	7 60E-03	2 66E-04	7 60E-03	1 65E-02
4 0000 h	4 52E-03	2 26E-03	9 62E-04	4 81E-04	4 81E-04	1 92E-04	1 1E-04	8 15E-04	4 80E-04	5 06E-02	4 80E-04	5 06E-02	2 98E-02
8 0000 h	6 69E-03	1 67E-03	1 43E-03	3 56E-04	8 85E-02	3 80E-04	8 98E-05	1 61E-03	3 80E-04	1 00E-01	3 80E-04	1 00E-01	2 36E-02
8 5000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	7 32E-06	3 10E-05	3 10E-05	8 38E-07	1 93E-03	8 38E-07	1 93E-03	5 20E-05
24 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	2 05E-07	6 42E-14	8 69E-07	2 72E-13	5 40E-05	2 72E-13	5 40E-05	1 69E-11
96 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	6 66E-14	0 00E+00	2 82E-13	0 00E+00	1 75E-11	0 00E+00	1 75E-11	0 00E+00
720 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00
TOTALS	1 35E-02	2 87E-03	2 87E-03	1 78E-01	6 06E+00	6 16E-04	0 00E+00	0 00E+00	0 00E+00	1 62E-01	0 00E+00	1 62E-01	0 00E+00

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Concurrent Iodine Spike - LPZ and C.R. Doses

I-135	PHOTON-SUBMG		BETA-SUBMG		ENVIRONMENT		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		CENTROROOM		THYROID-INHAL	
	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr
0 2500 h	4 14E-06	1 66E-05	8 91E-07	3 57E-06	4 52E-04	1 81E-03	3 12E-07	2 46E-06	1 33E-06	1 06E-05	6 77E-04	5 36E-03				
1 2500 h	4 89E-04	4 89E-04	1 05E-04	1 05E-04	5 34E-02	5 34E-02	4 77E-06	6 83E-06	2 05E-05	2 93E-05	1 04E-02	1 49E-02				
2 0000 h	1 45E-03	1 93E-03	3 12E-04	4 16E-04	1 58E-01	2 11E-01	3 20E-05	7 56E-05	1 37E-04	3 24E-04	6 97E-02	1 64E-01				
4 0000 h	7 19E-03	3 59E-03	1 59E-03	7 74E-04	7 85E-01	3 93E-01	4 28E-04	3 24E-04	1 83E-03	1 39E-03	9 30E-01	7 04E-01				
8 0000 h	3 79E-02	9 48E-03	8 17E-03	2 04E-03	4 14E+00	1 04E+00	3 47E-03	1 21E-03	1 49E-02	5 19E-03	7 54E+00	2 63E+00				
8 5000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	1 05E-04	3 76E-06	4 48E-04	1 61E-05	2 27E-01	8 18E-03				
24 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	1 33E-05	5 03E-08	5 71E-05	2 16E-07	2 90E-02	1 07E-04				
96 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	1 81E-07	1 00E-16	7 75E-07	4 29E-16	3 93E-04	2 18E-13				
720 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	3 60E-16	0 00E+00	1 54E-15	0 00E+00	7 82E-13	0 00E+00				
TOTALS	4 70E-02		1 01E-02		5 14E+00		4 05E-03		1 74E-02		8 81E+00					

ALL NUCLIDES	PHOTON-SUBMG		BETA-SUBMG		ENVIRONMENT		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		CENTROROOM		THYROID-INHAL	
	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr
0 2500 h	2 01E-05	8 04E-05	5 05E-06	2 02E-05	5 24E-03	2 10E-02	1 47E-06	1 15E-05	7 41E-06	5 80E-05	7 89E-03	6 26E-02				
1 2500 h	2 04E-03	2 04E-03	5 30E-04	5 30E-04	6 09E-01	6 09E-01	1 89E-05	2 51E-05	9 91E-05	1 34E-04	1 23E-01	1 77E-01				
2 0000 h	5 38E-03	7 17E-03	1 44E-03	1 92E-03	1 86E+00	2 47E+00	1 12E-04	2 58E-04	6 10E-04	1 41E-03	8 34E-01	1 98E+00				
4 0000 h	2 26E-02	1 13E-02	6 43E-03	3 21E-03	9 89E+00	4 94E+00	1 25E-03	8 97E-04	7 28E-03	5 38E-03	1 22E+01	9 53E+00				
8 0000 h	9 54E-02	2 38E-02	3 08E-02	7 71E-03	6 30E+01	1 58E+01	8 40E-03	2 88E-03	5 62E-02	1 99E-02	1 24E+02	4 60E+01				
8 5000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	2 48E-04	8 83E-06	1 72E-03	6 22E-05	4 00E+00	1 49E-01				
24 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	3 31E-05	2 11E-07	2 59E-04	2 01E-06	7 40E-01	8 00E-03				
96 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	1 00E-06	1 99E-13	9 88E-06	1 94E-12	4 34E-02	1 82E-08				
720 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	1 10E-12	0 00E+00	1 06E-11	0 00E+00	1 02E-07	0 00E+00				
TOTALS	1 23E-01		3 92E-02		7 54E+01		1 01E-02		6 62E-02		1 42E+02					

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Initial steam release I2 & N6 -- LPZ and CR Doses

COMP: NOT USED THIS CASE COMP: 3 S/G initial steam rel COMP: Control Room
 VOLUME: 1.730E+05 Cu Ft

INITIAL:	0.000E+00 KR-83m	4.280E-05 KR-83m	0.000E+00 KR-83m
	0.000E+00 KR-85m	2.080E-04 KR-85m	0.000E+00 KR-85m
	0.000E+00 KR-87	1.100E-03 KR-85	0.000E+00 KR-85
	0.000E+00 KR-88	1.200E-04 KR-87	0.000E+00 KR-87
	0.000E+00 KR-89	3.180E-04 KR-88	0.000E+00 KR-88
	0.000E+00 KR-90	1.000E-05 KR-89	0.000E+00 KR-89
	0.000E+00 XE-131M	0.000E+00 KR-90	0.000E+00 KR-90
	0.000E+00 XE-133M	1.070E-05 XE-131M	0.000E+00 XE-131M
	0.000E+00 XE-133	3.070E-04 XE-133M	0.000E+00 XE-133M
	0.000E+00 XE-135M	2.610E-03 XE-133	0.000E+00 XE-133
	0.000E+00 XE-135	1.080E-04 XE-135M	0.000E+00 XE-135M
	0.000E+00 XE-137	3.200E-04 XE-135	0.000E+00 XE-135
	0.000E+00 XE-138	1.530E-05 XE-137	0.000E+00 XE-137
	0.000E+00 I-131	6.710E-05 XE-138	0.000E+00 XE-138
	0.000E+00 I-132	6.280E-03 I-131	0.000E+00 I-131
	0.000E+00 I-133	1.120E-03 I-132	0.000E+00 I-132
	0.000E+00 I-134	8.190E-03 I-133	0.000E+00 I-133
	0.000E+00 I-135	1.960E-04 I-134	0.000E+00 I-134
ACT MULY (to uCi):	1.000E+00	3.000E-03 I-135	0.000E+00 I-135
		1.000E+06	1.000E+00

PRODUCTION, uCi/s:	0.000E+00 KR-83m	0.000E+00 KR-83m	0.000E+00 KR-83m
	0.000E+00 KR-85m	0.000E+00 KR-85m	0.000E+00 KR-85m
	0.000E+00 KR-87	0.000E+00 KR-85	0.000E+00 KR-85
	0.000E+00 KR-88	0.000E+00 KR-87	0.000E+00 KR-87
	0.000E+00 KR-89	0.000E+00 KR-88	0.000E+00 KR-88
	0.000E+00 KR-90	0.000E+00 KR-89	0.000E+00 KR-89
	0.000E+00 XE-131M	0.000E+00 KR-90	0.000E+00 KR-90
	0.000E+00 XE-133M	0.000E+00 XE-131M	0.000E+00 XE-131M
	0.000E+00 XE-133	0.000E+00 XE-133M	0.000E+00 XE-133M
	0.000E+00 XE-135M	0.000E+00 XE-133	0.000E+00 XE-133
	0.000E+00 XE-135	0.000E+00 XE-135M	0.000E+00 XE-135M
	0.000E+00 XE-137	0.000E+00 XE-135	0.000E+00 XE-135
	0.000E+00 XE-138	0.000E+00 XE-137	0.000E+00 XE-137
	0.000E+00 I-131	0.000E+00 XE-138	0.000E+00 XE-138
	0.000E+00 I-132	0.000E+00 I-131	0.000E+00 I-131
	0.000E+00 I-133	0.000E+00 I-132	0.000E+00 I-132
	0.000E+00 I-134	0.000E+00 I-133	0.000E+00 I-133
	0.000E+00 I-135	0.000E+00 I-134	0.000E+00 I-134
		0.000E+00 I-135	0.000E+00 I-135

REMOVAL: 0.000E+00 1/sec 1.295E-01 1/sec 1.000E+01 cfm
 NSJC 1-14 REL FR: 0.000E+00 INTAKE REDUCT: 0.000E+00
 NUC 15-20 REL FR: 0.000E+00 INTAKE FILTER: 9.360E-01

CASE 4

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Initial steam release I2 & N2 -- LPZ and CR Doses

MULTIPLIERS====>

STEP	TIME	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF
1	9 000E+02	0 000E+00	1 00	0 000E+00	0 000E+00	1 00	0 000E+00	50 0	50 0	0 000E+00	50 0	50 0	0 000E+00
2	4 500E+03	0 000E+00	1 00	0 000E+00	0 000E+00	1 00	0 000E+00	1 00	70 0	0 000E+00	1 00	70 0	0 000E+00
3	7 200E+03	0 000E+00	1 00	0 000E+00	0 000E+00	1 00	0 000E+00	70 0	70 0	0 000E+00	70 0	70 0	1 00
4	1 440E+04	0 000E+00	1 00	0 000E+00	0 000E+00	1 00	0 000E+00	70 0	70 0	0 000E+00	70 0	70 0	1 00
5	2 880E+04	0 000E+00	1 00	0 000E+00	0 000E+00	1 00	0 000E+00	70 0	70 0	0 000E+00	70 0	70 0	1 00
6	5 060E+04	0 000E+00	1 00	0 000E+00	0 000E+00	1 00	0 000E+00	3 300E+03	3 300E+03	0 000E+00	3 300E+03	3 300E+03	0 000E+00
7	8 640E+04	0 000E+00	1 00	0 000E+00	0 000E+00	1 00	0 000E+00	50 0	50 0	0 000E+00	50 0	50 0	0 000E+00
8	3 456E+05	0 000E+00	1 00	0 000E+00	0 000E+00	1 00	0 000E+00	50 0	50 0	0 000E+00	50 0	50 0	0 000E+00
9	2 592E+06	0 000E+00	1 00	0 000E+00	0 000E+00	1 00	0 000E+00	50 0	50 0	0 000E+00	50 0	50 0	0 000E+00

----- CONTROL ROOM -----

X/G	Breathing	Occupancy
s/M3	M3/s	
1 000E-03	3 470E-04	1 000E+00
2 97	1 00	1 00
2 97	1 00	1 00
2 97	1 00	1 00
2 97	1 00	1 00
2 97	1 00	1 00
1 94	1 00	1 00
1 94	1 00	1 00
0 592	1 00	1 00
0 154	1 00	1 00

----- ENVIRONMENT -----

X/G	Breathing
s/M3	M3/s
1 000E+00	3 470E-04
4 200E-05	1 00
4 200E-05	1 00
4 200E-05	1 00
4 200E-05	1 00
4 200E-05	1 00
2 700E-05	1 00
2 700E-05	1 00
1 540E-05	1 00
6 800E-06	1 00

MULTIPLIERS====>

STEP	TIME
1	9 000E+02
2	4 500E+03
3	7 200E+03
4	1 440E+04
5	2 880E+04
6	5 060E+04
7	8 640E+04
8	3 456E+05
9	2 592E+06

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Initial steam release I2 & NG -- LPZ and CR Doses

STEP	TIME	NOT USED THIS CASE		3 S/G initial steam		AVERAGE		CURRENT		CONTROL ROOM	
		CURRENT	INTEGRD	CURRENT	INTEGRD	RELEASED	RELEASE	uCi	uCi/cc	CURRENT	INTEGRD
		uCi	uCi-sec	uCi	uCi-sec	uCi	uCi/sec	uCi	uCi/cc	uCi-sec	uCi-sec
KR-83m INITIAL											
1	0 2500 h	0 000E+00	0 000E+00	4 280E+01	3 328E+02	4 276E+01	4 752E-02	0 000E+00	5 715E-12	1 289E+01	
2	1 2500 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	2 800E-02	3 070E-12	7 506E+01	
3	2 0000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	9 450E-03	1 926E-12	3 245E+01	
4	4 0000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	2 700E-03	5 570E-13	3 888E+01	
5	8 0000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	2 260E-04	4 626E-14	1 440E+01	
6	8 5000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	6 100E-10	2 404E-16	5 981E-02	
7	24 0000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	6 400E-28	1 307E-37	7 679E-07	
8	96 0000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	4 175E-24	
9	720 0000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	4 175E-24	
KR-83m TOTALS											
		0 000E+00	0 000E+00	4 280E+01	3 328E+02	4 276E+01	4 752E-02	0 000E+00	0 000E+00	4 175E-24	1 738E+02
KR-85m INITIAL											
1	0 2500 h	0 000E+00	0 000E+00	2 080E+02	1 618E+03	2 079E+02	2 310E-01	0 000E+00	2 506E-11	6 382E+01	
2	1 2500 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	9 402E-02	1 919E-11	4 156E+02	
3	2 0000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	6 978E-02	1 428E-11	2 195E+02	
4	4 0000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	3 151E-02	6 433E-12	3 466E+02	
5	8 0000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	6 426E-03	1 312E-12	2 272E+02	
6	8 5000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	1 946E-05	3 972E-15	1 988E+00	
7	24 0000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	1 203E-07	2 455E-17	2 121E-01	
8	96 0000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	6 400E-18	1 347E-27	1 320E-03	
9	720 0000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	7 241E-14	
KR-85m TOTALS											
		0 000E+00	0 000E+00	2 080E+02	1 618E+03	2 079E+02	2 310E-01	0 000E+00	0 000E+00	7 241E-14	1 275E+03
KR-85 INITIAL											
1	0 2500 h	0 000E+00	0 000E+00	1 100E+03	8 560E+03	1 100E+03	1 222E+00	0 000E+00	1 540E-10	3 420E+02	
2	1 2500 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	5 918E-01	1 208E-10	2 411E+03	
3	2 0000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	4 933E-01	1 007E-10	1 461E+03	
4	4 0000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	3 036E-01	6 196E-11	2 814E+03	
5	8 0000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	1 149E-01	2 346E-11	2 797E+03	
6	8 5000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	3 760E-04	7 676E-14	3 604E+01	
7	24 0000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	2 558E-05	5 221E-15	7 275E+00	
8	96 0000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	9 665E-11	1 973E-20	5 309E-01	
9	720 0000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	2 006E-06	
KR-85 TOTALS											
		0 000E+00	0 000E+00	1 100E+03	8 560E+03	1 100E+03	1 222E+00	0 000E+00	0 000E+00	2 006E-06	9 869E+03
KR-87 INITIAL											
1	0 2500 h	0 000E+00	0 000E+00	1 200E+02	9 320E+02	1 199E+02	1 332E-01	0 000E+00	1 570E-11	3 564E+01	
2	1 2500 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	3 497E-02	7 139E-12	1 915E+02	
3	2 0000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	1 937E-02	3 954E-12	7 130E+01	
4	4 0000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	4 007E-03	8 180E-13	7 020E+01	
5	8 0000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	1 715E-04	3 501E-14	1 753E+01	
6	8 5000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	4 272E-07	8 721E-17	5 136E-02	
7	24 0000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	6 228E-12	1 271E-21	2 141E-03	
8	96 0000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	2 133E-34	0 000E+00	3 121E-08	
9	720 0000 h	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	0 000E+00	1 069E-30	
KR-87 TOTALS											
		0 000E+00	0 000E+00	1 200E+02	9 320E+02	1 199E+02	1 332E-01	0 000E+00	0 000E+00	1 069E-30	3 863E+02

STEP	TIME	NOT USED THIS CASE		3 S/G initial steam		AVERAGE		CONTROL ROOM	
		CURRENT uCi	INTEGRD uCi-sec	CURRENT uCi	INTEGRD uCi-sec	RELEASED uCi	RELEASE uCi/sec	CURRENT uCi/cc	INTEGRD uCi-sec
KR-88	INITIAL	0	0	3	180E+02	3	178E+02	3	531E-01
1	0 2500 h	0	0	0	0	0	0	2	115E-01
2	1 2500 h	0	0	0	0	0	0	1	300E-01
3	2 0000 h	0	0	0	0	0	0	9	023E-02
4	4 0000 h	0	0	0	0	0	0	3	408E-02
5	8 0000 h	0	0	0	0	0	0	4	861E-03
6	8 5000 h	0	0	0	0	0	0	1	407E-05
7	24 0000 h	0	0	0	0	0	0	2	178E-08
8	96 0000 h	0	0	0	0	0	0	1	921E-21
9	720 0000 h	0	0	0	0	0	0	0	0
KR-88	TOTALS	0	0	3	178E+02	3	178E+02	0	0
KR-89	INITIAL	0	0	1	000E+01	9	723E+00	0	0
1	0 2500 h	0	0	0	0	0	0	1	971E-03
2	1 2500 h	0	0	0	0	0	0	2	974E-09
3	2 0000 h	0	0	0	0	0	0	1	280E-13
4	4 0000 h	0	0	0	0	0	0	2	913E-25
5	8 0000 h	0	0	0	0	0	0	0	0
6	8 5000 h	0	0	0	0	0	0	0	0
7	24 0000 h	0	0	0	0	0	0	0	0
8	96 0000 h	0	0	0	0	0	0	0	0
9	720 0000 h	0	0	0	0	0	0	0	0
KR-89	TOTALS	0	0	1	000E+01	9	723E+00	0	0
XE-131M	INITIAL	0	0	1	070E+01	1	070E+01	0	0
1	0 2500 h	0	0	0	0	0	0	7	337E-03
2	1 2500 h	0	0	0	0	0	0	5	741E-03
3	2 0000 h	0	0	0	0	0	0	4	777E-03
4	4 0000 h	0	0	0	0	0	0	2	925E-03
5	8 0000 h	0	0	0	0	0	0	1	097E-03
6	8 5000 h	0	0	0	0	0	0	3	584E-06
7	24 0000 h	0	0	0	0	0	0	2	348E-07
8	96 0000 h	0	0	0	0	0	0	7	446E-13
9	720 0000 h	0	0	0	0	0	0	0	0
XE-131M	TOTALS	0	0	1	070E+01	1	070E+01	0	0
XE-133M	INITIAL	0	0	3	070E+02	3	070E+02	0	0
1	0 2500 h	0	0	0	0	0	0	2	102E-01
2	1 2500 h	0	0	0	0	0	0	1	627E-01
3	2 0000 h	0	0	0	0	0	0	1	343E-01
4	4 0000 h	0	0	0	0	0	0	8	050E-02
5	8 0000 h	0	0	0	0	0	0	2	892E-02
6	8 5000 h	0	0	0	0	0	0	9	398E-05
7	24 0000 h	0	0	0	0	0	0	5	211E-06
8	96 0000 h	0	0	0	0	0	0	7	624E-12
9	720 0000 h	0	0	0	0	0	0	0	0
XE-133M	TOTALS	0	0	3	070E+02	3	070E+02	0	0

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
Initial steam release I2 & NG -- LPZ and CR Doses

STEP TIME	NOT USED THIS CASE			3 S/G initial steam			CONTROL ROOM		
	CURRENT uCi	INTEGRD uCi-sec	INTEGRD uCi-sec	CURRENT uCi	INTEGRD uCi-sec	INTEGRD uCi-sec	CURRENT uCi/cc	INTEGRD uCi-sec	INTEGRD uCi-sec
XE-133 INITIAL	0.000E+00	0.000E+00	2.610E+03	2.610E+03	2.900E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00
1 0 2500 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	1.789E+00	3.652E-10	8.110E+02	0.000E+00
2 1 2500 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	1.396E+00	2.849E-10	5.703E+03	0.000E+00
3 2 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	1.158E+00	2.365E-10	3.438E+03	0.000E+00
4 4 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	7.051E-01	1.439E-10	6.574E+03	0.000E+00
5 8 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	2.612E-01	5.331E-11	5.436E+03	0.000E+00
6 8 5000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	8.520E-04	1.735E-13	8.184E+01	0.000E+00
7 24 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	1.322E-05	1.086E-14	1.607E+01	0.000E+00
8 96 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	1.553E-10	2.763E-20	1.071E+00	0.000E+00
9 720 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	2.723E-06	0.000E+00
XE-133 TOTALS	0.000E+00	0.000E+00	2.610E+03	2.610E+03	2.900E+00	0.000E+00	0.000E+00	2.306E+04	0.000E+00
XE-135M INITIAL	0.000E+00	0.000E+00	1.080E+02	1.074E+02	1.193E-01	0.000E+00	0.000E+00	0.000E+00	0.000E+00
1 0 2500 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	5.364E-02	1.095E-11	2.701E+01	0.000E+00
2 1 2500 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	2.806E-03	5.729E-13	6.202E+01	0.000E+00
3 2 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	3.070E-04	6.267E-14	3.050E+01	0.000E+00
4 4 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	8.405E-07	1.716E-16	3.736E-01	0.000E+00
5 8 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	6.299E-12	1.286E-21	1.026E-03	0.000E+00
6 8 5000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	5.322E-15	1.056E-24	1.601E-09	0.000E+00
7 24 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	2.151E-34	0.000E+00	6.650E-12	0.000E+00
8 96 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	2.688E-31	0.000E+00
9 720 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00
XE-135M TOTALS	0.000E+00	0.000E+00	1.074E+02	1.074E+02	1.193E-01	0.000E+00	0.000E+00	9.246E+01	0.000E+00
XE-135 INITIAL	0.000E+00	0.000E+00	3.199E+02	3.199E+02	3.535E-01	0.000E+00	0.000E+00	0.000E+00	0.000E+00
1 0 2500 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	2.174E-01	4.437E-11	9.884E+01	0.000E+00
2 1 2500 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	1.580E-01	3.226E-11	6.701E+02	0.000E+00
3 2 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	1.244E-01	2.540E-11	3.795E+02	0.000E+00
4 4 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	6.575E-02	1.342E-11	6.623E+02	0.000E+00
5 8 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	1.836E-02	3.748E-12	5.350E+02	0.000E+00
6 8 5000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	5.783E-05	1.180E-14	5.720E+00	0.000E+00
7 24 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	1.209E-06	4.659E-16	8.169E-01	0.000E+00
8 96 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	1.907E-14	3.893E-24	1.745E-02	0.000E+00
9 720 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	2.752E-10	0.000E+00
XE-135 TOTALS	0.000E+00	0.000E+00	3.199E+02	3.199E+02	3.535E-01	0.000E+00	0.000E+00	2.352E+03	0.000E+00
XE-137 INITIAL	0.000E+00	0.000E+00	1.593E+01	1.593E+01	1.770E-02	0.000E+00	0.000E+00	0.000E+00	0.000E+00
1 0 2500 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	3.791E-03	7.738E-13	2.406E+00	0.000E+00
2 1 2500 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	5.726E-08	1.169E-17	1.229E+00	0.000E+00
3 2 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	1.388E-11	2.832E-21	1.857E-05	0.000E+00
4 4 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	3.167E-21	6.464E-31	4.500E-09	0.000E+00
5 8 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	1.027E-18	0.000E+00
6 8 5000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00
7 24 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00
8 96 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00
9 720 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00
XE-137 TOTALS	0.000E+00	0.000E+00	1.593E+01	1.593E+01	1.770E-02	0.000E+00	0.000E+00	3.635E+00	0.000E+00

STEP TIME	NOT USED THIS CASE		3 S/G initial steam		AVERAGE		CONTROL ROOM	
	CURRENT	INTEGRD	CURRENT	INTEGRD	RELEASED	RELEASE	CURRENT	INTEGRD
	uCi	uCi-sec	uCi	uCi-sec	uCi	uCi/sec	uCi/cc	uCi-sec
1-131 INITIAL	0	0	6	710E+01	6	668E+01	0	0
1 0 2500 h	0	0	0	0	0	0	3	246E-02
2 1 2500 h	0	0	0	0	0	0	1	342E-03
3 2 0000 h	0	0	0	0	0	0	1	230E-04
4 4 0000 h	0	0	0	0	0	0	2	101E-07
5 8 0000 h	0	0	0	0	0	0	6	130E-13
6 8 5000 h	0	0	0	0	0	0	4	603E-16
7 24 0000 h	0	0	0	0	0	0	4	812E-37
8 96 0000 h	0	0	0	0	0	0	0	0
9 720 0000 h	0	0	0	0	0	0	0	0
1-131 TOTALS	0	0	6	710E+01	6	668E+01	0	0
1-131 INITIAL	0	0	6	280E+03	6	280E+03	0	0
1 0 2500 h	0	0	0	0	0	0	4	305E+00
2 1 2500 h	0	0	0	0	0	0	3	365E+00
3 2 0000 h	0	0	0	0	0	0	2	797E+00
4 4 0000 h	0	0	0	0	0	0	1	709E+00
5 8 0000 h	0	0	0	0	0	0	6	380E-01
6 8 5000 h	0	0	0	0	0	0	2	083E-03
7 24 0000 h	0	0	0	0	0	0	1	340E-04
8 96 0000 h	0	0	0	0	0	0	3	913E-10
9 720 0000 h	0	0	0	0	0	0	0	0
1-131 TOTALS	0	0	6	280E+03	6	280E+03	0	0
1-132 INITIAL	0	0	1	120E+03	1	119E+03	0	0
1 0 2500 h	0	0	0	0	0	0	7	397E-01
2 1 2500 h	0	0	0	0	0	0	4	293E-01
3 2 0000 h	0	0	0	0	0	0	2	854E-01
4 4 0000 h	0	0	0	0	0	0	9	613E-02
5 8 0000 h	0	0	0	0	0	0	1	090E-02
6 8 5000 h	0	0	0	0	0	0	3	068E-05
7 24 0000 h	0	0	0	0	0	0	1	954E-08
8 96 0000 h	0	0	0	0	0	0	2	789E-23
9 720 0000 h	0	0	0	0	0	0	0	0
1-132 TOTALS	0	0	1	120E+03	1	119E+03	0	0
1-133 INITIAL	0	0	8	190E+03	8	189E+03	0	0
1 0 2500 h	0	0	0	0	0	0	5	594E+00
2 1 2500 h	0	0	0	0	0	0	4	244E+00
3 2 0000 h	0	0	0	0	0	0	3	450E+00
4 4 0000 h	0	0	0	0	0	0	1	986E+00
5 8 0000 h	0	0	0	0	0	0	6	583E-01
6 8 5000 h	0	0	0	0	0	0	2	118E-03
7 24 0000 h	0	0	0	0	0	0	8	595E-05
8 96 0000 h	0	0	0	0	0	0	2	950E-11
9 720 0000 h	0	0	0	0	0	0	0	0
1-133 TOTALS	0	0	8	190E+03	8	189E+03	0	0

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Initial steam release I2 & N6 -- LPZ and CR Doses

STEP	TIME	NOT USED THIS CASE		3 S/G initial steam		AVERAGE		CONTROL ROOM			
		CURRENT uCi	INTEGRD uCi-sec	CURRENT uCi	INTEGRD uCi-sec	RELEASED uCi	RELEASE uCi/sec	CURRENT uCi	CURRENT uCi/sec	INTEGRD uCi-sec	
I-134	INITIAL	0	0.000E+00	1	960E+02	1	957E+03	2	174E-01	0	0.000E+00
1	0 2500 h	0	0.000E+00	0	0.000E+00	0	0.000E+00	0	0.000E+00	1	217E-01
2	1 2500 h	0	0.000E+00	0	0.000E+00	0	0.000E+00	0	0.000E+00	4	336E-02
3	2 0000 h	0	0.000E+00	0	0.000E+00	0	0.000E+00	0	0.000E+00	1	902E-02
4	4 0000 h	0	0.000E+00	0	0.000E+00	0	0.000E+00	0	0.000E+00	2	527E-03
5	8 0000 h	0	0.000E+00	0	0.000E+00	0	0.000E+00	0	0.000E+00	4	054E-05
6	8 5000 h	0	0.000E+00	0	0.000E+00	0	0.000E+00	0	0.000E+00	8	932E-08
7	24 0000 h	0	0.000E+00	0	0.000E+00	0	0.000E+00	0	0.000E+00	2	897E-14
8	96 0000 h	0	0.000E+00	0	0.000E+00	0	0.000E+00	0	0.000E+00	0	0.000E+00
9	720 0000 h	0	0.000E+00	0	0.000E+00	0	0.000E+00	0	0.000E+00	0	0.000E+00
I-134	TOTALS	0	0.000E+00	1	960E+02	1	957E+03	2	174E-01	0	0.000E+00
I-135	INITIAL	0	0.000E+00	3	0.000E+03	2	999E+03	3	333E+00	0	0.000E+00
1	0 2500 h	0	0.000E+00	0	0.000E+00	0	0.000E+00	0	0.000E+00	2	031E+00
2	1 2500 h	0	0.000E+00	0	0.000E+00	0	0.000E+00	0	0.000E+00	1	434E+00
3	2 0000 h	0	0.000E+00	0	0.000E+00	0	0.000E+00	0	0.000E+00	1	105E+00
4	4 0000 h	0	0.000E+00	0	0.000E+00	0	0.000E+00	0	0.000E+00	5	514E-01
5	8 0000 h	0	0.000E+00	0	0.000E+00	0	0.000E+00	0	0.000E+00	1	373E-01
6	8 5000 h	0	0.000E+00	0	0.000E+00	0	0.000E+00	0	0.000E+00	4	261E-04
7	24 0000 h	0	0.000E+00	0	0.000E+00	0	0.000E+00	0	0.000E+00	5	705E-06
8	96 0000 h	0	0.000E+00	0	0.000E+00	0	0.000E+00	0	0.000E+00	1	134E-14
9	720 0000 h	0	0.000E+00	0	0.000E+00	0	0.000E+00	0	0.000E+00	0	0.000E+00
I-135	TOTALS	0	0.000E+00	3	0.000E+03	2	999E+03	3	333E+00	0	0.000E+00
ALL NUCLIDES		0	0.000E+00	0	0.000E+00	0	0.000E+00	0	0.000E+00	0	0.000E+00
# STEP											

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
Initial steam release I2 & NG -- LPZ and CR Doses

		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		DOSE RATE		DOSE		R O D M		THYROID-INHAL	
		DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE
		mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
KR-B3m															
0	2500	h	1.17E-09	4.67E-09	6.31E-08	0.00E+00	0.00E+00	8.59E-11	6.72E-10	2.31E-08	1.81E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00
1	2500	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.01E-10	3.61E-10	1.35E-07	9.71E-08	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2	0000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.16E-10	2.26E-10	5.82E-08	6.09E-08	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4	0000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.59E-10	6.53E-11	6.97E-08	1.76E-08	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8	0000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.64E-11	5.44E-12	2.59E-08	1.46E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00
24	5000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.59E-13	1.47E-14	1.23E-10	3.96E-12	0.00E+00	0.00E+00	0.00E+00	0.00E+00
96	0000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.67E-14	2.83E-18	7.17E-12	7.60E-16	0.00E+00	0.00E+00	0.00E+00	0.00E+00
720	0000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.12E-18	1.54E-35	4.38E-15	4.13E-33	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS			1.17E-09	4.67E-09	6.31E-08	0.00E+00	0.00E+00	2.78E-35	0.00E+00	7.49E-33	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

KR-B5m															
0	2500	h	3.44E-07	1.38E-06	2.05E-06	0.00E+00	0.00E+00	2.58E-08	2.04E-07	7.65E-07	6.04E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00
1	2500	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.68E-07	1.37E-07	4.98E-06	4.06E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2	0000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.88E-08	1.02E-07	2.63E-06	3.01E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4	0000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.40E-07	4.59E-08	4.15E-06	1.36E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8	0000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.19E-08	9.36E-09	2.72E-06	2.77E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8	5000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.04E-10	2.83E-11	2.38E-08	8.40E-10	0.00E+00	0.00E+00	0.00E+00	0.00E+00
24	0000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.58E-11	1.75E-13	2.54E-09	5.19E-12	0.00E+00	0.00E+00	0.00E+00	0.00E+00
96	0000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.34E-13	9.61E-24	1.58E-11	2.85E-22	0.00E+00	0.00E+00	0.00E+00	0.00E+00
720	0000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.93E-23	0.00E+00	8.68E-22	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS			3.44E-07	1.38E-06	2.05E-06	0.00E+00	0.00E+00	5.16E-07	0.00E+00	1.53E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

KR-B5															
0	2500	h	2.54E-08	1.02E-07	2.67E-06	1.07E-05	0.00E+00	1.92E-09	1.53E-08	4.03E-06	3.20E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00
1	2500	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.36E-08	1.20E-08	2.84E-05	2.51E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2	0000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.24E-09	1.00E-08	1.72E-05	2.09E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4	0000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.59E-08	6.17E-09	3.31E-05	1.29E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8	0000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.58E-08	2.33E-09	3.29E-05	4.88E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8	5000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.03E-10	7.64E-12	4.25E-07	1.60E-08	0.00E+00	0.00E+00	0.00E+00	0.00E+00
24	0000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.11E-11	5.19E-13	8.57E-09	1.09E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00
96	0000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.00E-12	1.96E-18	6.26E-18	4.10E-15	0.00E+00	0.00E+00	0.00E+00	0.00E+00
720	0000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.13E-17	0.00E+00	2.36E-14	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS			2.54E-08	1.02E-07	2.67E-06	1.07E-05	0.00E+00	5.57E-08	0.00E+00	1.16E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

KR-B7															
0	2500	h	9.98E-07	3.99E-06	1.53E-06	6.13E-06	0.00E+00	7.25E-08	5.63E-07	2.21E-06	1.72E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00
1	2500	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.90E-07	2.56E-07	1.19E-05	7.82E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2	0000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.45E-07	1.42E-07	4.43E-06	4.33E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4	0000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.43E-07	2.93E-08	4.36E-06	8.96E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8	0000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.57E-08	3.26E-09	1.09E-06	3.84E-08	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8	5000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.04E-10	3.13E-12	3.19E-09	9.56E-11	0.00E+00	0.00E+00	0.00E+00	0.00E+00
24	0000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.35E-12	4.56E-17	1.33E-10	1.39E-15	0.00E+00	0.00E+00	0.00E+00	0.00E+00
96	0000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.35E-17	0.00E+00	1.94E-15	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
720	0000	h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.64E-38	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS			9.98E-07	3.99E-06	1.53E-06	6.13E-06	0.00E+00	7.86E-07	0.00E+00	2.40E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
Initial steam release 12 & NG -- LPZ and CR Doses

	PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL	
	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr
MR-88												
0 2500 h	6.52E-06	2.61E-05	1.12E-06	4.48E-06	0.00E+00	0.00E+00	4.85E-07	3.82E-06	1.66E-06	1.30E-05	0.00E+00	0.00E+00
1 2500 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.02E-06	2.35E-06	1.03E-05	8.02E-06	0.00E+00	0.00E+00
2 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.47E-06	1.63E-06	5.03E-06	5.56E-06	0.00E+00	0.00E+00
4 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.08E-06	6.15E-07	7.11E-06	2.10E-06	0.00E+00	0.00E+00
8 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.08E-06	8.77E-08	3.70E-06	3.00E-07	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.48E-09	2.54E-10	2.56E-08	8.68E-10	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.08E-10	3.93E-13	2.07E-09	1.34E-12	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.42E-13	3.47E-26	3.22E-12	1.18E-25	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.30E-26	0.00E+00	2.84E-25	0.00E+00	0.00E+00	0.00E+00
TOTALS	6.52E-06	1.12E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.15E-06	0.00E+00	2.79E-05	0.00E+00	0.00E+00	0.00E+00

MR-89												
0 2500 h	1.87E-07	7.49E-07	1.25E-07	5.12E-07	0.00E+00	0.00E+00	6.15E-09	3.34E-08	8.36E-08	4.54E-07	0.00E+00	0.00E+00
1 2500 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.49E-09	5.04E-14	3.38E-08	6.85E-13	0.00E+00	0.00E+00
2 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.76E-15	2.17E-18	5.11E-14	2.95E-17	0.00E+00	0.00E+00
4 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.62E-19	4.93E-30	2.20E-18	6.71E-29	0.00E+00	0.00E+00
8 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.68E-31	0.00E+00	5.00E-30	0.00E+00	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS	1.87E-07	1.28E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.64E-09	0.00E+00	1.17E-07	0.00E+00	0.00E+00	0.00E+00

XE-131M												
0 2500 h	2.26E-09	9.03E-09	1.47E-08	5.88E-08	0.00E+00	0.00E+00	1.71E-10	1.36E-09	2.22E-08	1.76E-07	0.00E+00	0.00E+00
1 2500 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.21E-09	1.07E-09	1.56E-07	1.38E-07	0.00E+00	0.00E+00
2 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.30E-10	8.86E-10	9.43E-08	1.15E-07	0.00E+00	0.00E+00
4 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.40E-09	5.43E-10	1.81E-07	7.03E-08	0.00E+00	0.00E+00
8 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.38E-09	2.04E-10	1.79E-07	2.64E-08	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.77E-11	6.65E-13	2.29E-09	8.61E-11	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.53E-12	4.36E-14	4.58E-10	5.64E-12	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.48E-13	1.38E-19	3.21E-11	1.79E-17	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.86E-19	0.00E+00	1.02E-16	0.00E+00	0.00E+00	0.00E+00
TOTALS	2.26E-09	1.47E-08	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.92E-09	0.00E+00	6.36E-07	0.00E+00	0.00E+00	0.00E+00

XE-133M												
0 2500 h	1.34E-07	5.35E-07	5.64E-07	2.26E-06	0.00E+00	0.00E+00	1.01E-08	8.05E-08	8.51E-07	6.76E-06	0.00E+00	0.00E+00
1 2500 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.11E-08	6.24E-08	5.96E-06	5.23E-06	0.00E+00	0.00E+00
2 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.26E-08	3.15E-08	3.57E-06	4.32E-06	0.00E+00	0.00E+00
4 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.06E-08	3.08E-08	6.76E-06	2.59E-06	0.00E+00	0.00E+00
8 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.72E-08	1.11E-08	6.48E-06	9.30E-07	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.64E-10	3.60E-11	8.08E-08	3.02E-09	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.82E-10	2.00E-12	1.53E-08	1.68E-10	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.07E-11	2.92E-18	8.98E-10	2.45E-16	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.57E-17	0.00E+00	1.31E-15	0.00E+00	0.00E+00	0.00E+00
TOTALS	1.34E-07	5.64E-07	5.64E-07	2.26E-06	0.00E+00	0.00E+00	2.83E-07	0.00E+00	2.37E-05	0.00E+00	0.00E+00	0.00E+00

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
Initial steam release I2 & NG -- LPZ and CR Doses

	PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		PHOTON-SUBMG		DCSE RATE		BETA-SUBMG		R D O M		THYROID-INHAL	
	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr
XE-133																
0 2500 h	1.24E-06	4.97E-06	3.42E-06	1.37E-05	0.00E+00	0.00E+00	9.42E-08	7.48E-07	5.16E-06	4.10E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
1 2500 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.63E-07	5.84E-07	3.63E-05	3.20E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.99E-07	4.84E-07	2.19E-05	2.65E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.64E-07	2.95E-07	4.18E-05	1.61E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.48E-07	3.09E-07	4.09E-05	5.98E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.51E-09	3.56E-10	5.20E-07	1.95E-08	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.87E-09	2.23E-11	1.02E-07	1.22E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.24E-10	5.66E-17	6.81E-09	3.10E-15	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.16E-16	0.00E+00	1.73E-14	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS	1.24E-06	3.42E-06	3.42E-06	0.00E+00	0.00E+00	0.00E+00	2.68E-06	0.00E+00	1.47E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

XE-135M																
0 2500 h	4.86E-07	1.94E-06	9.94E-08	3.97E-07	0.00E+00	0.00E+00	2.98E-08	2.13E-07	1.21E-07	8.68E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
1 2500 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.85E-08	1.12E-08	2.79E-07	4.54E-08	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.37E-09	1.22E-09	1.37E-08	4.97E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.13E-10	3.34E-12	1.68E-09	1.36E-11	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.13E-12	2.50E-17	4.61E-12	1.02E-16	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.77E-18	2.12E-20	7.20E-18	8.62E-20	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.35E-21	0.00E+00	2.99E-20	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS	4.86E-07	9.94E-08	9.94E-08	3.97E-07	0.00E+00	0.00E+00	1.02E-07	0.00E+00	4.16E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

XE-135																
0 2500 h	8.33E-07	3.33E-06	9.83E-07	3.93E-06	0.00E+00	0.00E+00	6.26E-08	4.98E-07	1.48E-06	1.17E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
1 2500 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.26E-07	3.62E-07	1.00E-05	8.50E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.41E-07	2.85E-07	5.67E-06	6.69E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.21E-07	1.50E-07	9.89E-06	3.54E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.40E-07	4.20E-08	7.99E-06	9.87E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.64E-09	1.32E-10	8.54E-08	3.11E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.19E-10	2.77E-12	1.22E-08	6.50E-11	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.11E-11	4.37E-20	2.61E-10	1.03E-18	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.75E-19	0.00E+00	4.11E-18	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS	8.33E-07	9.83E-07	9.83E-07	3.93E-06	0.00E+00	0.00E+00	1.50E-06	0.00E+00	3.51E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

XE-137																
0 2500 h	3.14E-08	1.26E-07	2.74E-07	1.09E-06	0.00E+00	0.00E+00	1.16E-09	6.57E-09	2.01E-07	1.14E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
1 2500 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.92E-10	9.92E-14	1.03E-07	1.72E-11	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.94E-15	2.40E-17	1.59E-12	4.17E-15	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.17E-18	5.49E-27	3.76E-16	9.52E-25	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.94E-28	0.00E+00	8.57E-26	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS	3.14E-08	1.26E-07	2.74E-07	1.09E-06	0.00E+00	0.00E+00	1.75E-09	0.00E+00	3.03E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Initial steam release I2 & NG -- LPZ and CR Doses

	PHOTON-SUBMG		BETA-SUBMG		E N V I R O N M E N T		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		C O N T R O L		R O D M		THYROID-INHAL		
	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	
	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	
XE-138																			
0 2500 h	7.88E-07	3.15E-06	4.07E-07	1.63E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.76E-08	3.37E-07	4.89E-07	3.46E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
1 2500 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.02E-07	1.02E-07	1.39E-08	1.04E-06	1.43E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.98E-09	3.98E-09	1.28E-09	4.08E-08	1.31E-08	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.01E-10	2.18E-12	4.11E-09	4.11E-09	2.24E-11	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.85E-13	6.37E-18	7.04E-12	6.54E-17	6.54E-17	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.43E-19	4.78E-21	4.54E-18	4.54E-18	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.54E-21	0.00E+00	1.58E-20	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS	7.88E-07	4.07E-07	4.07E-07	1.63E-06	0.00E+00	0.00E+00	0.00E+00	1.53E-07	3.37E-07	4.89E-07	3.46E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

I-131																			
0 2500 h	2.51E-05	1.01E-04	1.16E-05	4.62E-05	1.35E-01	5.42E-01	1.91E-06	1.51E-05	1.75E-05	1.39E-04	1.08E-04	1.08E-04	2.05E-01	1.62E+00					
1 2500 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.34E-05	1.18E-05	1.23E-04	1.08E-04	1.44E+00	1.44E+00	1.27E+00						
2 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.11E-06	9.84E-06	7.42E-05	9.01E-05	8.70E-01	8.70E-01	1.06E+00						
4 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.55E-05	6.01E-06	1.42E-04	5.50E-05	1.67E+00	1.67E+00	6.45E-01						
8 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.53E-05	2.24E-06	1.40E-04	2.03E-05	1.64E+00	1.64E+00	2.41E-01						
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.95E-07	7.33E-09	1.79E-06	6.71E-08	2.10E-02	2.10E-02	7.86E-04						
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.72E-10	3.54E-07	4.32E-09	4.16E-03	5.06E-05	5.06E-05							
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.66E-09	1.38E-15	2.44E-08	1.26E-14	2.86E-04	1.48E-10							
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.78E-15	0.00E+00	7.12E-14	0.00E+00	8.34E-10	0.00E+00							
TOTALS	2.51E-05	1.16E-05	1.35E-01	4.62E-05	1.35E-01	5.42E-01	5.45E-05	4.99E-04	1.75E-05	1.39E-04	1.08E-04	2.05E-01	1.62E+00						

I-132																			
0 2500 h	2.69E-05	1.08E-04	5.30E-06	2.12E-05	8.73E-04	3.49E-03	1.99E-06	1.56E-05	7.81E-06	6.13E-05	1.29E-03	1.29E-03	1.01E-02						
1 2500 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.21E-05	9.08E-06	4.73E-05	3.56E-05	7.78E-03	7.78E-03	5.86E-03						
2 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.39E-06	6.04E-06	2.19E-05	2.37E-05	3.61E-03	3.61E-03	3.89E-03						
4 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.36E-06	2.03E-06	2.88E-05	7.97E-06	4.79E-03	4.79E-03	1.31E-03						
8 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.31E-06	2.31E-07	1.30E-05	9.04E-07	2.14E-03	2.14E-03	1.49E-04						
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.96E-08	6.49E-10	7.67E-08	2.54E-09	1.26E-05	1.26E-05	4.19E-07						
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.37E-09	4.13E-13	5.35E-09	1.62E-12	8.81E-07	8.81E-07	2.67E-10						
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.71E-13	5.90E-28	3.41E-12	2.31E-27	5.42E-10	3.80E-25							
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.24E-27	0.00E+00	4.87E-27	0.00E+00	8.01E-25	0.00E+00							
TOTALS	2.69E-05	5.30E-06	8.73E-04	2.12E-05	8.73E-04	3.49E-03	3.04E-05	1.19E-04	7.81E-06	6.13E-05	1.29E-03	1.29E-03	1.01E-02						

I-133																			
0 2500 h	5.22E-05	2.09E-04	3.24E-05	1.30E-04	4.77E-02	1.91E-01	3.95E-06	3.13E-05	4.88E-05	3.68E-04	7.19E-02	5.71E-01							
1 2500 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.74E-05	2.38E-05	3.39E-04	2.94E-04	4.99E-01	4.33E-01							
2 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.61E-05	1.93E-05	1.99E-04	2.39E-04	2.93E-01	3.52E-01							
4 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.11E-05	3.67E-05	1.38E-04	1.38E-04	5.41E-01	2.03E-01							
8 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.69E-05	3.69E-06	3.33E-04	4.56E-05	4.91E-01	6.71E-02							
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.20E-07	1.19E-08	3.96E-06	1.47E-07	5.83E-03	2.16E-04							
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.51E-08	4.81E-10	6.81E-07	5.95E-09	1.00E-03	8.77E-06							
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.33E-09	1.65E-16	2.88E-08	2.04E-15	4.24E-05	3.01E-12							
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.99E-16	0.00E+00	9.88E-15	0.00E+00	1.46E-11	0.00E+00							
TOTALS	5.22E-05	3.24E-05	4.77E-02	1.30E-04	4.77E-02	1.91E-01	1.04E-04	1.29E-04	4.88E-05	3.68E-04	7.19E-02	5.71E-01							

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
Initial steam release I2 & MG -- LPZ and CR Doses

ENVIRONMENT		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		PHOTON-SUBM2		DOSE RATE		CENTRORL		DOSE RATE		THYROID-INHAL	
DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE
mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
0 2500 h	5 39E-06	2 16E-06	4 59E-06	7 13E-05	2 85E-04	3 84E-07	2 95E-06	1 63E-06	1 23E-05	1 01E-04	7 77E-04	0 2500 h	4 94E-05	0 00E+00	0 00E+00	0 00E+00	0 00E+00
1 2500 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	1 84E-06	1 05E-06	7 80E-06	4 45E-06	4 54E-04	2 76E-04	1 2500 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00
2 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	5 49E-07	4 84E-07	2 00E-06	2 05E-06	1 44E-04	1 27E-04	2 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00
4 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	4 09E-07	6 13E-08	1 70E-06	2 60E-07	1 08E-04	1 61E-05	4 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00
8 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	5 84E-08	9 83E-08	2 47E-07	4 14E-07	1 94E-05	2 58E-07	8 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00
24 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	8 01E-11	2 16E-12	3 39E-10	9 17E-12	2 11E-08	5 69E-10	24 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00
96 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	2 25E-12	7 02E-19	9 51E-12	2 98E-18	5 91E-10	1 85E-16	96 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00
720 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	7 28E-19	0 00E+00	3 09E-18	0 00E+00	1 92E-16	0 00E+00	720 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00
TOTALS	5 39E-06	1 15E-06	7 13E-05	2 85E-04	3 84E-07	2 95E-06	1 63E-06	1 23E-05	1 01E-04	7 77E-04	0 00E+00	TOTALS	4 94E-05	0 00E+00	0 00E+00	0 00E+00	0 00E+00

ENVIRONMENT		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		PHOTON-SUBM2		DOSE RATE		CENTRORL		DOSE RATE		THYROID-INHAL	
DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE
mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
0 2500 h	4 94E-05	1 07E-04	2 17E-02	3 73E-06	2 95E-05	1 60E-05	1 27E-04	8 12E-03	6 42E-02	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00
1 2500 h	0 00E+00	0 00E+00	0 00E+00	2 49E-05	2 09E-05	1 07E-04	8 94E-05	5 42E-02	4 54E-02	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00
2 0000 h	0 00E+00	0 00E+00	0 00E+00	1 38E-05	1 61E-05	5 90E-05	5 89E-05	2 99E-02	3 49E-02	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00
4 0000 h	0 00E+00	0 00E+00	0 00E+00	2 32E-05	8 02E-06	9 92E-05	3 44E-03	5 04E-02	1 74E-02	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00
8 0000 h	0 00E+00	0 00E+00	0 00E+00	1 73E-05	2 07E-06	7 42E-05	8 55E-06	3 77E-02	4 34E-03	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00
24 0000 h	0 00E+00	0 00E+00	0 00E+00	1 72E-07	6 20E-09	7 38E-07	2 66E-08	3 75E-04	1 35E-05	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00
96 0000 h	0 00E+00	0 00E+00	0 00E+00	2 20E-08	8 30E-11	9 41E-08	3 56E-10	4 78E-05	1 80E-07	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00
720 0000 h	0 00E+00	0 00E+00	0 00E+00	2 98E-10	1 65E-19	1 28E-09	7 07E-19	6 48E-07	3 59E-16	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00
TOTALS	4 94E-05	1 07E-04	2 17E-02	3 73E-06	2 95E-05	1 60E-05	1 27E-04	8 12E-03	6 42E-02	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00

ENVIRONMENT		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		PHOTON-SUBM2		DOSE RATE		CENTRORL		DOSE RATE		THYROID-INHAL	
DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE
mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
0 2500 h	1 71E-04	6 83E-04	2 91E-04	1 90E-01	7 58E-01	1 28E-05	1 01E-04	1 09E-04	8 61E-04	2 86E-01	2 27E+00	0 2500 h	1 71E-04	0 00E+00	0 00E+00	0 00E+00	0 00E+00
1 2500 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	8 46E-05	7 04E-05	7 33E-04	6 23E-04	2 00E+00	1 78E+00	1 2500 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00
2 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	4 65E-05	5 45E-05	4 17E-04	4 95E-04	1 20E+00	1 49E+00	2 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00
4 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	7 98E-05	2 84E-05	7 47E-04	2 75E-04	2 26E+00	8 66E-01	4 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00
8 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	6 53E-05	8 42E-06	6 57E-04	8 90E-05	2 17E+00	3 12E-01	8 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00
24 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	7 30E-07	2 69E-08	7 73E-06	2 86E-07	2 72E-02	1 02E-03	24 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00
96 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	1 20E-07	1 06E-09	1 36E-06	1 32E-08	5 21E-03	5 95E-05	96 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00
720 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	5 44E-09	1 60E-15	6 87E-08	2 21E-14	3 29E-04	1 51E-10	720 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00
TOTALS	1 71E-04	7 29E-05	2 91E-04	1 90E-01	7 58E-01	1 28E-05	1 01E-04	1 09E-04	8 61E-04	2 86E-01	2 27E+00	TOTALS	1 71E-04	0 00E+00	0 00E+00	0 00E+00	0 00E+00

COMP	NOT USED THIS CASE	COMP	3 Steam Generators	COMP	Control Room	VOLUME	1.730E+05 Cu Ft.
INITIAL							
ACT MULT (to uCi)							
PRODUCTION, uCi/s							
REMOVAL							
NUC 1-14 REL FR							
NUC 15-20 REL FR							

CASE 5

ERS-SFL-89-021

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Initial sec liquid iodine - LPZ and CR Doses

MULTIPLIERS====>

STEP	TIME	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF
1	9 000E+02	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
2	4 500E+03	0.050E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	1.00	70.0	0.000E+00
3	7 200E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	70.0	70.0	1.00
4	1 440E+04	0.000E+00	1.00	0.000E+00	0.000E+00	0.596	0.000E+00	70.0	70.0	1.00
5	2 880E+04	0.000E+00	1.00	0.000E+00	0.000E+00	0.596	0.000E+00	70.0	70.0	1.00
6	3 060E+04	0.000E+00	1.00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	3.300E+03	3.300E+03	0.000E+00
7	8 640E+04	0.000E+00	1.00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	50.0	50.0	0.000E+00
8	3 456E+05	0.000E+00	1.00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	50.0	50.0	0.000E+00
9	2 592E+06	0.000E+00	1.00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	50.0	50.0	0.000E+00

----- CONTROL ROOM -----

X/G	Breathing	Occupancy
s/M3	MC/s	
1.000E-03	3.470E-04	1.000E+00

----- ENVIRONMENT -----

X/G	Breathing
s/M3	MC/s
1.000E+00	3.470E-04

MULTIPLIERS====>

STEP	TIME	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF
1	9 000E+02	2.97	1.00	1.00	4.200E-05	1.00	0.000E+00	50.0	50.0	0.000E+00
2	4 500E+03	2.97	1.00	1.00	4.200E-05	1.00	0.000E+00	1.00	70.0	0.000E+00
3	7 200E+03	2.97	1.00	1.00	4.200E-05	1.00	0.000E+00	70.0	70.0	1.00
4	1 440E+04	2.97	1.00	1.00	4.200E-05	1.00	0.000E+00	70.0	70.0	1.00
5	2 880E+04	2.97	1.00	1.00	4.200E-05	1.00	0.000E+00	70.0	70.0	1.00
6	3 060E+04	1.94	1.00	1.00	2.700E-05	1.00	0.000E+00	3.300E+03	3.300E+03	0.000E+00
7	8 640E+04	1.94	1.00	1.00	2.700E-05	1.00	0.000E+00	50.0	50.0	0.000E+00
8	3 456E+05	0.692	1.00	1.00	1.540E-05	1.00	0.000E+00	50.0	50.0	0.000E+00
9	2 592E+06	0.154	1.00	1.00	6.800E-06	1.00	0.000E+00	50.0	50.0	0.000E+00

STEP	TIME	NOT USED THIS CASE			3 Steam Generators			AVERAGE			CONTROL ROOM		
		CURRENT	INTEGRD	INTEGRD	CURRENT	INTEGRD	INTEGRD	RELEASED	RELEASE	CURRENT	CURRENT	INTEGRD	
		uCi	uCi-sec	uCi-sec	uCi	uCi-sec	uCi	uCi/sec	uCi	uCi/cc	uCi-sec		
1-131	INITIAL	0	0	0	9	510E+06			0	0	0		
1	0 2500 h	0	0	0	9	484E+06	1	794E+04	1	230E+01	2	511E-09	
2	1 2500 h	0	0	0	9	378E+06	7	126E+04	1	980E+01	2	173E-09	
3	2 0000 h	0	0	0	9	300E+06	5	293E+04	1	960E+01	2	401E-09	
4	4 0000 h	0	0	0	9	151E+05	8	310E+04	1	154E+01	2	308E-09	
5	8 0000 h	0	0	0	8	839E+06	1	622E+03	1	126E+01	2	184E-09	
6	8 5000 h	0	0	0	8	943E+06	0	000E+00	0	000E+00	7	131E-12	
7	24 0000 h	0	0	0	8	365E+06	0	000E+00	0	000E+00	4	588E-13	
8	96 0000 h	0	0	0	6	458E+06	1	510E+12	0	000E+00	1	339E-18	
9	720 0000 h	0	0	0	6	855E+05	5	785E+12	0	000E+00	0	000E+00	
1-131	TOTALS	0	0	0	8	455E+12	3	874E+05	0	000E+00	3	213E+05	
1-132	INITIAL	0	0	0	1	690E+06			0	0	0		
1	0 2500 h	0	0	0	1	564E+06	3	072E+03	3	414E+00	4	145E-10	
2	1 2500 h	0	0	0	1	149E+06	4	845E+09	1	017E+04	2	825E+00	
3	2 0000 h	0	0	0	9	111E+05	5	811E+03	2	152E+00	2	360E-10	
4	4 0000 h	0	0	0	4	942E+05	6	139E+03	8	526E-01	1	274E-10	
5	8 0000 h	0	0	0	1	454E+05	5	136E+03	3	567E-01	4	927E+03	
6	8 5000 h	0	0	0	1	251E+05	0	000E+00	0	000E+00	1	161E-13	
7	24 0000 h	0	0	0	1	171E+03	0	000E+00	0	000E+00	7	397E-17	
8	96 0000 h	0	0	0	4	419E-07	0	000E+00	0	000E+00	1	056E-31	
9	720 0000 h	0	0	0	0	000E+00	5	280E-03	0	000E+00	0	000E+00	
1-132	TOTALS	0	0	0	1	983E+10	3	033E+04	0	000E+00	2	113E+04	
1-133	INITIAL	0	0	0	1	240E+07			0	0	0		
1	0 2500 h	0	0	0	1	227E+07	2	331E+04	2	590E+01	3	249E-09	
2	1 2500 h	0	0	0	1	178E+07	9	088E+04	2	524E+01	1	319E+01	
3	2 0000 h	0	0	0	1	143E+07	6	576E+04	2	436E+01	2	693E-09	
4	4 0000 h	0	0	0	1	059E+07	9	912E+04	1	377E+01	2	990E-09	
5	8 0000 h	0	0	0	9	106E+06	1	771E+05	1	230E+01	9	876E+04	
6	8 5000 h	0	0	0	8	956E+06	0	000E+00	0	000E+00	2	261E-09	
7	24 0000 h	0	0	0	5	343E+06	0	000E+00	0	000E+00	7	274E-12	
8	96 0000 h	0	0	0	4	850E+05	0	000E+00	0	000E+00	5	952E-13	
9	720 0000 h	0	0	0	4	514E-04	0	000E+00	0	000E+00	2	013E-15	
1-133	TOTALS	0	0	0	1	290E+12	4	562E+05	0	000E+00	3	711E+05	
1-134	INITIAL	0	0	0	2	970E+05			0	0	0		
1	0 2500 h	0	0	0	2	433E+05	5	086E+02	5	651E-01	1	483E+02	
2	1 2500 h	0	0	0	1	095E+05	1	266E+03	3	518E-01	2	527E-11	
3	2 0000 h	0	0	0	6	019E+05	4	670E+02	1	730E-01	1	581E-11	
4	4 0000 h	0	0	0	1	227E+05	2	714E+02	3	770E-02	2	472E-12	
5	8 0000 h	0	0	0	5	102E+05	6	663E+01	4	627E-03	6	590E-13	
6	8 5000 h	0	0	0	3	436E+02	0	000E+00	0	000E+00	5	706E-16	
7	24 0000 h	0	0	0	1	638E-03	0	000E+00	0	000E+00	1	850E-22	
8	96 0000 h	0	0	0	3	120E-28	0	000E+00	0	000E+00	2	044E-02	
9	720 0000 h	0	0	0	0	000E+00	0	000E+00	0	000E+00	0	000E+00	
1-134	TOTALS	0	0	0	1	341E+09	2	580E+03	0	000E+00	1	486E+03	

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Initial sec liquid iodine - LPZ and CR Doses

STEP	TIME	NOT USED THIS CASE		3 Steam Generators		AVERAGE		CONTROL ROOM	
		CURRENT uCi	INTEGRD uCi-sec	CURRENT uCi	INTEGRD uCi-sec	RELEASED uCi	RELEASE uCi/sec	CURRENT uCi/cc	INTEGRD uCi-sec
1-135	INITIAL	0.000E+00	0.000E+00	4.540E+06	4.029E+09	8.457E+03	9.397E+00	0.000E+00	0.000E+00
1	0 2500 h	0.000E+00	0.000E+00	4.414E+06	4.029E+09	8.457E+03	9.397E+00	5.726E+00	1.169E-09
2	1 2500 h	0.000E+00	0.000E+00	3.945E+06	1.503E+10	3.155E+04	8.764E+00	4.418E+00	9.018E-10
3	2 0000 h	0.000E+00	0.000E+00	3.626E+06	1.021E+10	2.144E+04	7.941E+00	4.589E+00	9.368E-10
4	4 0000 h	0.000E+00	0.000E+00	2.913E+06	2.343E+10	2.933E+04	4.074E+00	3.617E+00	7.384E-10
5	8 0000 h	0.000E+00	0.000E+00	1.881E+06	3.398E+10	4.251E+04	2.952E+00	2.342E+00	4.731E-10
6	8 5000 h	0.000E+00	0.000E+00	1.785E+06	3.299E+09	0.000E+00	0.000E+00	7.271E-03	1.484E-12
7	24 0000 h	0.000E+00	0.000E+00	3.513E+05	4.922E+10	0.000E+00	0.000E+00	9.735E-05	1.587E-14
8	96 0000 h	0.000E+00	0.000E+00	1.847E+02	1.203E+10	0.000E+00	0.000E+00	1.935E-13	3.931E-23
9	720 0000 h	0.000E+00	0.000E+00	7.037E-27	6.342E+06	0.000E+00	0.000E+00	0.000E+00	0.000E+00
1-135	TOTALS	0.000E+00	0.000E+00	1.513E+11	1.333E+05	1.333E+05	0.000E+00	0.000E+00	0.000E+00
ALL NUCLIDES		0.000E+00	0.000E+00	6.865E+03				0.000E+00	0.000E+00
STEP	9								

IRAILS -- Transport of Radioactive Material in Linear Systems, v.1.0
Initial sec liquid iodine - LPZ and CR Doses

PHOTON-SUBMCG		BETA-SUBMCG		ENVIRONMENT		THYROID-INHAL		PHOTON-SUBMCG		BETA-SUBMCG		CENTROL		THYROID-INHAL			
DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE		
mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr		
I-131																	
0 2500 h	7 18E-05	2 87E-04	3 30E-05	1 32E-04	3 87E-01	1 55E+00	5 45E-06	4 33E-05	4 99E-05	3 96E-04	3 96E-04	5 84E-01	4 64E+00				
1 2500 h	2 85E-04	2 85E-04	1 31E-04	1 31E-04	1 54E+00	1 54E+00	4 00E-05	3 69E-05	3 66E-04	3 38E-04	3 38E-04	4 29E+00	3 96E+00				
2 0000 h	2 12E-04	2 82E-04	9 74E-05	1 30E-04	1 14E+00	1 52E+00	2 94E-05	4 14E-05	2 69E-04	3 79E-04	3 79E-04	3 16E+00	4 44E+00				
4 0000 h	3 33E-04	1 66E-04	1 53E-04	7 65E-05	1 79E+00	8 96E-01	8 10E-05	3 98E-05	7 41E-04	3 34E-04	3 34E-04	8 69E+00	4 27E+00				
8 0000 h	6 49E-04	1 62E-04	2 99E-04	7 46E-05	3 50E+00	8 75E-01	1 54E-04	3 76E-05	1 41E-03	3 44E-04	3 44E-04	1 65E+01	4 04E+00				
B 5000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	3 28E-06	1 23E-07	3 00E-05	1 12E-06	1 12E-06	3 52E-01	1 32E-02				
24 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	6 50E-07	7 91E-09	5 94E-06	7 24E-08	6 97E-02	6 48E-04	2 48E-09				
96 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	4 47E-08	2 31E-14	4 39E-07	2 11E-13	4 79E-03	2 48E-09	0 00E+00				
720 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	1 30E-13	0 00E+00	1 19E-12	0 00E+00	1 40E-08	0 00E+00	0 00E+00				
TOTALS	1 55E-03	7 13E-04	7 13E-04	7 13E-04	8 36E+00	8 36E+00	3 14E-04	2 87E-03	2 87E-03	3 37E+01	3 37E+01	3 37E+01	3 37E+01				
I-132																	
0 2500 h	7 99E-05	2 96E-04	1 46E-05	5 82E-05	2 40E-03	9 58E-03	5 48E-06	4 30E-05	2 14E-05	1 68E-04	1 68E-04	3 53E-03	2 77E-02				
1 2500 h	2 45E-04	2 45E-04	4 82E-05	4 82E-05	7 93E-03	7 93E-03	3 44E-05	2 73E-05	2 73E-05	1 07E-04	1 07E-04	2 22E-02	1 76E-02				
2 0000 h	1 40E-04	1 86E-04	2 75E-05	3 67E-05	4 53E-03	6 04E-03	1 93E-05	2 45E-05	2 45E-05	9 58E-05	9 58E-05	1 25E-02	1 58E-02				
4 0000 h	1 48E-04	7 38E-05	2 91E-05	1 45E-05	4 79E-03	2 39E-03	3 57E-05	1 32E-05	1 40E-04	5 17E-05	5 17E-05	2 30E-02	8 52E-03				
8 0000 h	1 24E-04	3 09E-05	2 43E-05	6 08E-06	4 00E-03	1 60E-03	2 90E-05	4 28E-06	1 13E-04	1 87E-05	1 87E-05	2 76E-03	2 76E-03				
B 5000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	3 63E-07	1 20E-08	1 42E-06	4 72E-08	2 34E-04	7 76E-06	4 94E-09				
24 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	2 53E-08	7 67E-12	9 92E-08	3 00E-11	1 63E-05	4 94E-09	7 03E-24				
96 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	1 61E-11	1 09E-26	6 32E-11	4 29E-26	1 04E-08	7 03E-24	0 00E+00				
720 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	2 30E-26	0 00E+00	9 02E-26	0 00E+00	1 49E-23	0 00E+00	0 00E+00				
TOTALS	7 30E-04	1 44E-04	1 44E-04	1 44E-04	2 36E-02	2 36E-02	1 24E-04	8 92E-05	8 92E-05	1 10E-03	1 10E-03	2 05E-01	1 62E+00				
I-133																	
0 2500 h	1 48E-04	5 94E-04	9 23E-05	3 69E-04	1 36E-01	5 43E-01	1 12E-05	8 92E-05	1 39E-04	1 10E-03	1 10E-03	2 05E-01	1 62E+00				
1 2500 h	5 79E-04	5 79E-04	2 60E-04	3 60E-04	5 30E-01	5 30E-01	8 12E-05	7 39E-05	7 39E-05	9 14E-04	9 14E-04	1 48E+00	1 35E+00				
2 0000 h	4 19E-04	5 59E-04	2 60E-04	3 47E-04	3 83E-01	5 11E-01	5 82E-05	8 10E-05	7 19E-04	1 00E-03	1 06E+00	1 06E+00	1 47E+00				
4 0000 h	6 31E-04	3 16E-04	3 92E-04	1 96E-04	5 78E-01	2 89E-01	1 54E-04	7 34E-05	1 90E-03	9 08E-04	2 80E+00	1 34E+00	1 34E+00				
8 0000 h	1 13E-03	2 82E-04	7 01E-04	1 75E-04	1 03E+00	2 58E-01	2 67E-04	6 20E-05	3 30E-03	7 67E-04	4 86E+00	1 13E+00	1 13E+00				
B 5000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	5 39E-06	2 00E-07	6 66E-05	2 47E-06	9 81E-02	3 63E-03	3 63E-03				
24 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	9 26E-07	8 10E-09	1 15E-05	1 00E-07	1 69E-02	1 48E-04	1 48E-04				
96 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	3 92E-08	2 78E-15	4 84E-07	3 44E-14	7 13E-04	5 06E-11	5 06E-11				
720 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	1 34E-14	0 00E+00	1 66E-13	0 00E+00	2 45E-10	0 00E+00	0 00E+00				
TOTALS	2 91E-03	1 81E-03	1 81E-03	1 81E-03	2 66E+00	2 66E+00	5 77E-04	8 92E-05	8 92E-05	1 10E-03	1 10E-03	2 05E-01	1 62E+00				
I-134																	
0 2500 h	1 40E-05	5 61E-05	2 99E-06	1 19E-05	1 85E-04	7 41E-04	9 98E-07	7 68E-06	4 23E-06	3 25E-05	3 25E-05	2 63E-04	2 02E-03				
1 2500 h	3 49E-05	3 49E-05	7 43E-06	7 43E-06	4 61E-04	4 61E-04	4 94E-06	3 00E-06	2 09E-05	1 27E-05	1 30E-03	7 89E-04	7 89E-04				
2 0000 h	1 29E-05	1 72E-05	2 74E-06	3 66E-06	1 70E-04	2 27E-04	1 78E-06	1 88E-06	7 52E-06	7 95E-06	4 67E-04	4 94E-04	4 94E-04				
4 0000 h	7 48E-06	3 74E-06	1 59E-06	7 97E-07	9 89E-05	4 94E-05	1 82E-06	4 12E-07	7 70E-06	1 75E-06	4 78E-04	1 08E-04	1 08E-04				
8 0000 h	1 84E-06	4 59E-07	3 91E-07	9 78E-08	2 43E-05	6 07E-06	4 67E-07	3 07E-08	1 98E-06	1 30E-07	1 23E-04	8 09E-06	8 09E-06				
B 5000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	2 51E-09	6 77E-11	1 06E-08	2 87E-10	6 60E-07	1 78E-08	1 78E-08				
24 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	7 03E-11	2 20E-17	2 98E-10	9 31E-17	1 85E-08	5 78E-15	5 78E-15				
96 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	2 28E-17	0 00E+00	9 66E-17	0 00E+00	5 99E-15	0 00E+00	0 00E+00				
720 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00				
TOTALS	7 11E-05	1 51E-05	1 51E-05	1 51E-05	9 40E-04	9 40E-04	1 00E-05	7 68E-06	7 68E-06	1 10E-03	1 10E-03	2 63E-04	2 02E-03				

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
Initial sec liquid iodine - LPZ and CR Doses

	PHOTON-SUBRGM			BETA-SUBRGM			THYROID-INHAL			PHOTON-SUBRGM			BETA-SUBRGM			THYROID-INHAL		
	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr
1-135																		
0 2500 h	1.40E-04	5.59E-04	3.01E-05	1.20E-04	1.53E-02	6.11E-02	1.05E-05	8.33E-05	4.51E-05	3.57E-04	2.29E-02	1.81E-01						
1 2500 h	5.22E-04	5.22E-04	1.12E-04	1.12E-04	5.70E-02	5.70E-02	7.32E-05	6.42E-05	3.14E-04	2.75E-04	1.59E-01	1.40E-01						
2 0000 h	3.55E-04	4.73E-04	7.64E-05	1.02E-04	3.87E-02	5.17E-02	4.92E-05	6.67E-05	2.11E-04	2.86E-04	1.07E-01	1.45E-01						
4 0000 h	4.85E-04	2.43E-04	1.04E-04	5.22E-05	5.30E-02	2.65E-02	1.18E-04	5.26E-05	5.04E-04	2.25E-04	2.56E-01	1.14E-01						
8 0000 h	7.03E-04	1.76E-04	1.51E-04	3.79E-05	7.68E-02	1.92E-02	1.65E-04	3.41E-05	7.07E-04	1.46E-04	3.59E-01	7.41E-02						
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.94E-06	1.06E-07	1.26E-05	4.53E-07	6.39E-03	2.30E-04						
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.75E-07	1.42E-09	1.61E-06	6.07E-09	8.15E-04	3.08E-06						
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.09E-09	2.81E-18	2.18E-08	1.21E-17	1.11E-05	6.12E-15						
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.01E-17	0.00E+00	4.33E-17	0.00E+00	2.20E-14	0.00E+00						
TOTALS	2.20E-03	4.75E-04	4.75E-04	2.41E-01	4.19E-04	4.19E-04	4.19E-04	0.00E+00	1.79E-03	0.00E+00	9.11E-01	0.00E+00						

ALL NUCLIDES	PHOTON-SUBRGM			BETA-SUBRGM			THYROID-INHAL			PHOTON-SUBRGM			BETA-SUBRGM			THYROID-INHAL		
	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr
0 2500 h	4.48E-04	1.79E-03	1.73E-04	6.92E-04	5.41E-01	2.16E+00	3.37E-05	2.66E-04	2.60E-04	2.06E-03	8.16E-01	6.48E+00						
1 2500 h	1.67E-03	1.67E-03	6.59E-04	6.59E-04	2.13E+00	2.13E+00	2.34E-04	2.05E-04	1.84E-03	1.65E-03	5.95E+00	5.47E+00						
2 0000 h	1.14E-03	1.52E-03	4.64E-04	6.19E-04	1.57E+00	2.09E+00	1.58E-04	2.15E-04	1.28E-03	1.77E-03	4.33E+00	6.07E+00						
4 0000 h	1.60E-03	8.02E-04	6.81E-04	3.40E-04	2.43E+00	1.21E+00	3.90E-04	1.79E-04	3.29E-03	1.55E-03	1.18E+01	5.73E+00						
8 0000 h	2.61E-03	6.51E-04	1.18E-03	2.94E-04	4.61E+00	1.15E+00	4.15E-04	1.38E-04	5.53E-03	1.27E-03	2.18E+01	5.24E+00						
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.20E-05	4.40E-07	1.11E-04	4.09E-06	4.56E-01	1.71E-02						
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.98E-06	1.74E-08	1.91E-05	1.79E-07	8.74E-02	9.99E-04						
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.90E-08	2.59E-14	9.15E-07	2.46E-13	5.52E-03	2.53E-09						
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.44E-13	0.00E+00	1.36E-12	0.00E+00	1.42E-08	0.00E+00						
TOTALS	7.46E-03	3.15E-03	3.15E-03	1.13E+01	1.44E-03	1.44E-03	1.44E-03	0.00E+00	1.23E-02	0.00E+00	4.52E+01	0.00E+00						

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 pri-to-sec leak losses in UI LRA assuming 1% F.F. w/ 35 min isol

COMP: RCS 1% FF PER SRP COMP: 3 Steam Generators COMP: Control Room
 VOLUME: 1.730E+05 Cu.ft.

INITIAL	C1	COMP: 3 Steam Generators	COMP: Control Room
0.000E+00	KR-B3m	0.000E+00	KR-B3m
0.000E+00	KR-B5m	0.000E+00	KR-B5m
0.000E+00	KR-B5	0.000E+00	KR-B5
0.000E+00	KR-B7	0.000E+00	KR-B7
0.000E+00	KR-B8	0.000E+00	KR-B8
0.000E+00	KR-B9	0.000E+00	KR-B9
0.000E+00	KR-90	0.000E+00	KR-90
0.000E+00	XE-131M	0.000E+00	XE-131M
0.000E+00	XE-133M	0.000E+00	XE-133M
0.000E+00	XE-133	0.000E+00	XE-133
0.000E+00	XE-135M	0.000E+00	XE-135M
0.000E+00	XE-135	0.000E+00	XE-135
0.000E+00	XE-137	0.000E+00	XE-137
0.000E+00	XE-138	0.000E+00	XE-138
B.210E+04	I-131	0.000E+00	I-131
1.040E+05	I-132	0.000E+00	I-132
1.530E+05	I-133	0.000E+00	I-133
1.790E+05	I-134	0.000E+00	I-134
1.390E+05	I-135	0.000E+00	I-135
1.000E+06		1.000E+00	

ACT MULT (to uCi):

PRODUCTION, uCi/s:	COMP: 3 Steam Generators	COMP: Control Room
0.000E+00	KR-B3m	0.000E+00
0.000E+00	KR-B5m	0.000E+00
0.000E+00	KR-B5	0.000E+00
0.000E+00	KR-B7	0.000E+00
0.000E+00	KR-B8	0.000E+00
0.000E+00	KR-B9	0.000E+00
0.000E+00	KR-90	0.000E+00
0.000E+00	XE-131M	0.000E+00
0.000E+00	XE-133M	0.000E+00
0.000E+00	XE-133	0.000E+00
0.000E+00	XE-135M	0.000E+00
0.000E+00	XE-135	0.000E+00
0.000E+00	XE-137	0.000E+00
0.000E+00	XE-138	0.000E+00
0.000E+00	I-131	0.000E+00
0.000E+00	I-132	0.000E+00
0.000E+00	I-133	0.000E+00
0.000E+00	I-134	0.000E+00
0.000E+00	I-135	0.000E+00

REMOVAL:
 NUC 1-14 REL FR: 1.000E+00
 NUC 15-20 REL FR: 1.000E+00

3.564E-07 1/sec
 1.000E+00
 1.000E+00

2.099E-06 1/sec
 0.000E+00
 0.000E+00

1.000E+01 cfm
 INTAKE REDUCT: 0.000E+00
 INTAKE FILTER: 9.360E-01

CASE 13

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 pri-to-sec leak iodines in UI LRA assuming 1% F.F. w/ 33 min isol

MULTIPLIERS====>

STEP	TIME	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF
1	2.100E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
2	5.700E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	1.00	70.0	0.000E+00
3	7.200E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	70.0	70.0	1.00
4	1.440E+04	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	70.0	70.0	1.00
5	2.880E+04	0.000E+00	1.00	0.000E+00	0.000E+00	0.596	0.000E+00	70.0	70.0	1.00
6	3.060E+04	0.000E+00	1.00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	3.300E+03	3.300E+03	0.000E+00
7	8.640E+04	0.000E+00	1.00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	50.0	50.0	0.000E+00
8	3.456E+05	0.000E+00	1.00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	50.0	50.0	0.000E+00
9	2.592E+06	0.000E+00	1.00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	50.0	50.0	0.000E+00

----- CONTROL ROOM -----

X/G	Breathing	Occupancy
s/M3	MG/s	
1.000E-03	3.470E-04	1.000E+00
2.97	1.00	1.00
2.97	1.00	1.00
2.97	1.00	1.00
2.97	1.00	1.00
2.97	1.00	1.00
1.94	1.00	1.00
1.94	1.00	1.00
0.692	1.00	1.00
0.154	1.00	1.00

----- ENVIRONMENT -----

X/G	Breathing
s/M3	M3/s
1.000E+00	3.470E-04
4.200E-05	1.00
4.200E-05	1.00
4.200E-05	1.00
4.200E-05	1.00
2.700E-05	1.00
2.700E-05	1.00
1.540E-05	1.00
6.800E-06	1.00

MULTIPLIERS====>

STEP	TIME, s	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF
1	2.100E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
2	5.700E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	1.00	70.0	0.000E+00
3	7.200E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	70.0	70.0	1.00
4	1.440E+04	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	70.0	70.0	1.00
5	2.880E+04	0.000E+00	1.00	0.000E+00	0.000E+00	0.596	0.000E+00	70.0	70.0	1.00
6	3.060E+04	0.000E+00	1.00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	3.300E+03	3.300E+03	0.000E+00
7	8.640E+04	0.000E+00	1.00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	50.0	50.0	0.000E+00
8	3.456E+05	0.000E+00	1.00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	50.0	50.0	0.000E+00
9	2.592E+06	0.000E+00	1.00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	50.0	50.0	0.000E+00

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 pri-to-sec leak iodines in UI LRA assuming 1x F.F. w/ 35 min iso1

RCS 1% FF PER SRP			3 Steam Generators			CONTROL ROOM		
STEP	TIME	INITIAL	CURRENT	INTEGR	INTEGR	INTEGR	CURRENT	INTEGR
			uCi	uCi-sec	uCi-sec	uCi-sec	uCi/cc	uCi-sec
I-131	INITIAL		0.000E+00					
1	0 5833 h	6 197E+10	1.722E+14	6.432E+10	1.350E+05	6.429E+01	8.990E+00	8.990E+00
2	1 5837 h	8 147E+10	2.940E+14	1.647E+08	4.070E+11	2.373E+02	8.088E+01	1.651E-08
3	2 0000 h	8 130E+10	1.275E+14	2.073E+08	2.775E+11	3.905E+02	1.079E+02	2.04E-08
4	4 0000 h	8 051E+10	5.805E+14	4.099E+08	2.225E+12	3.867E+02	2.40E+02	4.164E-08
5	8 0000 h	7 896E+10	1.748E+15	7.995E+08	8.733E+12	1.587E+02	5.124E+02	1.046E-07
6	8 5000 h	7 877E+10	1.420E+14	8.486E+08	1.483E+12	0.000E+00	1.673E+00	3.416E-10
7	24 0000 h	7 303E+10	4.233E+15	2.270E+09	8.790E+13	0.000E+00	1.077E-01	2.198E-11
8	96 0000 h	5.141E+10	1.597E+16	6.728E+09	1.234E+15	0.000E+00	3.143E-07	6.416E-17
9	720 0000 h	2.454E+09	3.615E+16	3.726E+07	1.592E+16	0.000E+00	0.000E+00	0.000E+00
I-131	TOTALS		5.881E+16		1.726E+16	1.528E+07		7.408E+06
I-132	INITIAL		0.000E+00					
1	0 5833 h	8 717E+10	2.002E+14	6.512E+07	7.263E+10	1.525E+05	9.333E+01	1.905E-08
2	1 5833 h	6.441E+10	2.708E+14	1.302E+08	3.663E+11	2.136E+02	6.247E+01	1.275E-08
3	2 0000 h	5.678E+10	9.077E+13	1.448E+08	2.070E+11	2.896E+02	7.421E+01	1.515E-08
4	4 0000 h	3.100E+10	3.067E+14	1.578E+08	1.133E+12	1.969E+02	7.924E+01	1.617E-08
5	8 0000 h	9.238E+09	2.536E+14	9.354E+07	1.842E+12	1.600E+02	6.794E+01	1.387E-08
6	8 5000 h	7.940E+09	1.543E+13	8.555E+07	1.611E+11	0.000E+00	1.912E-01	3.902E-11
7	24 0000 h	7.288E+07	9.359E+13	2.265E+06	1.393E+12	0.000E+00	1.218E-04	2.485E-14
8	96 0000 h	2.508E-02	6.659E+11	3.282E-03	3.075E+10	0.000E+00	1.737E-19	3.547E-29
9	720 0000 h	0.000E+00	2.983E+02	0.000E+00	4.048E+01	0.000E+00	0.000E+00	0.000E+00
I-132	TOTALS		1.237E+15		5.206E+12	5.078E+06		2.091E+06
I-133	INITIAL		0.000E+00					
1	0 5833 h	1.530E+11	3.181E+14	1.120E+08	1.185E+11	2.487E+05	1.642E+02	3.352E-08
2	1 5833 h	1.499E+11	5.306E+14	2.928E+08	7.328E+11	4.273E+02	1.434E+02	2.628E-08
3	2 0000 h	1.428E+11	2.157E+14	3.641E+08	4.929E+11	6.898E+02	1.892E+02	3.862E-08
4	4 0000 h	1.332E+11	9.932E+14	6.783E+08	3.781E+12	4.570E+02	3.372E+02	6.883E-08
5	8 0000 h	1.160E+11	1.792E+15	1.175E+09	1.354E+13	1.176E+03	7.555E+02	1.542E-07
6	8 5000 h	1.140E+11	2.070E+14	1.228E+09	2.163E+12	0.000E+00	2.431E+00	4.962E-10
7	24 0000 h	6.648E+10	4.924E+15	2.072E+09	9.841E+13	0.000E+00	9.865E-02	2.014E-11
8	96 0000 h	5.518E+09	6.362E+15	7.221E+08	3.908E+14	0.000E+00	3.386E-08	5.911E-18
9	720 0000 h	2.307E+00	5.740E+14	3.502E+00	1.001E+14	0.000E+00	0.000E+00	0.000E+00
I-133	TOTALS		1.592E+16		6.101E+14	2.449E+07		1.161E+07
I-134	INITIAL		0.000E+00					
1	0 5833 h	1.790E+11	3.010E+14	8.426E+07	1.039E+11	2.181E+05	0.000E+00	0.000E+00
2	1 5833 h	5.109E+10	2.805E+14	1.033E+08	3.651E+11	7.663E+05	1.169E+02	2.386E-08
3	2 0000 h	3.673E+10	6.528E+13	9.367E+07	1.483E+11	2.075E+02	4.829E+01	9.858E-09
4	4 0000 h	7.538E+09	1.327E+14	3.838E+07	4.646E+11	8.725E+01	4.728E+01	9.651E-09
5	8 0000 h	3.175E+08	3.283E+13	3.215E+06	2.122E+11	1.844E+01	2.141E+01	4.370E-09
6	8 5000 h	2.137E+08	4.719E+11	2.302E+06	4.721E+09	0.000E+00	4.312E+00	8.802E-10
7	24 0000 h	9.987E+02	9.715E+11	3.103E+01	1.206E+10	0.000E+00	9.300E-03	1.939E-12
8	96 0000 h	1.734E-22	4.540E+06	2.270E-23	1.487E+05	0.000E+00	3.081E-09	6.289E-19
9	720 0000 h	0.000E+00	7.885E-19	0.000E+00	1.046E-19	0.000E+00	0.000E+00	0.000E+00
I-134	TOTALS		8.138E+14		1.311E+12	2.142E+06		8.185E+05

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 pri-u-sec leak iodines in U1 LRA assuming 1X F.F. w/ 35 min isol

STEP	TIME	RCS 1X FF PER SRP		3 Steam Generators		AVERAGE RELEASED uCi	CONTROL ROOM		
		CURRENT uCi	INTEGRD uCi-sec	CURRENT uCi	INTEGRD uCi-sec		CURRENT uCi/cc	INTEGRD uCi-sec	
1-135	INITIAL								
1	0.3833 h	1.390E+11	2.830E+14	0.000E+00	0.000E+00	2.198E+05	1.422E+02	2.902E-08	1.533E+05
2	1.9833 h	1.307E+11	4.463E+14	9.761E+07	1.047E+11	1.287E+06	1.157E+02	2.361E-08	4.613E+05
3	2.0000 h	1.124E+11	1.724E+14	2.867E+08	3.936E+11	8.265E+05	1.484E+02	3.029E-08	1.986E+05
4	2.0000 h	9.091E+10	7.292E+14	4.629E+08	2.754E+11	3.446E+06	2.300E+02	4.694E-08	1.396E+06
5	2.0000 h	5.946E+10	1.067E+15	6.020E+08	7.932E+12	9.923E+06	3.938E+02	8.039E-08	4.756E+06
6	2.0000 h	5.638E+10	1.043E+14	6.075E+08	1.089E+12	0.000E+00	1.222E+00	2.495E-10	1.224E+05
7	2.0000 h	1.088E+10	1.543E+15	3.381E+08	2.813E+13	0.000E+00	1.637E-02	3.341E-12	1.560E+04
8	2.0000 h	5.216E+05	3.688E+14	6.826E+05	1.609E+13	0.000E+00	3.294E-11	6.643E-21	2.117E+02
9	2.0000 h	8.921E-23	1.769E+11	1.335E-22	2.560E+10	0.000E+00	0.000E+00	0.000E+00	4.210E-07
1-135	TOTALS		4.714E+15		5.714E+13	1.570E+07			7.103E+05

ALL NUCLIDES @ STEP 9 2.454E+09 3.726E+09 0.000E+00 0.000E+00

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 p1-to-sec leak iodine in UI LRA assuming 1X F.F. w/ 33 min isol

		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL	
		DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE
		mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
1-131													
0	5933 h	5.40E-04	9.26E-04	2.48E-04	4.26E-04	2.91E+00	4.99E+00	7.39E-05	3.16E-04	8.59E-04	2.89E-03	1.01E+01	3.39E+01
1	5833 h	3.42E-03	3.42E-03	1.57E-03	1.57E-03	1.84E+01	1.84E+01	3.00E-04	2.85E-04	2.74E-03	2.60E-03	3.22E+01	3.05E+01
2	0000 h	2.34E-03	5.53E-03	1.08E-03	2.59E-03	1.26E+01	3.03E+01	1.39E-04	3.80E-04	1.27E-03	3.48E-03	1.49E+01	4.07E+01
4	0000 h	1.11E-02	5.57E-03	5.12E-03	2.56E-03	6.00E+01	3.00E+01	1.13E-03	7.18E-04	1.03E-02	6.57E-03	1.21E+02	7.70E+01
8	0000 h	4.37E-02	1.09E-02	2.01E-02	5.03E-03	2.36E+02	5.89E+01	5.39E-03	1.80E-03	4.93E-02	1.65E-02	5.78E+02	1.93E+02
8	5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.57E-04	5.89E-06	1.44E-03	5.39E-05	1.68E+01	6.32E-01
24	0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.11E-05	3.79E-07	2.85E-04	3.47E-06	3.34E+00	4.06E-02
96	0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.14E-06	1.11E-12	1.96E-05	1.01E-11	2.30E-01	1.19E-07
720	0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.25E-12	0.00E+00	5.72E-11	0.00E+00	6.70E-07	0.00E+00
TOTALS		6.12E-02		2.81E-02		3.30E+02		7.24E-03		6.62E-02		7.77E+02	

		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL	
		DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE
		mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
1-132													
0	5833 h	3.67E-03	6.29E-03	7.22E-04	1.24E-03	1.19E-01	2.04E-01	6.02E-01	1.97E-03	2.36E-03	7.74E-03	3.88E-01	1.27E+00
1	5833 h	1.85E-02	1.85E-02	3.64E-03	3.64E-03	6.00E-01	6.00E-01	1.62E-03	1.32E-03	6.34E-03	5.18E-03	1.04E+00	8.92E-01
2	0000 h	1.05E-02	2.51E-02	2.06E-03	4.94E-03	8.13E-01	8.13E-01	6.04E-04	1.57E-03	2.37E-03	6.15E-03	7.90E-01	1.01E+00
4	0000 h	3.41E-02	1.71E-02	6.71E-03	3.36E-03	1.11E+00	5.53E-01	3.27E-03	1.68E-03	1.28E-02	6.57E-03	2.11E+00	1.08E+00
8	0000 h	5.54E-02	1.39E-02	1.09E-02	2.73E-03	1.80E+00	4.49E-01	6.07E-03	1.44E-03	2.38E-02	5.63E-03	3.91E+00	9.27E-01
8	5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.22E-04	4.04E-06	4.78E-04	1.58E-05	7.87E-02	2.61E-03
24	0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.51E-06	2.58E-09	3.33E-05	1.01E-08	5.49E-03	1.66E-06
96	0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.43E-09	3.68E-24	2.13E-08	1.44E-23	3.50E-06	2.37E-21
720	0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.74E-24	0.00E+00	3.03E-23	0.00E+00	4.99E-21	0.00E+00
TOTALS		1.22E-01		2.41E-02		3.96E+00		1.23E-02		4.81E-02		7.92E+00	

		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL	
		DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE
		mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
1-133													
0	5833 h	1.58E-03	2.72E-03	9.85E-04	1.69E-03	1.45E+00	2.49E+00	2.74E-04	9.20E-04	3.38E-03	1.14E-02	4.98E+00	1.67E+01
1	5833 h	9.80E-03	9.80E-03	6.09E-03	6.09E-03	8.97E+00	8.97E+00	8.59E-04	8.03E-04	1.06E-02	9.94E-03	1.56E+01	1.46E+01
2	0000 h	6.59E-03	1.58E-02	4.10E-03	9.83E-03	6.03E+00	1.45E+01	3.89E-04	1.06E-03	4.81E-03	1.31E-02	7.09E+00	1.93E+01
4	0000 h	3.01E-02	1.51E-02	1.87E-02	3.7E-03	2.76E+01	1.38E+01	3.02E-03	1.89E-03	3.74E-02	2.34E-02	5.51E+01	3.44E+01
8	0000 h	1.08E-01	2.70E-02	6.71E-02	1.68E-02	9.87E+01	2.47E+01	1.31E-02	4.23E-03	1.62E-01	5.23E-02	2.38E+02	7.71E+01
8	5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.68E-04	1.36E-05	4.54E-03	1.68E-04	6.69E+00	2.48E-01
24	0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.32E-05	5.53E-07	7.81E-04	6.83E-06	1.15E+00	1.01E-02
96	0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.67E-06	1.90E-13	3.30E-05	2.35E-12	4.87E-02	3.45E-09
720	0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.17E-13	0.00E+00	1.13E-11	0.00E+00	1.67E-08	0.00E+00
TOTALS		1.56E-01		9.70E-02		1.43E+02		1.81E-02		2.23E-01		3.29E+02	

		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL	
		DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE	DOSE	RATE
		mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
1-134													
0	5833 h	6.01E-03	1.03E-02	1.28E-03	2.19E-03	7.95E-02	1.36E-01	9.04E-04	2.83E-03	3.83E-03	1.20E-02	2.38E-01	7.45E-01
1	5833 h	2.11E-02	2.11E-02	4.50E-03	4.50E-03	2.79E-01	2.79E-01	1.86E-03	1.17E-03	7.89E-03	4.96E-03	4.90E-01	3.08E-01
2	0000 h	8.58E-03	2.06E-02	1.83E-03	4.38E-03	1.13E-01	2.72E-01	4.82E-04	1.15E-03	2.04E-03	4.86E-03	1.27E-01	3.01E-01
4	0000 h	1.60E-02	8.01E-03	3.41E-03	1.71E-03	2.12E-01	1.06E-01	1.46E-03	5.19E-04	6.20E-03	2.20E-03	3.85E-01	1.36E-01
8	0000 h	7.32E-02	1.83E-03	1.56E-03	3.90E-04	9.67E-02	2.42E-02	7.92E-04	1.05E-04	3.36E-03	4.43E-04	2.75E-02	2.75E-02
8	5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.52E-06	2.30E-07	3.61E-05	9.76E-07	2.24E-03	6.04E-05
24	0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.39E-07	7.47E-14	1.01E-06	3.16E-13	6.28E-05	1.96E-11
96	0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.75E-14	0.00E+00	3.28E-13	0.00E+00	2.04E-11	0.00E+00
720	0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS		5.91E-02		1.26E-02		7.81E-01		5.51E-03		2.33E-02		1.45E+00	

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 pri-to-sec leak iodines in UI LRA assuming 1% F.F. w/ 35 min isci

		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL		PHOTON-SUBMG		BETA-SUBMG		THYROID-INHAL	
		DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE
		mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
I-135													
0	5833 h	3.63E-03	6.23E-03	7.83E-04	1.34E-03	3.97E-01	6.81E-01	6.19E-04	2.07E-03	2.65E-03	8.86E-03	1.35E+00	4.50E+00
1	5833 h	2.13E-02	2.13E-02	4.58E-03	4.58E-03	2.33E+00	2.33E+00	1.86E-03	1.68E-03	7.98E-03	7.21E-03	4.05E+00	3.68E+00
2	0000 h	1.37E-02	3.28E-02	2.94E-03	7.06E-03	1.49E+00	3.58E+00	8.02E-04	2.16E-03	3.44E-03	9.23E-03	1.74E+00	4.69E+00
4	0000 h	5.70E-02	2.85E-02	1.23E-02	6.14E-03	6.23E+00	3.11E+00	5.64E-03	3.34E-03	2.42E-02	1.43E-02	1.23E+01	7.27E+00
8	0000 h	1.64E-01	4.10E-02	3.53E-02	8.84E-03	1.79E+01	4.48E+00	1.92E-02	5.73E-03	8.23E-02	2.45E-02	4.18E+01	1.25E+01
8	5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.94E-04	1.78E-05	2.12E-03	7.62E-05	1.07E+00	3.87E-02
24	0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.30E-05	2.03E-07	2.70E-04	1.02E-06	1.37E-01	5.18E-04
96	0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.55E-07	4.78E-16	3.66E-06	2.03E-15	1.86E-03	1.03E-12
720	0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.70E-15	0.00E+00	7.29E-15	0.00E+00	3.70E-12	0.00E+00
TOTALS		2.60E-01	5.59E-02	5.59E-02	0.00E+00	2.84E+01	0.00E+00	2.87E-02	8.11E-03	1.23E-01	4.29E-02	6.24E+01	0.00E+00

ALL NUCLIDES

0	5833 h	1.54E-02	2.65E-02	4.02E-03	6.89E-03	4.96E+00	8.90E+00	2.49E-03	8.11E-03	1.31E-02	4.29E-02	1.70E+01	5.74E+01
1	5833 h	7.41E-02	7.41E-02	2.04E-02	2.04E-02	3.06E+01	3.06E+01	6.50E-03	5.26E-03	3.56E-02	2.99E-02	5.34E+01	5.00E+01
2	0000 h	4.16E-02	9.59E-02	1.20E-02	2.88E-02	2.06E+01	4.95E+01	2.42E-03	6.31E-03	1.39E-02	3.68E-02	2.42E+01	6.60E+01
4	0000 h	1.48E-01	7.62E-02	4.63E-02	2.31E-02	9.52E+01	4.76E+01	1.45E-02	8.13E-03	9.08E-02	5.30E-02	1.91E+02	1.20E+02
8	0000 h	3.78E-01	9.46E-02	1.35E-01	3.37E-02	3.54E+02	8.85E+01	4.46E-02	1.33E-02	3.21E-01	9.95E-02	8.63E+02	2.84E+02
8	5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.15E-03	4.16E-05	8.61E-03	3.15E-04	2.47E+01	9.21E-01
24	0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.66E-04	1.17E-06	1.37E-03	1.13E-05	4.63E+00	5.12E-02
96	0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.67E-06	1.30E-12	5.63E-05	1.25E-11	2.80E-01	1.22E-07
720	0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.17E-12	0.00E+00	6.85E-11	0.00E+00	6.87E-07	0.00E+00
TOTALS		6.58E-01	2.18E-01	2.18E-01	0.00E+00	5.06E+02	0.00E+00	7.18E-02	8.11E-03	1.23E-01	4.29E-02	1.18E+03	0.00E+00

COMP: NOT USED THIS CASE COMP: RCS 1XFF PER SRP -3/56 COMP: Control Room
 VOLUME: 1.730E+05 Cu Ft.

INITIAL:

C1

0.000E+00 KR-83m
 0.000E+00 KR-85m
 0.000E+00 KR-85
 0.000E+00 KR-87
 0.000E+00 KR-88
 0.000E+00 KR-89
 0.000E+00 KR-90
 0.000E+00 XE-131M
 0.000E+00 XE-133M
 0.000E+00 XE-133
 0.000E+00 XE-135M
 0.000E+00 XE-135
 0.000E+00 XE-137
 0.000E+00 XE-138
 0.000E+00 I-131
 0.000E+00 I-132
 0.000E+00 I-133
 0.000E+00 I-134
 0.000E+00 I-135
 1.000E+00

1.270E+04 KR-83m
 3.070E+04 KR-85m
 2.840E+03 KR-85
 5.900E+04 KR-87
 8.390E+04 KR-88
 1.080E+05 KR-89
 0.000E+00 KR-90
 5.230E+02 XE-131M
 4.140E+03 XE-133M
 1.590E+05 XE-133
 4.250E+04 XE-135M
 4.320E+04 XE-135
 1.390E+05 XE-137
 1.390E+05 XE-138
 0.000E+00 I-131
 0.000E+00 I-132
 0.000E+00 I-133
 0.000E+00 I-134
 0.000E+00 I-135
 1.000E+00

ACT MULT (to uCi):

PRODUCTION, uCi/s:

0.000E+00 KR-83m
 0.000E+00 KR-85m
 0.000E+00 KR-85
 0.000E+00 KR-87
 0.000E+00 KR-88
 0.000E+00 KR-89
 0.000E+00 KR-90
 0.000E+00 XE-131M
 0.000E+00 XE-133M
 0.000E+00 XE-133
 0.000E+00 XE-135M
 0.000E+00 XE-135
 0.000E+00 XE-137
 0.000E+00 XE-138
 0.000E+00 I-131
 0.000E+00 I-132
 0.000E+00 I-133
 0.000E+00 I-134
 0.000E+00 I-135

0.000E+00 KR-83m
 0.000E+00 KR-85m
 0.000E+00 KR-85
 0.000E+00 KR-87
 0.000E+00 KR-88
 0.000E+00 KR-89
 0.000E+00 KR-90
 0.000E+00 XE-131M
 0.000E+00 XE-133M
 0.000E+00 XE-133
 0.000E+00 XE-135M
 0.000E+00 XE-135
 0.000E+00 XE-137
 0.000E+00 XE-138
 0.000E+00 I-131
 0.000E+00 I-132
 0.000E+00 I-133
 0.000E+00 I-134
 0.000E+00 I-135
 1.000E+00

REMOVAL:

NUC 1-14 REL FR:
 NUC 15-20 REL FR:

0.000E+00 1/sec
 0.000E+00
 6.000E+00

3.564E-07 1/svc
 1.000E+00
 1.000E+00

INTAKE: 1.000E+01 CFM

1.000E+01 cfm
 INTAKE REDUCT: 0.000E+00
 INTAKE FILTER: 9.360E-01

CASE 23

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Pri-to-sec leak N.0 in UI LRA assuming 1% F.F. (non-eql1) W/ 35 DELAY

MULTIPLIERS====>

STEP	TIME	XPR	XREM	XRF	XPR	XREM	XRF	XPR	XREM	XRF
1	2.100E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
2	5.700E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	70.0	70.0	0.000E+00
3	7.200E+03	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	70.0	70.0	1.00
4	1.440E+04	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	70.0	70.0	1.00
5	2.880E+04	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	70.0	70.0	1.00
6	3.060E+04	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	3.300E+03	3.300E+03	0.000E+00
7	8.640E+04	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
8	3.456E+05	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00
9	2.592E+06	0.000E+00	1.00	0.000E+00	0.000E+00	1.00	0.000E+00	50.0	50.0	0.000E+00

----- CONTROL ROOM -----

X/G	Breathing	Occupancy	X/G	Breathing
s/M3	M3/s		s/M3	M3/s
1.000E-03	3.470E-04	1.000E+00	1.000E+00	3.470E-04

----- ENVIRONMENT -----

X/G	Breathing
s/M3	M3/s
4.200E-05	1.00
4.200E-05	1.00
4.200E-05	1.00
4.200E-05	1.00
2.700E-05	1.00
2.700E-05	1.00
1.540E-05	1.00
6.800E-06	1.00

MULTIPLIERS====>

STEP	TIME
1	2.100E+03
2	5.700E+03
3	7.200E+03
4	1.440E+04
5	2.880E+04
6	3.060E+04
7	8.640E+04
8	3.456E+05
9	2.592E+06

NOT USED THIS CASE

HCS 1XFF PER SRP -3/

CONTROL ROOM

STEP TIME	NOT USED THIS CASE		HCS 1XFF PER SRP -3/		CONTROL ROOM	
	CURRENT	INTEGRD	CURRENT	INTEGRD	CURRENT	INTEGRD
	UC1	UC1-sec	UC1	UC1-sec	UC1/cc	UC1-sec
KR-83m INITIAL	0	0.000E+00	1.270E+10		0	0.000E+00
1 0 5833 h	0	0.000E+00	1.017E+10	2.392E+13	5	1.08E+03
2 1 5833 h	0	0.000E+00	6.958E+09	3.047E+13	5	8.32E-07
3 2 0000 h	0	0.000E+00	5.939E+09	9.633E+12	1	0.57E-06
4 4 0000 h	0	0.000E+00	2.778E+09	2.995E+13	7	4.90E+03
5 8 0000 h	0	0.000E+00	6.075E+08	2.056E+13	3	2.75E+03
6 8 5000 h	0	0.000E+00	5.027E+08	9.962E+11	6	6.81E-07
7 24 0000 h	0	0.000E+00	1.419E+06	4.765E+12	1	8.10E-09
8 96 0000 h	0	0.000E+00	2.040E-06	1.349E+10	8	7.02E-03
9 720 0000 h	0	0.000E+00	0	1.939E-02	9	2.53E-21
KR-83m TOTALS	0	0.000E+00	1.203E+14		0	0.000E+00
KR-85m INITIAL	0	0.000E+00	3.070E+10		0	0.000E+00
1 0 5833 h	0	0.000E+00	2.803E+10	6.162E+13	1	4.01E+04
2 1 5833 h	0	0.000E+00	2.398E+10	9.343E+13	2	7.99E+03
3 2 0000 h	0	0.000E+00	2.247E+10	3.483E+13	2	0.00E-07
4 4 0000 h	0	0.000E+00	1.645E+10	1.390E+14	3	9.53E+04
5 8 0000 h	0	0.000E+00	8.813E+09	1.762E+14	4	2.35E+04
6 8 5000 h	0	0.000E+00	8.156E+09	1.526E+13	8	6.55E-05
7 24 0000 h	0	0.000E+00	7.412E+08	1.725E+14	1	1.96E+02
8 96 0000 h	0	0.000E+00	1.076E+04	1.725E+13	7	3.90E-01
9 720 0000 h	0	0.000E+00	0	2.503E+08	4	0.55E-11
KR-85m TOTALS	0	0.000E+00	7.101E+14		0	0.000E+00
KR-85 INITIAL	0	0.000E+00	2.840E+09		0	0.000E+00
1 0 5833 h	0	0.000E+00	2.838E+09	5.962E+12	1	4.16E+03
2 1 5833 h	0	0.000E+00	2.834E+09	1.021E+13	2	1.56E+03
3 2 0000 h	0	0.000E+00	2.833E+09	4.250E+12	2	4.59E+03
4 4 0000 h	0	0.000E+00	2.825E+09	2.037E+13	7	1.55E+03
5 8 0000 h	0	0.000E+00	2.811E+09	4.058E+13	1	1.79E+04
6 8 5000 h	0	0.000E+00	2.511E+09	5.059E+12	2	4.06E-06
7 24 0000 h	0	0.000E+00	2.811E+09	1.568E+14	3	8.57E+01
8 96 0000 h	0	0.000E+00	2.809E+09	7.283E+14	2	6.23E+00
9 720 0000 h	0	0.000E+00	2.796E+09	6.296E+15	9	9.13E-06
KR-85 TOTALS	0	0.000E+00	7.267E+15		0	0.000E+00
KR-87 INITIAL	0	0.000E+00	5.900E+10		0	0.000E+00
1 0 5833 h	0	0.000E+00	4.290E+10	1.061E+14	2	1.65E+04
2 1 5833 h	0	0.000E+00	2.484E+10	1.190E+14	4	0.26E+04
3 2 0000 h	0	0.000E+00	1.978E+10	3.333E+13	1	7.32E+04
4 4 0000 h	0	0.000E+00	6.434E+09	8.685E+13	3	5.36E-06
5 8 0000 h	0	0.000E+00	7.460E+08	3.880E+13	1	8.84E+04
6 8 5000 h	0	0.000E+00	5.680E+08	1.75E+12	4	9.28E+03
7 24 0000 h	0	0.000E+00	1.217E+05	3.751E+12	0	2.27E+01
8 96 0000 h	0	0.000E+00	1.103E-12	8.040E+08	1	7.89E-04
9 720 0000 h	0	0.000E+00	0	7.283E-09	6	1.28E-27
KR-87 TOTALS	0	0.000E+00	3.885E+14		0	0.000E+00

STEP TIME	NOT USED THIS CASE		RCS 1%FF PER SRP -3/		AVERAGE		CONTROL ROOM	
	CURRENT uCi	INTEGRD uCi-sec	CURRENT uCi	INTEGRD uCi-sec	RELEASED uCi	RELEASE uCi/sec	CURRENT uCi/cc	INTEGRD uCi-sec
MR-88 INITIAL	0.000E+00	0.000E+00	8.390E+10	0.000E+00	5.851E+07	2.786E+04	0.000E+00	0.000E+00
1 0 5833 h	0.000E+00	0.000E+00	7.271E+10	1.642E+14	3.639E+04	7.429E-06	3.639E+04	3.976E+07
2 1 5833 h	0.000E+00	0.000E+00	5.689E+10	2.321E+14	8.273E+07	2.298E+04	4.753E-06	1.055E+08
3 2 0000 h	0.000E+00	0.000E+00	5.136E+10	8.112E+13	2.891E+07	1.927E+04	4.468E+04	5.152E+07
4 4 0000 h	0.000E+00	0.000E+00	3.144E+10	9.23E+14	1.042E+08	1.447E+04	8.219E+04	4.783E+08
5 8 0000 h	0.000E+00	0.000E+00	1.178E+10	3.84E+14	1.028E+08	7.13E+03	5.513E+04	9.386E+08
6 8 5000 h	0.000E+00	0.000E+00	1.043E+10	1.997E+13	0.000E+00	0.000E+00	1.625E+02	1.724E+07
7 24 0000 h	0.000E+00	0.000E+00	2.373E+08	1.503E+14	0.000E+00	0.000E+00	2.515E-01	1.399E+06
8 96 0000 h	0.000E+00	0.000E+00	5.534E+00	3.500E+12	0.000E+00	0.000E+00	2.218E-14	4.528E-24
9 720 0000 h	0.000E+00	0.000E+00	0.000E+00	8.163E+04	0.000E+00	0.000E+00	0.000E+00	0.000E+00
MR-88 TOTALS	0.000E+00	0.000E+00	1.232E+15	3.771E+08	3.771E+08	0.000E+00	0.000E+00	1.632E+09
MR-89 INITIAL	0.000E+00	0.000E+00	1.080E+11	0.000E+00	1.052E+07	5.011E+03	0.000E+00	0.000E+00
1 0 5833 h	0.000E+00	0.000E+00	4.998E+07	2.952E+13	4.871E+03	1.353E+00	9.476E+02	1.934E-07
2 1 5833 h	0.000E+00	0.000E+00	9.998E+01	1.367E+10	9.317E-03	6.211E-06	6.523E-03	1.332E-12
3 2 0000 h	0.000E+00	0.000E+00	3.984E-01	2.614E+04	4.871E+03	6.211E-06	2.611E-05	5.531E-15
4 4 0000 h	0.000E+00	0.000E+00	1.469E-12	1.090E+02	3.883E-05	5.393E-09	1.421E-09	2.901E-19
5 8 0000 h	0.000E+00	0.000E+00	1.999E-35	4.019E-10	1.432E-16	9.947E-21	2.621E-21	5.350E-31
6 8 5000 h	0.000E+00	0.000E+00	2.773E-38	5.461E-33	0.000E+00	0.000E+00	1.189E-26	2.427E-36
7 24 0000 h	0.000E+00	0.000E+00	0.000E+00	7.584E-36	0.000E+00	0.000E+00	0.000E+00	0.000E+00
8 96 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00
9 720 0000 h	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00
MR-89 TOTALS	0.000E+00	0.000E+00	2.954E+13	1.053E+07	1.053E+07	0.000E+00	0.000E+00	1.990E+06
XE-131M INITIAL	0.000E+00	0.000E+00	5.230E+08	0.000E+00	3.910E+05	1.862E+02	0.000E+00	0.000E+00
1 0 5833 h	0.000E+00	0.000E+00	5.219E+08	1.097E+12	6.683E+05	1.856E+02	2.121E+02	4.330E-08
2 1 5833 h	0.000E+00	0.000E+00	5.199E+08	1.875E+12	2.777E+05	1.852E+02	4.506E+02	9.197E-08
3 2 0000 h	0.000E+00	0.000E+00	5.191E+08	7.793E+11	1.327E+06	1.843E+02	1.305E+03	2.664E-07
4 4 0000 h	0.000E+00	0.000E+00	5.153E+08	3.724E+12	2.625E+06	1.823E+02	2.131E+03	4.349E-07
5 8 0000 h	0.000E+00	0.000E+00	5.077E+08	7.365E+12	0.000E+00	0.000E+00	6.961E+00	1.421E-09
6 8 5000 h	0.000E+00	0.000E+00	5.070E+08	9.132E+11	0.000E+00	0.000E+00	4.560E-01	9.308E-11
7 24 0000 h	0.000E+00	0.000E+00	4.882E+08	2.776E+13	0.000E+00	0.000E+00	1.446E-06	2.952E-16
8 96 0000 h	0.000E+00	0.000E+00	4.096E+08	1.161E+14	0.000E+00	0.000E+00	0.000E+00	0.000E+00
9 720 0000 h	0.000E+00	0.000E+00	8.939E+07	4.725E+14	0.000E+00	0.000E+00	0.000E+00	0.000E+00
XE-131M TOTALS	0.000E+00	0.000E+00	6.321E+14	5.289E+06	5.289E+06	0.000E+00	0.000E+00	3.470E+07
XE-133M INITIAL	0.000E+00	0.000E+00	4.140E+09	0.000E+00	3.086E+06	1.469E+03	0.000E+00	0.000E+00
1 0 5833 h	0.000E+00	0.000E+00	4.105E+09	8.657E+12	5.229E+06	1.453E+03	1.651E+03	3.370E-07
2 1 5833 h	0.000E+00	0.000E+00	4.046E+09	1.467E+13	2.157E+06	1.438E+03	3.491E+03	7.126E-07
3 2 0000 h	0.000E+00	0.000E+00	4.022E+09	6.051E+12	1.017E+07	1.413E+03	9.904E+03	2.022E-06
4 4 0000 h	0.000E+00	0.000E+00	3.907E+09	2.854E+13	1.948E+07	1.353E+03	1.552E+04	3.168E-06
5 8 0000 h	0.000E+00	0.000E+00	3.687E+09	5.467E+13	0.000E+00	0.000E+00	5.044E+01	1.030E-08
6 8 5000 h	0.000E+00	0.000E+00	3.663E+09	6.616E+12	0.000E+00	0.000E+00	2.797E+00	5.710E-10
7 24 0000 h	0.000E+00	0.000E+00	2.986E+09	1.849E+14	0.000E+00	0.000E+00	4.092E-06	8.354E-16
8 96 0000 h	0.000E+00	0.000E+00	1.155E+09	4.997E+14	0.000E+00	0.000E+00	0.000E+00	0.000E+00
9 720 0000 h	0.000E+00	0.000E+00	3.084E+05	3.154E+14	0.000E+00	0.000E+00	0.000E+00	0.000E+00
XE-133M TOTALS	0.000E+00	0.000E+00	1.119E+15	4.013E+07	4.013E+07	0.000E+00	0.000E+00	2.586E+08

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Pri-to-sec Leak N. @ in U1 LRA assuming 1% F.F. (non-equil) W/ 35 DELAY

STEP	TIME	NOT USED THIS CASE		RCS 1%FF PER SRP -3/		AVERAGE		CONTROL ROOM	
		CURRENT uCi	INTEGRD uCi-sec	CURRENT uCi	INTEGRD uCi-sec	RELEASED uCi	RELEASE uCi/sec	CURRENT uCi/cc	INTEGRD uCi-sec
XE-138	INITIAL	0	0.000E+00	1.390E+11	0	0	0	0.000E+00	0
1	0 5833 h	0	0.000E+00	2.495E+10	1.394E+14	4.970E+07	2.366E+04	1.605E+04	3.276E-06
2	1 5833 h	0	0.000E+00	1.313E+09	2.889E+13	1.030E+07	2.861E+03	7.067E+02	1.443E-07
3	2 0000 h	0	0.000E+00	3.849E+08	1.134E+12	4.043E+05	2.675E+02	4.069E+02	8.307E-08
4	4 0000 h	0	0.000E+00	1.066E+06	4.692E+11	1.672E+03	2.323E+01	2.640E+01	5.389E-09
5	8 0000 h	0	0.000E+00	8.171E+00	1.303E+09	4.644E+02	3.225E-02	3.583E-02	7.313E-12
6	8 5000 h	0	0.000E+00	1.876E+00	7.700E+03	0	0.000E+00	2.690E-03	5.492E-15
7	24 0000 h	0	0.000E+00	2.882E-20	2.294E+03	0	0.000E+00	2.812E-26	3.741E-36
8	96 0000 h	0	0.000E+00	0	3.525E-17	0	0.000E+00	0	0.000E+00
9	720 0000 h	0	0.000E+00	0	0.000E+00	0	0.000E+00	0	0.000E+00
XE-138	TOTALS	0	0.000E+00	1.699E+14	0	6.057E+07	0	0.000E+00	4.062E+07
ALL NUCLIDES		0	0.000E+00	5.869E+09	0	0	0	0.000E+00	0
@ STEP	9								

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Pri-to-sec leak N 0 in UI LRA assuming 1% F.F. (non-equil) W/ 35 DELAY

		PHOTON-SURMG		BETA-SURMG		THYROID-INHAL		PHOTON-SURMG		BETA-SURMG		THYROID-INHAL	
		DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE
		mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
KR-B3*	0 5833 h	2 33E-04	3 99E-04	3 15E-03	5 39E-03	0 00E+00	0 00E+00	3 77E-05	1 23E-04	1 01E-02	3 30E-02	0 00E+00	0 00E+00
	1 5833 h	2 97E-04	2 97E-04	4 01E-03	4 01E-03	0 00E+00	0 00E+00	9 28E-05	6 86E-05	2 50E-02	1 84E-02	0 00E+00	0 00E+00
	2 0000 h	9 39E-05	2 75E-04	1 27E-03	3 05E-03	0 00E+00	0 00E+00	4 07E-05	1 24E-04	1 09E-02	3 34E-02	0 00E+00	0 00E+00
	4 0000 h	2 91E-04	1 46E-04	3 94E-03	1 97E-03	0 00E+00	0 00E+00	3 15E-04	1 80E-04	8 48E-02	4 84E-02	0 00E+00	0 00E+00
	8 0000 h	2 00E-04	5 00E-05	2 70E-03	6 76E-04	0 00E+00	0 00E+00	4 41E-04	7 86E-05	1 18E-01	5 11E-02	0 00E+00	0 00E+00
	8 5000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	6 43E-06	2 13E-07	1 78E-03	5 72E-05	0 00E+00	0 00E+00
	24 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	3 85E-07	4 09E-11	1 04E-04	1 10E-08	0 00E+00	0 00E+00
	96 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	7 40E-11	2 22E-28	1 99E-08	5 97E-26	0 00E+00	0 00E+00
	720 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	4 02E-28	0 00E+00	1 08E-25	0 00E+00	0 00E+00	
TOTALS		1 11E-03		1 51E-02		0 00E+00		9 34E-04		2 51E-01		0 00E+00	

		PHOTON-SURMG		BETA-SURMG		THYROID-INHAL		PHOTON-SURMG		BETA-SURMG		THYROID-INHAL	
		DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE
		mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
KR-B5m	0 5833 h	3 64E-02	6 23E-02	5 42E-02	9 29E-02	0 00E+00	0 00E+00	6 14E-03	2 04E-02	1 82E-01	6 04E-01	0 00E+00	0 00E+00
	1 5833 h	5 51E-02	5 51E-02	8 21E-02	8 21E-02	0 00E+00	0 00E+00	1 71E-02	1 43E-02	5 08E-01	4 23E-01	0 00E+00	0 00E+00
	2 0000 h	2 06E-02	4 93E-02	3 06E-02	7 35E-02	0 00E+00	0 00E+00	8 98E-03	2 84E-02	2 66E-01	8 43E-01	0 00E+00	0 00E+00
	4 0000 h	8 20E-02	4 10E-02	1 22E-01	6 11E-02	0 00E+00	0 00E+00	9 45E-02	6 17E-02	2 80E+00	1 83E+00	0 00E+00	0 00E+00
	8 0000 h	1 04E-01	2 60E-02	1 55E-01	3 87E-02	0 00E+00	0 00E+00	2 36E-01	5 75E-02	7 00E+00	1 70E+00	0 00E+00	0 00E+00
	8 5000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	4 94E-03	1 74E-04	1 46E-01	5 16E-03	0 00E+00	0 00E+00
	24 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	5 27E-04	1 08E-06	1 56E-02	3 19E-05	0 00E+00	0 00E+00
	96 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	3 28E-06	5 90E-17	9 72E-05	1 75E-15	0 00E+00	0 00E+00
	720 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	1 80E-14	0 00E+00	5 33E-15	0 00E+00	0 00E+00	
TOTALS		2 98E-01		4 44E-01		0 00E+00		3 68E-01		1 09E+01		0 00E+00	

		PHOTON-SURMG		BETA-SURMG		THYROID-INHAL		PHOTON-SURMG		BETA-SURMG		THYROID-INHAL	
		DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE
		mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
KR-B5	0 5833 h	4 91E-05	8 41E-05	0 15E-03	8 83E-03	0 00E+00	0 00E+00	8 53E-06	2 88E-05	1 78E-02	6 01E-02	0 00E+00	0 00E+00
	1 5833 h	8 41E-05	8 41E-05	8 82E-03	8 82E-03	0 00E+00	0 00E+00	2 60E-05	2 35E-05	5 43E-02	4 91E-02	0 00E+00	0 00E+00
	2 0000 h	3 50E-05	8 40E-05	3 67E-03	8 81E-03	0 00E+00	0 00E+00	1 54E-05	4 99E-05	3 21E-02	1 04E-01	0 00E+00	0 00E+00
	4 0000 h	1 68E-04	8 38E-05	1 76E-02	8 80E-03	0 00E+00	0 00E+00	2 03E-04	1 45E-04	4 24E-01	3 04E-01	0 00E+00	0 00E+00
	8 0000 h	3 34E-04	8 35E-05	3 51E-03	8 77E-03	0 00E+00	0 00E+00	8 00E-04	2 39E-04	1 67E+00	5 00E-01	0 00E+00	0 00E+00
	8 5000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	2 09E-05	7 83E-07	4 35E-02	1 64E-03	0 00E+00	0 00E+00
	24 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	4 21E-06	5 33E-08	8 79E-03	1 11E-04	0 00E+00	0 00E+00
	96 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	3 07E-07	2 01E-13	6 42E-04	4 21E-10	0 00E+00	0 00E+00
	720 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	1 16E-12	0 00E+00	2 42E-09	0 00E+00	0 00E+00	
TOTALS		6 70E-04		7 03E-02		0 00E+00		1 08E-03		2 25E+00		0 00E+00	

		PHOTON-SURMG		BETA-SURMG		THYROID-INHAL		PHOTON-SURMG		BETA-SURMG		THYROID-INHAL	
		DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE
		mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
KR-B7	0 5833 h	3 15E-01	5 40E-01	4 83E-01	8 29E-01	0 00E+00	0 00E+00	4 95E-02	1 59E-01	1 51E+00	4 84E+00	0 00E+00	0 00E+00
	1 5833 h	3 53E-01	3 53E-01	5 42E-01	5 42E-01	0 00E+00	0 00E+00	1 11E-01	7 51E-02	3 40E+00	2 29E+00	0 00E+00	0 00E+00
	2 0000 h	9 89E-02	2 37E-01	1 52E-01	3 64E-01	0 00E+00	0 00E+00	4 27E-02	1 27E-01	1 30E+00	3 88E+00	0 00E+00	0 00E+00
	4 0000 h	2 57E-01	1 29E-01	3 95E-01	1 97E-01	0 00E+00	0 00E+00	2 68E-01	1 38E-01	8 17E+00	4 21E+00	0 00E+00	0 00E+00
	8 0000 h	1 15E-01	2 88E-02	1 77E-01	4 42E-02	0 00E+00	0 00E+00	2 55E-01	3 61E-02	7 80E+00	1 10E+00	0 00E+00	0 00E+00
	8 5000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	3 00E-03	8 59E-05	9 17E-02	2 75E-03	0 00E+00	0 00E+00
	24 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	1 25E-04	1 51E-09	3 82E-03	4 00E-08	0 00E+00	0 00E+00
	96 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	1 82E-09	4 49E-32	5 57E-08	1 37E-30	0 00E+00	0 00E+00
	720 0000 h	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	0 00E+00	6 25E-32	0 00E+00	1 91E-30	0 00E+00	0 00E+00	
TOTALS		1 14E+00		1 75E+00		0 00E+00		7 30E-01		2 23E+01		0 00E+00	

TRANS -- Transport of Radioactive Material in Linear Systems, v1.0
 Pr: 10-sec Leak N.G. in UI LRA assuming IX F.F. (non-equil) W/ 35 DELAY

		PHOTON-SUBMCG		BETA-SUBMCG		THYROID-INHAL		PHOTON-SUBMCG		BETA-SUBMCG		THYROID-INHAL	
		DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE
		mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
NR-88	0 5833 h	1.20E+00	2.06E+00	2.06E-01	3.53E-01	0.00E+00	0.00E+00	1.99E-01	6.57E-01	6.81E-01	2.24E+00	0.00E+00	0.00E+00
	1 5833 h	1.70E+00	1.70E+00	2.92E-01	2.42E-01	0.00E+00	0.00E+00	5.29E-01	4.20E-01	1.81E+00	1.44E+00	0.00E+00	0.00E+00
	2 0000 h	5.93E-01	1.42E+00	1.02E-01	2.45E-01	0.00E+00	0.00E+00	2.58E-01	8.06E-01	8.82E-01	2.76E+00	0.00E+00	0.00E+00
	4 0000 h	2.14E+00	1.07E+00	3.67E-01	1.84E-01	0.00E+00	0.00E+00	2.40E+00	1.48E+00	8.19E+00	5.07E+00	0.00E+00	0.00E+00
	8 0000 h	2.11E+00	5.27E-01	3.62E-01	9.56E-02	0.00E+00	0.00E+00	4.71E+00	1.01E+00	1.61E+01	3.46E+00	0.00E+00	0.00E+00
	8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.64E-02	2.93E-03	2.95E-01	1.00E-02	0.00E+00	0.00E+00
	24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.54E-06	4.54E-06	2.40E-02	1.55E-03	0.00E+00	0.00E+00
	96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.09E-05	4.00E-19	3.71E-05	1.37E-18	0.00E+00	0.00E+00
	720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.59E-19	0.00E+00	3.27E-18	0.00E+00	0.00E+00	0.00E+00
	TOTALS	7.74E+00	1.33E+00	1.33E+00	0.00E+00	0.00E+00	0.00E+00	8.18E+00	2.79E+01	2.79E+01	0.00E+00	0.00E+00	0.00E+00

		PHOTON-SUBMCG		BETA-SUBMCG		THYROID-INHAL		PHOTON-SUBMCG		BETA-SUBMCG		THYROID-INHAL	
		DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE
		mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
NR-89	0 5833 h	2.03E-01	3.47E-01	1.38E-01	2.37E-01	0.00E+00	0.00E+00	9.16E-03	1.60E-02	1.11E-01	2.18E-01	0.00E+00	0.00E+00
	1 5833 h	9.38E-05	9.38E-05	6.41E-05	5.41E-05	0.00E+00	0.00E+00	1.20E-03	1.10E-07	1.63E-02	1.50E-06	0.00E+00	0.00E+00
	2 0000 h	1.79E-10	4.31E-10	1.23E-10	2.94E-10	0.00E+00	0.00E+00	8.22E-09	4.42E-10	1.12E-07	6.01E-09	0.00E+00	0.00E+00
	4 0000 h	7.48E-13	3.74E-13	5.11E-13	2.55E-13	0.00E+00	0.00E+00	3.30E-11	2.41E-14	4.49E-10	3.27E-13	0.00E+00	0.00E+00
	8 0000 h	2.76E-24	6.90E-25	1.88E-24	4.71E-25	0.00E+00	0.00E+00	1.80E-15	4.44E-26	2.44E-14	6.03E-25	0.00E+00	0.00E+00
	8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.80E-27	2.01E-31	2.45E-26	2.74E-30	0.00E+00	0.00E+00
	24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.51E-32	0.00E+00	2.05E-31	0.00E+00	0.00E+00	0.00E+00
	96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
	720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
	TOTALS	2.03E-01	1.39E-01	1.39E-01	0.00E+00	0.00E+00	0.00E+00	9.36E-03	1.27E-01	1.27E-01	0.00E+00	0.00E+00	0.00E+00

		PHOTON-SUBMCG		BETA-SUBMCG		THYROID-INHAL		PHOTON-SUBMCG		BETA-SUBMCG		THYROID-INHAL	
		DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE
		mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
XE-131M	0 5833 h	8.25E-05	1.41E-04	5.37E-04	9.21E-04	0.00E+00	0.00E+00	1.43E-05	4.83E-05	7.8E-03	6.26E-03	0.00E+00	0.00E+00
	1 5833 h	1.41E-04	1.41E-04	9.18E-04	9.18E-04	0.00E+00	0.00E+00	4.37E-05	3.94E-05	5.65E-03	5.10E-03	0.00E+00	0.00E+00
	2 0000 h	5.86E-05	1.41E-04	3.82E-04	9.16E-04	0.00E+00	0.00E+00	2.58E-05	8.36E-05	3.34E-03	1.08E-02	0.00E+00	0.00E+00
	4 0000 h	2.80E-04	1.40E-04	1.82E-03	9.12E-04	0.00E+00	0.00E+00	3.39E-04	2.42E-04	4.39E-02	3.14E-02	0.00E+00	0.00E+00
	8 0000 h	5.54E-04	1.35E-04	3.61E-03	9.01E-04	0.00E+00	0.00E+00	1.32E-03	3.95E-04	1.71E-01	5.12E-02	0.00E+00	0.00E+00
	8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.44E-05	1.29E-06	4.46E-03	1.67E-04	0.00E+00	0.00E+00
	24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.87E-06	6.46E-08	8.89E-04	1.10E-05	0.00E+00	0.00E+00
	96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.81E-07	2.68E-13	6.23E-05	3.48E-11	0.00E+00	0.00E+00
	720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.53E-12	0.00E+00	1.98E-10	0.00E+00	0.00E+00	0.00E+00
	TOTALS	1.12E-03	7.27E-03	7.27E-03	0.00E+00	0.00E+00	0.00E+00	1.79E-03	2.32E-01	2.32E-01	0.00E+00	0.00E+00	0.00E+00

		PHOTON-SUBMCG		BETA-SUBMCG		THYROID-INHAL		PHOTON-SUBMCG		BETA-SUBMCG		THYROID-INHAL	
		DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE
		mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
XE-131M	0 5833 h	1.34E-03	2.30E-03	5.67E-03	9.72E-03	0.00E+00	0.00E+00	2.33E-04	7.85E-04	1.96E-02	6.59E-02	0.00E+00	0.00E+00
	1 5833 h	2.28E-03	2.28E-03	9.61E-03	9.61E-03	0.00E+00	0.00E+00	7.06E-04	6.33E-04	5.92E-02	5.31E-02	0.00E+00	0.00E+00
	2 0000 h	9.40E-04	2.24E-03	3.96E-03	9.51E-03	0.00E+00	0.00E+00	4.13E-04	1.34E-03	3.46E-02	1.12E-01	0.00E+00	0.00E+00
	4 0000 h	4.43E-03	2.22E-03	1.87E-02	9.35E-03	0.00E+00	0.00E+00	5.34E-03	3.79E-03	4.48E-01	3.18E-01	0.00E+00	0.00E+00
	8 0000 h	8.49E-03	2.12E-03	3.58E-02	8.95E-03	0.00E+00	0.00E+00	2.02E-02	5.95E-03	1.69E-01	4.99E-01	0.00E+00	0.00E+00
	8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.17E-04	1.53E-05	4.34E-02	1.62E-03	0.00E+00	0.00E+00
	24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.78E-05	1.07E-06	8.21E-03	8.99E-05	0.00E+00	0.00E+00
	96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.74E-06	1.57E-12	4.82E-04	1.32E-10	0.00E+00	0.00E+00
	720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.40E-12	0.00E+00	7.05E-10	0.00E+00	0.00E+00	0.00E+00
	TOTALS	1.75E-02	7.37E-02	7.37E-02	0.00E+00	0.00E+00	0.00E+00	2.75E-02	2.32E-01	2.32E-01	0.00E+00	0.00E+00	0.00E+00

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Pri-to-sec leak N₀ in UI LRA assuming 1% F.F. (non-equil) W/ 35 DELAY

E N V I R O N M E N T		B E T A - S U B M G		T H Y R O I D - I N H A L		P H O T O N - S U B M G		C O N T R O L R O O M		T H Y R O I D - I N H A L		
h	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE
	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
0 5833 h	5.63E-02	1.53E-01	2.66E-01	0.00E+00	0.00E+00	9.81E-03	3.31E-02	3.31E-02	5.37E-01	1.81E+00	0.00E+00	0.00E+00
1 5833 h	9.63E-02	2.65E-01	2.65E-01	0.00E+00	0.00E+00	2.98E-02	2.68E-02	2.68E-02	1.63E+00	1.47E+00	0.00E+00	0.00E+00
2 0000 h	3.99E-02	1.10E-01	2.64E-01	0.00E+00	0.00E+00	1.76E-02	5.69E-02	5.69E-02	9.61E-01	3.12E+00	0.00E+00	0.00E+00
4 0000 h	1.90E-01	5.23E-01	2.62E-01	0.00E+00	0.00E+00	2.30E-01	1.64E-01	1.64E-01	1.26E+01	8.98E+00	0.00E+00	0.00E+00
8 0000 h	3.73E-01	1.03E+00	2.56E-01	0.00E+00	0.00E+00	8.90E-01	2.65E-01	2.65E-01	4.87E+01	1.45E+01	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.30E-02	8.63E-04	8.63E-04	1.26E+00	4.73E-02	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.52E-03	5.39E-05	5.39E-05	2.48E-01	2.95E-03	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.01E-04	1.37E-10	1.37E-10	1.63E-02	7.51E-09	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.66E-10	0.00E+00	0.00E+00	4.19E-08	0.00E+00	0.00E+00	0.00E+00
TOTALS	7.56E-01	2.08E+00	0.00E+00	0.00E+00	0.00E+00	1.20E+00			6.59E+01		0.00E+00	

E N V I R O N M E N T		B E T A - S U B M G		T H Y R O I D - I N H A L		P H O T O N - S U B M G		C O N T R O L R O O M		T H Y R O I D - I N H A L		
h	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE
	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
0 5833 h	7.23E-02	1.48E-02	2.54E-02	0.00E+00	0.00E+00	7.98E-03	2.16E-02	2.16E-02	3.25E-02	8.78E-02	0.00E+00	0.00E+00
1 5833 h	1.75E-02	3.58E-03	4.13E-04	0.00E+00	0.00E+00	6.98E-03	1.20E-03	1.20E-03	2.84E-02	4.88E-03	0.00E+00	0.00E+00
2 0000 h	8.45E-04	2.03E-03	4.13E-04	0.00E+00	0.00E+00	3.92E-04	7.70E-04	7.70E-04	1.60E-03	3.14E-03	0.00E+00	0.00E+00
4 0000 h	4.02E-04	2.01E-04	4.11E-05	0.00E+00	0.00E+00	3.58E-04	6.97E-05	6.97E-05	1.46E-03	2.47E-04	0.00E+00	0.00E+00
8 0000 h	1.79E-06	4.48E-07	9.17E-08	0.00E+00	0.00E+00	3.11E-05	1.31E-07	1.31E-07	8.58E-05	5.35E-07	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.28E-09	1.11E-10	1.11E-10	3.78E-08	4.52E-10	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.86E-11	4.49E-33	4.49E-33	1.57E-10	1.83E-29	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.56E-30	0.00E+00	0.00E+00	6.34E-30	0.00E+00	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS	7.10E-02	1.86E-02	0.00E+00	0.00E+00	0.00E+00	1.57E-02			6.40E-02		0.00E+00	

E N V I R O N M E N T		B E T A - S U B M G		T H Y R O I D - I N H A L		P H O T O N - S U B M G		C O N T R O L R O O M		T H Y R O I D - I N H A L		
h	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE
	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
0 5833 h	8.23E-02	1.41E-01	1.57E-01	0.00E+00	0.00E+00	1.41E-02	4.72E-02	4.72E-02	3.31E-01	1.11E+00	0.00E+00	0.00E+00
1 5833 h	1.30E-01	1.57E-01	1.57E-01	0.00E+00	0.00E+00	4.12E-02	3.57E-02	3.57E-02	9.56E-01	8.39E-01	0.00E+00	0.00E+00
2 0000 h	5.23E-02	1.26E-01	1.48E-01	0.00E+00	0.00E+00	2.29E-02	7.35E-02	7.35E-02	5.39E-01	1.73E+00	0.00E+00	0.00E+00
4 0000 h	2.29E-01	1.14E-01	1.35E-01	0.00E+00	0.00E+00	2.70E-01	1.85E-01	1.85E-01	6.39E+00	4.34E+00	0.00E+00	0.00E+00
8 0000 h	3.64E-01	9.10E-02	1.07E-01	0.00E+00	0.00E+00	8.47E-01	2.29E-01	2.29E-01	1.99E+01	5.38E+00	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.98E-02	7.22E-04	7.22E-04	4.66E-01	1.70E-02	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.83E-03	1.51E-05	1.51E-05	6.65E-02	3.53E-04	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.05E-05	2.38E-13	2.38E-13	1.42E-03	5.59E-12	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.54E-13	0.00E+00	0.00E+00	2.24E-11	0.00E+00	0.00E+00	0.00E+00
TOTALS	8.61E-01	1.02E+00	0.00E+00	0.00E+00	0.00E+00	1.22E+00			2.86E+01		0.00E+00	

E N V I R O N M E N T		B E T A - S U B M G		T H Y R O I D - I N H A L		P H O T O N - S U B M G		C O N T R O L R O O M		T H Y R O I D - I N H A L		
h	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE	DOSE RATE	DOSE	DOSE RATE	DOSE	DOSE RATE
	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem	mrem/hr	mrem/hr	mrem	mrem/hr	mrem	mrem/hr
0 5833 h	3.23E-02	5.54E-02	4.83E-01	0.00E+00	0.00E+00	1.53E-03	3.09E-03	3.09E-03	2.64E-01	5.36E-01	0.00E+00	0.00E+00
1 5833 h	5.74E-05	5.01E-04	5.01E-04	0.00E+00	0.00E+00	2.78E-04	1.10E-07	1.10E-07	4.83E-02	1.92E-05	0.00E+00	0.00E+00
2 0000 h	1.26E-09	2.62E-09	2.29E-08	0.00E+00	0.00E+00	9.92E-09	1.28E-09	1.28E-09	1.72E-06	2.23E-07	0.00E+00	0.00E+00
4 0000 h	1.20E-11	5.99E-12	5.22E-11	0.00E+00	0.00E+00	1.17E-10	4.65E-13	4.65E-13	2.92E-08	8.07E-11	0.00E+00	0.00E+00
8 0000 h	4.43E-21	1.11E-21	9.65E-21	0.00E+00	0.00E+00	4.19E-14	8.61E-23	8.61E-23	7.27E-12	1.49E-20	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.86E-24	1.24E-27	1.24E-27	6.69E-22	2.14E-25	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.12E-28	0.00E+00	0.00E+00	1.94E-26	0.00E+00	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS	3.24E-02	2.82E-01	0.00E+00	0.00E+00	0.00E+00	1.80E-03			3.13E-01		0.00E+00	

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.0
 Pri-to-sec leak AQ in UI LRA assuming IX F.F. (non-equiv) W/ 35 DELAY

SE-135	PHOTON-SUBMG		BETA-SUBMG		ENVIRONMENT		THYROID-INHAL		PHOTON-SUBRG		BETA-SUBRG		CONTROL ROOM		THYROID-INHAL	
	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr	DOSE mrem	DOSE RATE mrem/hr
0 5833 h	5.87E-01	1.01E+00	3.03E-01	5.20E-01	0.00E+00	0.00E+00	6.26E-02	1.67E-01	6.43E-01	1.71E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
1 5833 h	1.22E-01	1.22E-01	6.28E-02	6.28E-02	0.00E+00	0.00E+00	5.05E-02	7.34E-03	5.19E-01	7.54E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2 0000 h	4.78E-03	1.15E-02	2.47E-03	5.92E-03	0.00E+00	0.00E+00	2.27E-03	4.23E-03	2.33E-02	4.34E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4 0000 h	1.98E-03	9.88E-04	1.02E-03	5.10E-04	0.00E+00	0.00E+00	1.78E-03	2.74E-04	1.82E-02	2.82E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 0000 h	5.49E-06	1.37E-06	2.83E-06	7.08E-07	0.00E+00	0.00E+00	8.75E-05	3.72E-07	8.98E-04	3.82E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.59E-08	2.80E-10	2.55E-07	2.87E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	8.97E-11	2.92E-31	9.21E-10	3.00E-30	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	9.38E-32	0.00E+00	9.63E-31	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS	7.16E-01	3.69E-01	3.69E-01	3.00E+00	0.00E+00	0.00E+00	1.17E-01	1.67E-01	1.20E+00	1.71E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00

ALL NUCLIDES																
0 5833 h	2.59E+00	4.44E+00	1.75E+00	3.00E+00	0.00E+00	0.00E+00	3.59E-01	1.12E+00	4.34E+00	1.33E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
1 5833 h	2.48E+00	2.48E+00	1.43E+00	1.43E+00	0.00E+00	0.00E+00	7.88E-01	5.81E-01	9.07E+00	6.67E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2 0000 h	8.12E-01	1.95E+00	4.68E-01	1.12E+00	0.00E+00	0.00E+00	3.54E-01	1.10E+00	4.06E+00	1.26E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
4 0000 h	2.90E+00	1.45E+00	1.72E+00	8.60E-01	0.00E+00	0.00E+00	3.27E+00	2.04E+00	3.91E+01	2.51E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 0000 h	3.08E+00	7.69E-01	2.23E+00	5.57E-01	0.00E+00	0.00E+00	6.96E+00	1.61E+00	1.03E+02	2.72E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
8 5000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.38E-01	4.80E-03	2.35E+00	8.56E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
24 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.51E-02	7.58E-05	3.75E-01	3.57E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
96 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.83E-04	1.39E-10	1.92E-02	8.10E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
720 0000 h	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	7.78E-10	0.00E+00	4.53E-08	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
TOTALS	1.19E+01	7.59E+00	7.59E+00	3.00E+00	0.00E+00	0.00E+00	1.19E-01	1.67E-01	1.62E+00	1.71E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00



ROW/COL	O-2 HOUR ISOTOPIC RELEASES		--- LOCKED ROTOR ACCIDENT		E= 5		F= 6		G= 7	
	A= 1	B= 2	C= 3	D= 4	E= 5	F= 6	G= 7	UCI	UCI	TOTAL
1>	NUCLIDE	CASE 1A	CASE 2A	CASE 3	CASE 4	CASE 5		CI		
2>		UCI	UCI	UCI	UCI	UCI				
3>	KR-83M		4. 12E+08		4. 28E+01					4. 12E+02
4>	KR-85M		1. 21E+09		2. 08E+02					1. 21E+03
5>	KR-85		1. 09E+08		1. 10E+03					1. 09E+02
6>	KR-87		1. 66E+09		1. 20E+02					1. 66E+03
7>	KR-88		3. 06E+09		3. 18E+02					3. 06E+03
8>	KR-89		1. 89E+08		9. 72E+00					1. 89E+02
9>	KR-90		0. 00E+00		0. 00E+00					0. 00E+00
10>	XE-131M		2. 36E+07		1. 07E+01					2. 38E+01
11>	XE-133M		1. 82E+08		3. 07E+02					1. 82E+02
12>	XE-133		7. 26E+09		2. 61E+03					7. 26E+03
13>	XE-135M		3. 60E+08		1. 07E+02					3. 60E+02
14>	XE-135		1. 84E+09		3. 20E+02					1. 84E+03
15>	XE-137		2. 95E+08		1. 59E+01					2. 95E+02
16>	XE-138		1. 09E+09		6. 67E+01					1. 09E+03
17>	I-131	2. 84E+07		6. 28E+04		1. 42E+05				2. 86E+01
18>	I-132	2. 44E+07		8. 72E+04		1. 12E+03				2. 45E+01
19>	I-133	5. 07E+07		1. 38E+05		8. 19E+03				5. 10E+01
20>	I-134	2. 33E+07		8. 23E+04		1. 96E+02				2. 34E+01
21>	I-135	4. 20E+07		1. 17E+05		3. 00E+03				4. 22E+01



0-8 HOUR ISOTOPIC RELEASES--LOCKED ROTOR ACCIDENT

ROW/CJL	A= 1	B= 2	C= 3	D= 4	E= 5	F= 6	G= 7
1>	NUCLIDE	CASE 1A	CASE 2A	CASE 3	CASE 4	CASE 5	TOTAL
2>		UCI	UCI	UCI	UCI	UCI	CI
3>	KR-83M		7.36E+08		4.28E+01		7.36E+02
4>	KR-85M		3.23E+09		2.08E+02		3.23E+03
5>	KR-85		4.33E+08		1.10E+03		4.33E+02
6>	KR-87		2.46E+09		1.20E+02		2.46E+03
7>	KR-88		6.78E+09		3.18E+02		6.78E+03
8>	KR-89		1.89E+08		9.72E+00		1.89E+02
9>	KR-90		0.00E+00		0.00E+00		0.00E+00
10>	XE-131M		9.43E+07		1.07E+01		9.43E+01
11>	XE-133M		6.99E+08		3.07E+02		6.99E+02
12>	XE-133		2.85E+10		2.61E+03		2.85E+04
13>	XE-135M		3.61E+08		1.07E+02		3.61E+02
14>	XE-135		5.94E+09		3.20E+02		5.94E+03
15>	XE-137		2.96E+08		1.59E+01		2.96E+02
16>	XE-138		1.09E+09		6.67E+01		1.09E+03
17>	I-131	2.75E+06		2.08E+06	6.28E+03	3.87E+05	2.77E+02
18>	I-132	9.13E+07		1.25E+06	1.12E+03	3.03E+04	9.26E+01
19>	I-133	4.40E+08		4.16E+05	8.19E+03	4.56E+05	4.45E+02
20>	I-134	3.95E+07		4.69E+05	1.96E+02	2.58E+03	3.90E+01
21>	I-135	2.82E+08		2.84E+06	3.00E+03	1.33E+05	2.85E+02