Docket No. 50-312

Mr. Joe Firlit Chief Executive Officer, Nuclear Rancho Seco Nuclear Generating Station 14440 Twin Cities Road Herald, California 95638-9799

Dear Mr. Firlit:

SUBJECT: AMENDMENT NO. 109 TO FACILITY OPERATING LICENSE NO. DPR-54 RANCHO SECO NUCLEAR GENERATING STATION (TAC NO. 63081)

The Commission has issued the enclosed Amendment No. to Facility Operating License No. DPR-54 for the Rancho Seco Nuclear Generating Station. This amendment consists of changes to the Technical Specifications (TS) in response to your letter dated September 24, 1986 and April 27, 1989.

This amendment revised TS 4.17, "Steam Generators," its bases, and associated Tables 4.17-2A and 4.17-2B to permit repairs of steam generator tubes by means of tube sleeves.

A copy of our Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's bi-weekly Federal Register notice.

Sincerely, /s/

George Kalman, Project Manager Project Directorate V Division of Reactor Projects III, IV, V and Special Projects

Enclosures:

Amendment No. 109to DPR-54

2. Safety Evaluation

cc w/enclosures: See next page

TAC NO. 63081

LOG p6 2/30

DISTRIBUTION

Docket File 50-312

T. Barnhart (4)
OC/LFMB

J. Lee

E. Jordan

DRSP/PDV JLee 5/30/89 DRSP/PDV GKalman:cw // /89

B. Grimes GPA/PA M. Virgilio D. Hagan

ACRS (10)
PD 5 Plant File
J. Calvo
Region V (4)

NRC/Local PDRs Wanda Jones GKalman OGC

OGC DRSP/D:PDV
GWKnighton
(1/89 (1/89

7/70-1 FOR ENTIR 6/2/89 DFOI

OFFICIAL RECORD COPY

906090216 890605 DR ADOCK 05000312 PDC



## UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

June 5. 1989

Docket No. 50-312

Mr. Joe Firlit Chief Executive Officer, Nuclear Rancho Seco Nuclear Generating Station 14440 Twin Cities Road Herald, California 95638-9799

Dear Mr. Firlit:

SUBJECT: AMENDMENT NO. 109 TO FACILITY OPERATING LICENSE NO. DPR-54 RANCHO SECO NUCLEAR GENERATING STATION (TAC NO. 63081)

The Commission has issued the enclosed Amendment No.109 to Facility Operating License No. DPR-54 for the Rancho Seco Nuclear Generating Station. This amendment consists of changes to the Technical Specifications (TS) in response to your letter dated September 24, 1986 and April 27, 1989.

This amendment revised TS 4.17, "Steam Generators," its bases, and associated Tables 4.17-2A and 4.17-2B to permit repairs of steam generator tubes by means of tube sleeves.

A copy of our Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's bi-weekly Federal Register notice.

Sincerely,

George Kalman, Project Manager

Project Directorate V

Division of Reactor Projects III, IV, V and Special Projects

Enclosures:

1. Amendment No. 109 to DPR-54

2. Safety Evaluation

cc w/enclosures: See next page Mr. Joe Firlit

Rancho Seco Nuclear Generating Station

cc:
Mr. David S. Kaplan, Secretary
and General Counsel
Sacramento Municipal Utility District
6201 S Street
P.O. Box 15830
Sacramento, California 95813

Thomas A. Baxter, Esq. Shaw, Pittman, Potts & Trowbridge 2300 N Street, N.W. Washington, D.C. 20037

Mr. Steven Crunk
Manager, Nuclear Licensing
Sacramento Municipal Utility District
Rancho Seco Nuclear Generating Station
14440 Twin Cities Road
Herald, California 95638-9799

Mr. Robert B. Borsum, Licensing Representative Babcock & Wilcox Nuclear Power Division 1700 Rockville Pike - Suite 525 Rockville, Maryland 20852

Resident Inspector/Rancho Seco c/o U. S. N. R. C. 14440 Twin Cities Road Herald, California 95638

Regional Administrator, Region V U.S. Nuclear Regulatory Commission 1450 Maria Lane, Suite 210 Walnut Creek, California 94596

Mr. Paul Szalinski, Chief Radiological Health Branch State Department of Health Services 714 P Street, Office Building #8 Sacramento, California 95814

Sacramento County Board of Supervisors 700 H Street, Suite 2450 Sacramento, California 95814 Mr. John Bartus Ms. JoAnne Scott Federal Energy Regulatory Commission 825 North Capitol Street, N. E. Washington, D.C. 20425

Ms. Helen Hubbard P. O. Box 63 Sunol, California 94586