

May 31, 1989

Docket No. 50-155

Mr. Kenneth W. Berry
Director, Nuclear Licensing
Consumers Power Company
1945 West Parnall Road
Jackson, Michigan 49201

Dear Mr. Berry:

DISTRIBUTION

~~Docket File~~

NRC & Local PDRs
GHolahan
LYandell
RPulsifer
OGC
DHagan
MJVirgilio
ARM/LFMB

BGrimes
TMeek (4)
Wanda Jones
EButcher
ACRS (10)
PD31 Plant Gray
EJordan
GPA/PA
LKelly

SUBJECT: AMENDMENT NO. 97 TO FACILITY OPERATING LICENSE NO. DPR-6:
(TAC NO. 59800)

The Commission has issued the enclosed Amendment No. 97 to Facility Operating License No. DPR-6 for the Big Rock Point Plant. This amendment consists of changes to the Technical Specifications in response to your application dated February 6, 1987, which superseded previous submittals dated September 30, 1985, March 4, April 21 and December 17, 1986, and the additional information provided by you on August 27, 1986.

This amendment revises Sections 11 and 12 by adding operability and surveillance requirements for the alternate shutdown system. This amendment also includes technical specifications for the active fire barriers and the fire detection instrumentation for the Auxiliary Shutdown Building. All these changes apply to equipment required by Appendix R to 10 CFR Part 50.

A copy of our related Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

/s/

Robert M. Pulsifer, Project Manager
Project Directorate III-1
Division of Reactor Projects - III, IV, V
& Special Projects
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 97 to
License No. DPR-6
2. Safety Evaluation

cc w/enclosures:

See next page

5520 (BIG ROCK AMEND 59800)

*PREVIOUSLY CONCURRED

LA/PD31:DRSP*

PShuttleworth

5/16/89

PM/PD31:DRSP*

RPulsifer

5/16/89

(A)PD/PD31:DRSP*

LYandell

5/18/89

OGC

5/30/89

/ECEB:DEST*

CMcCracken

05/18/89

8906090249 890531
FDR ADOCK 05000155
FDC

DFOL
11

Docket No. 50-155

Mr. Kenneth W. Berry
Director, Nuclear Licensing
Consumers Power Company
1945 West Parnall Road
Jackson, Michigan 49201

Dear Mr. Berry:

DISTRIBUTION

Docket File
NRC & Local PDRs
GHolahan
LYandell
RPulsifer
OGC
DHagan
MJVirgilio
ARM/LFMB

BGrimes
TMeek (4)
Wanda Jones
EButcher
ACRS (10)
PD31 Plant Gray
EJordan
GPA/PA
LKelly

SUBJECT: AMENDMENT NO. TO FACILITY OPERATING LICENSE NO. DPR-6:
(TAC NO. 59800)

The Commission has issued the enclosed Amendment No. to Facility Operating License No. DPR-6 for the Big Rock Point Plant. This amendment consists of changes to the Technical Specifications in response to your application dated February 6, 1987, which superseded previous submittals dated September 30, 1985, March 4, April 21 and December 17, 1986 plus additional information provided on August 27, 1986.

This amendment revises Sections 11 and 12 by adding operability and surveillance requirements for the alternate shutdown system. This amendment also includes technical specifications for the active fire barriers and the fire detection instrumentation for the Auxiliary Shutdown Building. All these changes apply to equipment required by Appendix R to 10 CFR Part 50.

A copy of our related Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Robert M. Pulsifer, Project Manager
Project Directorate III-1
Division of Reactor Projects - III, IV, V
& Special Projects
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. to
License No. DPR-6
2. Safety Evaluation

cc w/enclosures:
See next page

LA/PD31:DRSP
PShuttleworth
5/16/89

PM/PD31:DRSP
RPulsifer
5/16/89

(A)PD/PD31:DRSP
LYandell
5/18/89

OGC
5/ /89

/ECEB:DEST
CMcCracken
05/18/89

OK
DPW
5/18/89



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

May 31, 1989

Docket No. 50-155

Mr. Kenneth W. Berry
Director, Nuclear Licensing
Consumers Power Company
1945 West Parnall Road
Jackson, Michigan 49201

Dear Mr. Berry:

SUBJECT: AMENDMENT NO. 97 TO FACILITY OPERATING LICENSE NO. DPR-6:
(TAC NO. 59800)

The Commission has issued the enclosed Amendment No. 97 to Facility Operating License No. DPR-6 for the Big Rock Point Plant. This amendment consists of changes to the Technical Specifications in response to your application dated February 6, 1987, which superseded previous submittals dated September 30, 1985, March 4, April 21 and December 17, 1986, and the additional information provided by you on August 27, 1986.

This amendment revises Sections 11 and 12 by adding operability and surveillance requirements for the alternate shutdown system. This amendment also includes technical specifications for the active fire barriers and the fire detection instrumentation for the Auxiliary Shutdown Building. All these changes apply to equipment required by Appendix R to 10 CFR Part 50.

A copy of our related Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in dark ink, appearing to read "Robert M. Pulsifer", is written over the typed name.

Robert M. Pulsifer, Project Manager
Project Directorate III-1
Division of Reactor Projects - III, IV, V
& Special Projects
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 97 to
License No. DPR-6
2. Safety Evaluation

cc w/enclosures:
See next page

Mr. Kenneth W. Berry
Consumers Power Company

Big Rock Point Plant

cc:

Mr. Thomas A. McNish, Secretary
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201

Judd L. Bacon, Esquire
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201

Mr. Thomas W. Elward
Plant Manager
Big Rock Point Plant
10269 U.S. 31 North
Charlevoix, Michigan 49720

Mr. Bud Heeres
County Commissioner
303 Sheridan
Charlevoix, Michigan 49720

Office of the Governor
Room 1 - Capitol Building
Lansing, Michigan 48913

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Nuclear Facilities and Environmental
Monitoring Section Office
Division of Radiological Health
P. O. Box 30035
Lansing, Michigan 48909

U.S. Nuclear Regulatory Commission
Resident Inspector Office
Big Rock Point Plant
10253 U.S. 31 North
Charlevoix, Michigan 49720