

Northeast  
Nuclear Energy

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385-0128  
(860) 447-1791  
Fax (860) 444-4277

The Northeast Utilities System

MAY 26 1998

Docket No. 50-336  
B17259

Re: 10 CFR 50.73(a)(2)(i)

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555


Millstone Nuclear Power Station Unit 2  
Licensee Event Report 98-008-00  
Technical Specification Violations

This letter forwards Licensee Event Report (LER) 98-008-00, documenting an event that occurred at Millstone Nuclear Power Station, Unit No. 2, on April 23, 1998. This LER is being submitted pursuant to 10 CFR 50.73(a)(2)(i).

The NNECO's commitments made within this letter are included in Attachment 1.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

  
\_\_\_\_\_  
J. A. Price

Director - Millstone Unit No. 2

Attachments: 1. List of Regulatory Commitments  
2. LER 98-008-00

cc: H. J. Miller, Region I Administrator  
D. G. McDonald, Jr., NRC Senior Project Manager, Millstone Unit No. 2  
D. P. Beaulieu, Senior Resident Inspector, Millstone Unit No. 2  
W. D. Travers, Ph.D, Director, Special Projects Office  
P. F. McKee, Deputy Director of Licensing, Special Projects Office  
W. D. Lanning, Deputy Director of Inspections, Special Projects Office

9806020231 980526  
PDR ADOCK 05000336  
S PDR

1/1  
IE 27-

Docket No. 50-336  
B17259

Attachment 1

Millstone Nuclear Power Station, Unit No. 2

Commitments

May 1998

**Attachment 1**

**Regulatory Commitment Enclosure  
List of Regulatory Commitments**

The following table identifies those actions committed to by NNECO in this document.

REGULATORY COMMITMENT	COMMITTED DATE OR OUTAGE
B17259.01: The appropriate surveillance procedure has been revised to include the following checks for the Met Tower Technical Specification wind speed loops: verification of anemometer starting threshold, rotation of anemometer on the tower to a known RPM and readout of wind speed at the plant process computer.	Complete
B17259.02: A Technical Specification Change will be implemented which allows performance of the identified surveillances after entry into Mode 3. This activity will be completed prior to entry into Mode 4 from the current outage.	Mode 4 from current outage



Docket No. 50-336  
B17259

Attachment 2

Millstone Nuclear Power Station, Unit No. 2

LER 98-008-00

May 1998